NIHVA
NIHVA Technologies Pvt. Ltd.

# PRE DISPATCH INSPECTION REPORT

Format no.: NIHVA- QA-F-07
Rev. no.: 00
Rev date:
Date of origin: 01.01.2017

**Client Name-** Ingersoll Rand Ltd. | **Report No--**SO/23-24/0058(1)

**Project Name-** NTPL- | **Location-** NIHVA MANUFACTURING UNIT | **Date-22-02-2024**

**Product Name-** Motorized Single Skin Rolling Shutter (W8500xH4500mm) | **Qty-**01 NOS

| Sr.No | Part Name | Drawing no. | Dimension In mm | Qty per Product | Observation | | | Instrument used | Remark |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | 1 | 2 | 3 | | |
| 1 | Clear width | NIHVA/SO/23-24/058 | **8500** | **1** | OK | OK | OK | _ | OK |
| 2 | Clear height | NIHVA/SO/23-24/058 | **4500** | | OK | OK | OK | _ | OK |
| 3 | Curtain Length | NIHVA/SO/23-24/058 | 8660 ± 5 | 68 | 8658 | 8660 | 8659 | Steel Tape | OK |
| 4 | Curtain width | NIHVA/SO/23-24/058 | 75 ± 1.5 | | 76.36 | 76.45 | 76.37 | Digital Vernier caliper | OK |
| 5 | Curtain Thickness | NIHVA/SO/23-24/058 | 1.2 ± 0.2 | | 1.2 | 1.2 | 1.21 | Digital Micrometer | OK |
| 6 | Curtain Profile | NIHVA/SO/23-24/058 | Curved | | OK | OK | OK | Visual | OK |
| 7 | Hood cover length | NIHVA/SO/23-24/058 | 9100 | 1 | 9100 | _ | _ | Steel Tape | OK |
| 8 | Hood cover width | NIHVA/SO/23-24/058 | 500 | | 501 | _ | _ | Steel Tape | OK |
| 9 | Hood cover height | NIHVA/SO/23-24/058 | 500 | | 502 | _ | _ | Steel Tape | OK |
| 10 | Hood cover thickness | NIHVA/SO/23-24/058 | 0.8 ± 0.1 | | 0.760 | _ | _ | Digital Micrometer | OK |
| 11 | Roller Length | NIHVA/SO/23-24/058 | 9070 ± 5 | 1 | 9070 | _ | _ | Steel Tape | OK |
| 12 | Roller dia. | NIHVA/SO/23-24/058 | 140 ± 2 | | 139.42 | | | Digital Vernier caliper | OK |
| 13 | M.S. Bottom length | NIHVA/SO/23-24/058 | 8660 ± 8 | 1 | 8653 | _ | _ | Steel Tape | OK |
| 14 | M.S. Bottom width | NIHVA/SO/23-24/058 | 125 ± 2.5 | | 127.5 | _ | _ | Digital Vernier caliper | OK |
| 15 | M.S. Bottom thickness | NIHVA/SO/23-24/058 | 2 ± 0.2 | | 2.037 | _ | _ | Digital Micrometer | OK |
| 16 | Guide length | NIHVA/SO/23-24/058 | 4650 ± 5 | 2 | 4654 | 4655 | _ | Steel Tape | OK |
| 17 | Guide section | NIHVA/SO/23-24/058 | 150 x 95 | | 138 x 100 | 135 x 100 | _ | Steel Tape | Conditionaly accepted |
| 18 | Guide thickness | NIHVA/SO/23-24/058 | 3 ± 0.2 | | 3.071 | 3.022 | _ | Digital Micrometer | OK |
| 19 | M.S. Bracket (LxW) | NIHVA/SO/23-24/058 | 500x500 | 2 | 499 x 498 | 501 x 499 | _ | Steel Tape | OK |
| 20 | M.S. Bracket thickness | NIHVA/SO/23-24/058 | 8 ± 0.5 | | 8.069 | 8.047 | _ | Digital Micrometer | OK |
| 21 | Motor -Jielong 3PH, Indirect drive, Capacity-2000kg | | | 1 | OK | _ | _ | Visual | OK |
| 22 | Surface Finish | NIHVA/SO/23-24/058 | RAL 9010 | _ | OK | OK | OK | Visual | OK |
| 23 | Coating thickness | NIHVA/SO/23-24/058 | 70-90 µ | _ | 94.5 µ | 70.8 µ | 90.2 µ | DFT Meter | OK |
| 24 | Product name plate | NIHVA/SO/23-24/058 | | | SR. NO.- NMRS1037 | | | Visual | OK |
| 25 | Handle | NIHVA/SO/23-24/058 | | | Not welded | | | | NOT OK |

**Remark- All Material Are visually & dimensionally found ok**

**Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk**

NIHVA TECHNOLOGIES PVT. LTD. PUNE

**Inspected By**- Maruti Yamgar

**Approved By-** Amit Kurhade

NIHVA
NIHVA Technologies Pvt. Ltd.

# PRE DISPATCH INSPECTION REPORT

Format no.: NIHVA- QA-F-07
Rev. no.: 00
Rev date:
Date of origin: 01.01.2017

**Client Name-** Ingersoll Rand Ltd. | **Report No--**SO/23-24/0058(3)

**Project Name-** NTPL- | **Location-** NIHVA MANUFACTURING UNIT | **Date-22-02-2024**

**Product Name-** Motorised Double Wall Rolling Shutter(W4260xH2440 mm) | **Qty-**01 NOS

| Sr.No | Part Name | Drawing no. | Specification | Qty per Product | Observation | | | Instrument used | Remark |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | 1 | 2 | 3 | | |
| 1 | Curtain Length | NIHVA/SO/23-24/058 | 4390 ± 8 | 28 | 4395 | 4394 | 4395 | Steel Tape | OK |
| 2 | Curtain width | NIHVA/SO/23-24/058 | 95 ± 1.5 | | 120.42 | 120.4 | 120.38 | Digital Vernier caliper | Not OK |
| 3 | Curtain Thickness | NIHVA/SO/23-24/058 | 19 ± 1 | | 19.36 | 19.32 | 19.4 | Digital Vernier caliper | OK |
| 4 | Curtain Profile | NIHVA/SO/23-24/058 | Curved | | OK | OK | OK | Visual | OK |
| 5 | M.S. Bottom length | NIHVA/SO/23-24/058 | 4390 ± 8 | 1 | 4391 | _ | _ | Steel Tape | OK |
| 6 | M.S. Bottom width | NIHVA/SO/23-24/058 | 125 ± 2.5 | | 118 | _ | _ | Digital Vernier caliper | Not OK |
| 7 | M.S. Bottom thickness | NIHVA/SO/23-24/058 | 2 ± 0.2 | | 2.1 | _ | _ | Digital Vernier caliper | OK |
| 8 | Roller Length | NIHVA/SO/23-24/058 | 4500 ± 8 | 1 | 4500 | _ | _ | Steel Tape | OK |
| 9 | Roller dia. | NIHVA/SO/23-24/058 | 160 ± 2 | | 162 | _ | _ | Digital Vernier caliper | OK |
| 10 | Hood cover Length | NIHVA/SO/23-24/058 | 4650 ± 8 | 1 | 4649 | _ | _ | Steel Tape | OK |
| 11 | Hood cover width | NIHVA/SO/23-24/058 | 385 ± 2.5 | | 390 | _ | _ | Steel Tape | Conditionaly accepted |
| 12 | Hood cover thickness | NIHVA/SO/23-24/058 | 0.9 ± 0.2 | | 0.75 | _ | _ | Digital Vernier caliper | OK |
| 13 | Guide length | NIHVA/SO/23-24/058 | 2590 ± 8 | 2 | 2440 | 2440 | _ | Steel Tape | Not OK |
| 14 | Guide width | NIHVA/SO/23-24/058 | 110 ± 1.5 | | 78.1 | 78.14 | _ | Digital Vernier caliper | Not OK |
| 15 | Guide thickness | NIHVA/SO/23-24/058 | 2 ± 0.2 | | 3.02 | 3 | _ | Digital Vernier caliper | Conditionaly accepted |
| 16 | M.S. Bracket (LxW) | NIHVA/SO/23-24/058 | 380 X 380 | 2 | 385 X 392 | 386 X 391 | _ | Steel Tape | Conditionaly accepted |
| 17 | M.S. Bracket thickness | NIHVA/SO/23-24/058 | 5 ± 0.5 | | 2.5 | 2.5 | _ | Digital Vernier caliper | Not OK |
| 18 | Motor -Jielong 1PH Indirect drive | | | Xiamen Universal Electronic Co. Ltd 1Ph 600 kg | | | | Visual | Not OK |
| 19 | Surface Finish | RAL 9010 | | _ | OK | OK | OK | Visual | OK |
| 20 | Product name plate | NIHVA/SO/23-24/058 | | | SR. NO.- NDWRS1038 | | | Visual | OK |
| 21 | Visual | NIHVA/SO/23-24/058 | | | | | | | OK |
| 22 | Handle | NIHVA/SO/23-24/058 | | | NOT WELDED | | | | Not OK |

**Remark- All Material Are visually & dimensionally found ok**

**Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk**

**Inspected By-** Maruti Yamgar

NIHVA TECHNOLOGIES PVT. LTD. PUNE

**Approved By-** Amit Kurhade