NIHVA Technologies Pvt. Ltd.

RADIANT SAFEDOORS PVT. LTD.

SPECIFICATION SHEET

FIRE DOORS (120 Minutes)
(CONFORMS TO IS: 3614 (PART - II), 1992 & BS: 476 (PART 20 & 22

Auto Sliding Door:

This type of door is fabricated from GI / MS sheet having thickness of 18 SWG with overall panel thickness of 40 / 42 mm. Mineral Wool is used as an infill material to provide with integrity, stability and insulation. This door can be made in Single leaf or Double leaf (Bi-parting Door) or depending upon the requirement and suit the application and conditions prevailing at site. This door comprises of Sliding Rail to guide the panel, fusible link (fire rated at 68 deg.C), wire rope, bottom rollers to guide the panel at the bottom, counter weights etc. This door is always kept into open position and at the time of fire break, fusible link melts which allows the counter weight hung to the wire rope to pull the panel automatically close and to prevent fire from spreading further. Standard accessories are included in the supply.

FINISH

The door are primed with Zinc-Phosphate Stoving Primer and finished with two coats of Polyurethane paint as required up to a minimum of 70 microns.

NIHVA Technologies Pvt. Ltd.
187, G-Block, Thermax chowk, MIDC
Chinchwad, Pune – 411019.
Phone: +91 (0) 2066304033