AN ISO 9001:2015 & ISO 45001:2018 Certified Company. Govt. of Maharashtra
Approved License Agency. License No. MFS / LA / RF-534 / RD-514.

Surya Fire Safety Enterprises

At/Post- Chandapuri, Piliv, Tal- Malshiras, Dist.-Solapur Pin Code-413310 (Maharashtra- India).
Mob-9637348585, 9545149193 Web- www.suryafiresafety.com E-Mail: suryafiresafety22@gmail.com

Ref. No: SFSE/23-24/0582 **Date: 11/12/2023**

CERTIFICATE

TO WHOME SO EVER IT MAY CONCERN

This is to certify that following fire extinguisher installed on the premises of **M/s. NIHVA TECHNOLOGIES PRIVATE LIMITED. AT: - PLOT NO-187 FIRST FLOOR ABOVE RENAULT SHOWROOM THERMAX CHOWK MIDC CHINCHWAD 411019** Has been **Refilling** by our company as per IS 2190 standards on **11 DEC. 2023**.

Sr. No:	Type of Fire Extinguisher	Serial No.	Hydro Testing Pressure	Working Pressure	Remark
1	ABC Powder Base Stored Pressure Type Fire Extinguisher Capacity-**4kg.**	4142.	28 Bar	14 Bar	Satisfactory
2	CO2 Gas Base Type Fire Extinguisher Capacity-**4.5kg.**	2141.	250 Bar	55 Bar	Satisfactory
3	ABC Powder Base Stored Pressure Type Fire Extinguisher Capacity-**6kg.**	669, 1735.	28 Bar	14 Bar	Satisfactory
4	DCP Cartridge Type Fire Extinguisher Capacity-**5Kg.**	7265.	28 Bar	14 Bar	Rejected

DCP Cartridge Type Fire Extinguisher Rejected Remark: Body Damaged.

Total Fire Extinguisher – 05Nos.
Next Due Date of Refilling: - **10 DEC 2024.**
For Surya Fire Safety Enterprises

Fire Safety Enterprises

Note: -Daily Inspection of Fire Extinguisher Is Mandatory as It Is a Life and Property Saving Device.