	The thickness of the sheets shall be suitable for the mechanical stress and wind loads subject to a minimum thickness of 1.20 mm in case of CRCA sheets and 0.80 mm in case of high yield strength cold rolled Galvalume/Zincalume steel having minimum **345 Mpa** yield strength. The louvers shall be stationary blade, horizontal type, minimum 150mm deep, 45 Degree, hurricane duty and shall provide full visual screening from horizontal sight line or below. The vertical space between two louver blades shall not exceed 80 mm. The total area of opening of the louver ventilator shall be approximately 35% of the total louver face area. The louver blades shall be provided with suitable framing arrangement, fixing screws and POP rivets, sealant, flashing, trims etc. All gaps between the louver blades and the framework shall be sealed using UV resistant weathering sealant. The colour of the, flashing and trims shall match with the colour of the wall cladding sheets or as approved by EIC. **Fly Mesh:** The louvers shall be provided with easily removable SS fly mesh with necessary frames. The louvers shall be designed for wind loads up to 7.18 kPa (7180 Newtons/Sq.Mtr) without damage and ingress of water in to the building. Lovers shall be provided with test certificates for wind load withstand, water ingress and opening area. The cost to include preparation and submission of working drawings for approval, all materials tools tackles, consumables like sealants etc complete as per specification, approved drawings and as directed by EIC **Recommended and Benchmarked Product: Qubic Wheels, Chennai,**				
1ID4VNS1.1	1200 (W) x 2300 mm (H) **(For Boiler Room)**	Nos	8.00		
1ID4VNS1.2	Continuous Length Louvers x 1200 mm (H) **(For Utility Building)**	Sq.m	134.00		
CJ1RS1	**GI Rolling Shutters, Push-Pull Type, Hand Operated, Painted:** Providing, assembling, erecting in position rolling shutters of approved make as per the following specification **Shutter:** Shutter shall be made of G.I laths, 18 G thick, 80 mm wide, interlocked and held together throughout their length using 10mm dia. hard drawn seamless tubes and the end sealed with GI clips, 10G reinforced lock plate riveted to 40 x 40 x 6mm angle with 40 x 40 x 6mm stiffener welded on rear side, necessary locking arrangements from inside and outside,. The assembly shall be mounted on specially designed pipe shaft with superior flat springs, bearing arrangement and with all other necessary fixtures for the shutter. **Shutter Guides:** The side guide and bracket arrangements shall be made out of GI channel 75 x 25 x 3.15 mm thick. **Operating Mechanism:** Manually operated, Push-Pull Type				