


DRAWING







Section S1–S1
Frame Details



HANDING DETAILS

LHR 		LEFT HAND REVERSE
RHR 		RIGHT HAND REVERSE

NOTES :–
Frame Joint Type :– Bolted joint
Frame Profile(DxH):– 100 x 57mm.
RAL Shade Code :– RAL
Infill :– Honey Comb
Type :– 2Hr un–insulated door as per IS 3614–2021

Hardware/Accessories Description

1. SS BB Hinges "4x3x3"–Geze
2. Door Closer Std Arm – Geze TS 1000
3. One & Two Point Panic Bar with vertical rod– Geze
4. External trim with half EPC – Geze
5. 2 Hr.Fire Rated Vision Glass 300 x 450mm
6. Concealed Drop Seal
7. Door Stopper

NOTE :

DOUBLE EQUAL LEAF DOOR

LOCATION :

WH01A		WH01B		WH02		WH03		WH04		TOTAL
LHR	RHR	LHR	RHR	LHR	RHR	LHR	RHR	LHR	RHR	
1 NOS		1 NOS		0 NOS		0 NOS		0 NOS		2 NOS

TITLE - DOOR AUTOMATION
DWG NO - NTPL-308-PM-02

	NAME	SIGNATURE	DATE
DRAWN	J.P.		10-12-2025
CHK'D	B.S.		10-12-2025
APPV'D	V.T.		10-12-2025

IF ANY QUERIES CONTACT - Design@nihva.com
ALL DIMENSIONS ARE IN 'MM' A2

NIHVA TECHNOLOGIES PVT.LTD.PUNE
Website - www.nihva.com

PRODUCT - FIRE RATED DOOR
PROJECT NO - NTPL- 308 | REVISION - 01
SITE LOCATION - CHENNAI
MATERIAL - | QTY - 2
PROJECTION METHOD | SCALE :
SHEET 1 OF 1