NIHVA	PRE DISPATCH INSPECTION REPORT						NIHVA - QA - F - 07
Client Name : - Glatt							Report No : - PDIR-Glatt-01
Project Name :- Glatt			Location :- NIHVA Shop				Date :- 07-07-2023
Product Name :- Automatic Rolling Shutter (8000W×8150H)							
Sr.No.	Part Name	Drawing No.	Dimesion in mm	Qty per product	Observation		Remarks
					1	2	
1	Solid Slat (H×W×T)	NIHVA/23-24/VDR/0153	8150W x 1.2	212	8150WX1.2	8150X 1.2	Acceptable
2	Honey Comb Grill (WxH)	NIHVA/23-24/VDR/0153	8150W x 1500H	2	8150W X1500H	8150 X 1500	Acceptable
3	PIPE Shaft (L×D)	NIHVA/23-24/VDR/0153	8250 X 164	2	8250X165	8250X165	Acceptable
4	Hood Cover (L×W×T)	NIHVA/23-24/VDR/0153	8650 X 535 X 0.8	2	8650X535X0.8	8650X535X0.8	Acceptable
5	M.S Bottom (L×W×T)	NIHVA/23-24/VDR/0153	8150Lx 2T	2	8150LX2X130W	8150 X 2X130W	Acceptable
6	Guide (H×W×T)	NIHVA/23-24/VDR/0153	8150 H X 115 W X 2 T	4	8150HX115W x95x2	8150 X115X 95 X2	150mm short (Not Acceptable)
7	Side Bracket (L×W×T)	NIHVA/23-24/VDR/0153	535L X 535W X 5T	4	530X530X5	530X530X5	Acceptable
8	Motor Cover (L×W×H×T)	NIHVA/23-24/VDR/0153	600L X 400W X 350H	2	600X400X	600X400X	Acceptable.

Remark : All the dimensionally ~~accepted~~ observations are found ok, except Guide height 150mm short as per required. But riveting of hood cover is extra visible, it should be cleared before powder coating.

Rohit Pawar
Inspected By

Rohit Pawar
Checked By
07/07/2023