NIHVA
NIHVA Technologies Pvt. Ltd.

PRE DISPATCH INSPECTION REPORT

Format no.: NIHVA- QA-F-07	
Rev. no.: 00	
Rev date:	
Date of origin: 01.01.2017	

Client Name- SHREE PRE FAB STEELS PVT LTD — **Report No--**SO/23-24/059(1)

Project Name- NTPL-208 — **Location-** NIHVA MANUFACTURING UNIT — **Date-12-03-2024**

Product Name- GI 1.2mm Gear Opearated Rolling Shutter (W 6000 mm X H 6000 mm) — **Qty-**01 NOS

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain Length	NIHVA 22-23 SO 060	6150 ± 8	90	6150	6148	6152	Steel Tape	OK
2	Curtain width	NIHVA 22-23 SO 060	75 ± 1.5		76.26	76.48	76.37	Digital Vernier caliper	OK
3	Curtain Thickness	NIHVA 22-23 SO 060	1.2 ± 0.2		1.21	1.22	1.2	Digital Micrometer	OK
4	Curtain Profile	NIHVA 22-23 SO 060	Curved		OK	OK	OK	Visual	OK
5	M.S. Bottom length	NIHVA 22-23 SO 060	6150 ± 8	1	6150			Steel Tape	OK
6	M.S. Bottom width	NIHVA 22-23 SO 060	125 ± 2.5		127.26	_	_	Digital Vernier caliper	OK
7	M.S. Bottom thickness	NIHVA 22-23 SO 060	2 ± 0.2		1.996	_	_	Digital Micrometer	OK
8	Bottom lock	NIHVA 22-23 SO 060	[illegible]	2	OK	_	_	Visual	OK
9	Shaft assembly	NIHVA 22-23 SO 060		1	OK			Visual	OK
10	Hood cover Length	NIHVA 22-23 SO 060	6700 ± 8	1	6700	_	_	Steel Tape	OK
11	Hood cover width	NIHVA 22-23 SO 060	450 ± 4		452	_	_	Steel Tape	OK
12	Hood cover height	NIHVA 22-23 SO 060	450 ± 4		450	_	_	Steel Tape	OK
13	Hood cover thickness	NIHVA 22-23 SO 060	0.9 ± 0.2		0.8	_	_	Digital Micrometer	OK
14	Guide length	NIHVA 22-23 SO 060	6150 ± 8	2	6153	6155	_	Steel Tape	OK
15	Guide width	NIHVA 22-23 SO 060	130 ± 2.5		130	131	_	Steel Tape	OK
16	Guide thickness	NIHVA 22-23 SO 060	3.0 ± 0.2		3.028	3.026	_	Digital Micrometer	OK
17	M.S. Bracket (LAW)	NIHVA 22-23 SO 060	450x450	2	OK	OK	_	Steel Tape	OK
18	M.S. Bracket thickness	NIHVA 22-23 SO 060	5 ± 0.5		4.971	5.013	_	Digital Micrometer	OK
19	Gear Box & Handle	NIHVA 22-23 SO 060		1				Visual	OK
20	Product name plate			1	NGRS1078			Visual	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

NIHVA TECHNOLOGIES PVT. LTD. ★ PUNE ★

Approved By- Amit Kurhade