		Format No.: QA-F-18 Rev.no. : 00 Date : 10.10.2017

APL APOLLO TUBES LIMITED UNIT-III

Works-Vill-Kudavali Plot No-M-1, Murbad, 421401, Thane (MS)

TEST CERTIFICATE FOR STEEL TUBES

IS: 4923

CM/L-3850769

TEST CERTIFICATE NO :	**IS4923/210/IS01237**
DATE :	**24-06-23**
INVOICE NO	**1805823775**
INVOICE DATE	**24-06-23**

M/s APL APOLLO TUBES LIMITED, PUNE

We certify that the material described below fully conformed to IS 4923 : 2017. Chemical composition and Mechanical properties of the product, as tested in tested in accordance with the scheme of testing and inspection contained in the BIS certification marks license no. CM/L-3850769 are as indicated below against each order no.

TEST RESULT

Size	Grade/ Type	**HEAT NO./ BATCH NO.**	PCS.	Actual Wt (MT)	CHEMICAL ANALYSIS (% Max)				MECHANICAL PROPERTIES (Min)			GALVANIZING (Min)	
					C	Mn	P	S	Tensile Strength (Mpa)	Yeild Strenth (Mpa)	%El	Weight (g/m2)	Uniformity
Requirements					0.12	0.60	0.04	0.04	330	210	20	N/A	N/A
100 X 100 X 6.00 mm	BLK SHS (YST-210)	**19300880/ 8190313A**	79	7.19	0.047	0.152	0.011	0.005	397	302	30	_	_
100 X 100 X 3.20 mm	BLK SHS (YST-210)	**19200850/ 6190317B**	15	1.22	0.041	0.15	0.012	0.005	397	302	32	_	_
200 X 200 X 8.00 mm	BLK SHS (YST-210)	**L36488/ 8190219B**	10	2.25	0.161	0.933	0.011	0.0142	402	305	34	_	_
172 X 92 X 5.20 mm	BLK RHS (YST-210)	**19200847/ 8190316A**	23	2.82	0.046	0.137	0.011	0.006	403	303	32	_	_
100 X 100 X 4.50 mm	BLK SHS (YST-210)	**19200850/ 6190317B**	16	1.15	0.041	0.15	0.012	0.005	397	302	32	_	_
80 X 40 X 4.00 mm	BLK RHS (YST-210)	**55356J/ 6190307B**	40	1.7	0.059	0.38	0.017	0.05	372	279	38	_	_

It is certified that Material supplied conforms to standard dimensions and mass tolerances.

AUTHORISED SIGNATORY

Original

PREPARED BY

FOR APL APOLLO TUBES LIMITED