MEGADOOR

ASSA ABLOY

Created with PTC Mathcad Express. See www.mathcad.com for more information.

Calculation of uniformly loaded intermediate beam

Project: **ARRF4 Delhi Fire Station**
Project number/Door number: 22246 - 22249
Date: 210930
Name: Mats Brännström

Profile type: 100x30 -680

Nominal differential pressure: $P := 1150 \cdot \frac{N}{m^2}$

Fabric contribution: $cf := 1.0$

Reduction factor due to profile rotation: $rf := 0.96$

Actual pressure to be supported by intermediate beam: $p := \frac{P}{cf}$ $p = 1150 \frac{N}{m^2}$

Moment of inertia: $I := rf \cdot 1170000 \cdot mm^4$ $I = 1123200\ mm^4$

Support distance: $l := 5800 \cdot mm$

Plastic section modulus: $Z := rf \cdot 27000 \cdot mm^3$ $Z = 25920\ mm^3$

Yield point: $\sigma_y := 240 \cdot \frac{N}{mm^2}$

Modulus of elasticity: $E := 70000 \cdot \frac{N}{mm^2}$

Safety factor acc. to EN 12604: $n_s := 1.5$

Allowable stress: $\sigma_a := \frac{\sigma_y}{n_s}$ $\sigma_a = 160 \frac{N}{mm^2}$

Max allowed beam spacing: $d. := \frac{\sigma_a \cdot 8 \cdot Z}{l^2 \cdot p}$ $d. = 857.6\ mm$

Actual spacing: $d := 801 \cdot mm$

Beam stress at actual spacing: $\sigma := \frac{d}{\left(\frac{8 \cdot Z}{l^2 \cdot p}\right)}$ $\sigma = 149 \frac{N}{mm^2}$

Apparent shortening: $\Delta := \int_{0 \cdot mm}^{l} \sqrt{1 + \left(\frac{\mathrm{d}}{\mathrm{d}x}\left(\frac{5 \cdot d \cdot l \cdot p \cdot l^3}{384 \cdot E \cdot I} \cdot \left(1 - \frac{4 \cdot x^2}{l^2}\right) \cdot \left(1 - \frac{4 \cdot x^2}{5 \cdot l^2}\right)\right)\right)^2}\ \mathrm{d}x - l$

$\Delta = 12.757\ mm$

Deflection: $\delta := \frac{5 \cdot d \cdot p \cdot l^4}{384 \cdot E \cdot I}$ $\delta = 173\ mm$

Deflection limits are L/30 for aluminum and L/120 for steel.

Created with PTC Mathcad Express. See www.mathcad.com for more information.