Fire-Proof Steel Roller Shutter



Door type	Fire Rated Rolling Shutter	PL. indicate your requirement
Description	Fire-proof steel roller shutter Tested in acc. with STN EN 13501-2: 2005. (EW 60, EW 45, EW 30 and E 60) Operating values correspond to door standard EN	
Installation In	Walls for guide rails: Permanent wall construction with a mean density of at least 613 kg/m3 and min. wall thickness of 250 mm. Header for consoles: Permanent wall construction with a mean density of at least 1,200 kg/m3 and min. wall thickness of 250 mm.	
Dimensions	Ordering dimensions for: ➢ EW 60, E 60 Width: 1000 – 2500 mm Height: 1000 – 2450 mm ➢ EW 45, EW 30 Width: 1000 – 6000 mm Height: 1000 – 6000 mm	
Surface:	Galvanized steel	
Shutter curtain	Consisting of hinge-like interconnected galvanized steel profiles	
Profile	Double-skinned 1 mm galvanized steel, filled with mineral wool	
Bottom seal retainer:	Double-skinned box profile made of galvanized steel L-shaped profiles and C-shaped profiles (23 x 8) mm with rubber seal	
Guide rails:	Galvanized steel profiles 2.5 mm (82 x 110 mm) with wear-proof guides	
Winding shaft	Prime-coated steel tube in accordance with DIN 2458 with shafts welded onto each side for drive, anti-drop device or bearing support	
Header seal	As standard	
Consoles	Made of 4 mm thick sheet steel	
Drives and controls	Direct mount drive with integrated anti-drop device or chain drive with separate anti-drop device. • **Version 1. (standard):** Electric, type TAR (direct mount drive) 400 V,	

	50 Hz, 60% ED (power-on time), IP 54, emergency handcrank Electric, type TKR (chain drive) 400 V, 50 Hz, 40% ED (power-on time), IP 54, emergency handcrank Control AS 210 pulse, IP 65, 24 V, safety edge mechanism (SKS) via opto-sensors, fully wired, CEE plug 16A / 5-wire with IP 44 • **Version 2. (at additional charge):** Electric, type FDF (direct mount drive) incl. 24 V DC motor for closing during power failure. Control FS 345 pulse, with battery buffer, charger, acoustic signal, safety edge mechanism (SKS) via optosensors, fully wired, CEE plug 16A / 5-wire with IP 44 According to the manufacturer's specifications, the system must be checked once every four weeks!	
Further documents	Refer to the installation data for the exact dimensions of lateral buffers and headroom requirements. Each shutter is supplied with an individually, dimensioned assembly drawing. Please contact us about installation in unusual locations.	