




Inside Elevation




Top View

DOOR OPENING LEFT HAND REVERSE(OPTION 3)

Abbrevation's:
WOW-Wall Opening Width
WOH-Wall Opening Height
UC-Under Cut
FFL-Finished Floor Level

## ASSESORIES DETALES

(a) HINGES: 3 No. SS Ball bearing butt hinges 100x75x3mm


(b) LOCK : Mortise lock with half cylinder
Push Bar
External trim

(c) DOOR CLOSER: Door Closer

(d) GLASS : 1No. Clear fire Vision Glass size 200x300mm.

Shutter thickness : 47 mm
Frame Sheet thick : 1.20mm
Shutter sheet thick : 0.80mm
Fixing : On Soliid Brick plasterd wall with Anchors

NOTE:- *All Dimensions are in mm.
*Tolerance:-All Linear Dimensions ±3mm,Others ±0.5mm.
*The Drawing Is For Location of Hardware only. Drawing Does Not Represent The Hardware For More Clarity, Please Go Through Hardware Broucher.




Detail view of Section A

| FIRE DOOR SIZES | | |
|---|---|---|
| WOW | WOH | QUANTITY |
| 1000 | 2100 | 1 |

COLOR:-RAL 7035

This drawing & designing is the property of NIHVA TECHNOLOGIES. Not be sold or copy to any other concern.

Fire Door

CLIENT APPROVAL

ALL DIMENSION ARE IN mm

| | NAME | DATE | SIGN. |
|---|---|---|---|
| DRAWN | OMKAR | 29/02/16 | |
| CHECK | ANIL | 29/02/16 | |
| REV. | 00 | | |
| APPRD. | | | |
| MFG | | | |

NIHVA TECHNOLOGIES PVT. LTD.
NIHVA TECHNOLOGY PVT. LTD. PUNE
Tel : 020 66304033
Email:- info@nihva.com
Website:-www.nihva.com

CLIENT - S.S.GHORPADE
PROJECT -
SITE -
DWG. NO. - NIHVA/15-16/202
SCALE: 01 | WT: | SHEET: 01 OF 01
If any queries contact : projects@nihva.com