CLASSIFICATION REPORT OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1: 2007 + A1:2009 Valid 5 years from the date of issue of this classification report

1 Foreword

The product mentioned in this classification report is the object neither of a harmonized European standard, nor an European document of evaluation (EAD) leading to its CE marking, according to the European regulation n°305/2011 for construction product.

2 Introduction

This classification report defines the classification assigned to **« H6771 megaroller 700FR all colors »** (as described by the sponsor) in accordance with the procedure given in EN 13501-1: 2007 + A1: 2009

Sponsor:	**Heytex Bramsche GmbH** **Heywinkelstraβe** **D-49565 Bramsche** **Germany**
Prepared by :	**IFTH** **Avenue Guy de Collongue** **69134 Ecully cedex – France**
Name of product:	**H6771 megaroller 700FR all colors**
Classification report N° :	**N° 18-01982 L**
Issue number :	**1**
Date of issue :	**30 Août 2018**

This classification report consists of four pages and may only be used or reproduced in its entirety.

Ce rapport de classement atteste uniquement des caractéristiques de l'échantillon soumis aux essais et ne préjuge pas des caractéristiques de produits similaires. Il ne constitue donc pas une certification de produits au sens de l'article L.115-27 du code de la consommation et de la loi du 3 juin 1994.

3 Details of classified product:

3.1 General:

Product « **H6771 megaroller 700FR all colors** » (as described by the sponsor) is defined as a door material for hangars.

3.2 Description of the product:

Product « **H6771 megaroller 700FR all colors** » (as described by the sponsor), is described below or in the test report provided in support of classification listed in 3.1 :

Polyester fabric with inherent flame retardant PVC coating and acrylic lacquer on both sides.
Nominal surface weight: 700 g/m²
Nominal thickness: 570 µm
Colour : Grey – White – Blue

4 This reports and results in support of classification:

4.1 Reports :

Name of Laboratory	Name of Sponsor	Test report N°	Test method
IFTH Avenue Guy de Collongue 69134 ECULLY Cedex FRANCE	Heytex Bramsche GmbH Heywinkelstraβe D-49565 Bramsche GERMANY	N° 18-01982 E1 – V1 dated 30 Août 2018	NF EN ISO 11925-2:2013 NF EN 13823: 2013

4.2 Test results :

Test method	Parameter	Nb. of Tests	Results	
			Continuous parameter mean	Compliance parameter
EN ISO 11925-2 Applied on the face FRONT FACE Time exposure 30s Burning droplets or particles	Fs ≤ 150mm in 60s	6	/	IN ACCORDANCE
	Ignition of paper		/	NO
EN ISO 11925-2 Applied on the face BOTTOM FACE Time exposure 30s Burning droplets or particles	Fs ≤ 150mm in 60s	6	/	IN ACCORDANCE
	Ignition of paper		/	NO

Test method	Parameter	Nb. of Tests	Results	
			Continuous parameter mean	Compliance parameter
EN ISO 11925-2 Applied on the side Time exposure 30s Burning droplets or particles	Fs ≤ 150mm in 60s	6	/	IN ACCORDANCE
	Ignition of paper		/	NO
EN 13823*	$FIGRA_{0.2MJ}$ (w/s) $FIGRA_{0.4MJ}$ (w/s) $THR_{600\ (MJ)}$ LFS	3	1.3 1.3 0.7 /	/ / / NO REACH
	SMOGRA (m²/s²) TPS_{600s}(m²)		87.7 121.2	/ /
	$LDP_{f<10s}$ $LDP_{f>10s}$		/ /	NO NO
EN 13823*	$FIGRA_{0.2MJ}$ (w/s) $FIGRA_{0.4MJ}$ (w/s) $THR_{600\ (MJ)}$ LFS	3	9.3 0 0.8 /	/ / / NON ATTEINT
	SMOGRA (m²/s²) TPS_{600s}(m²)		84.2 132.6	/ /
	$LDP_{f<10s}$ $LDP_{f>10s}$		/ /	NON NON

*Specimen fixed on metallic frame with ventilated cavity 80 mm in width behind the sample according to the chapter 4.1.1.3-b of the standard EN 14716: 2004, sides the most remote from the angle and the spaces situated behind every wing being left opened.

5 Classification and field of application :

5.1 Reference of classification:

This classification has been carried out in accordance with EN 13501-1:2007 + A1:2009

5.2 Classification :

Product « **H6771 megaroller 700FR all colors** », in relation to fire behaviour is classified: **B**
The additional classification in relation to smoke product is: **s 2**
The additional classification in relation to flaming droplets / particles is: **d 0**
The format of the reaction to fire classification for construction products excluding flooring is:

Fire Behaviour		Smoke Production			Flaming Droplets	
B	-	s	2	-	d	0

REACTION TO FIRE CLASSIFICATION : B – s 2 – d 0

5-3 Field of application :


This classification is valid for the following product parameters :

Composition :	Polyester fabric with inherent flame retardant PVC coating and acrylic lacquer on both sides.
Nominal surface weight :	700 g/m²
Nominal thickness :	570 µm
Colors :	Various

This classification is valid for the following end used application: Door material for hangars

6 Limitation :

This classification document does not represent type approval or certification of the product.
The test laboratory has played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.

Report	Signatory	Signature*	Date
Edited by:	Sophie GUINAMAND Ingeneer Tests and Trials		30 Août 2018
Approved by:	Jean-Marc ORAISON In charge of Fire Regulation for Construction Products		30 Août 2018
* *For and in the name of **I.F.T.H.***			