NIHVA
NIHVA Technologies Pvt. Ltd.

PRE DISPATCH INSPECTION REPORT

Format no.: NIHVA- QA-F-07
Rev. no.: 00
Rev date:
Date of origin: 01.01.2017

Client Name- Tata Motors Limited | **Report No--**SO/23-24/0048(1)

Project Name- NTPL-210 | **Location-** NIHVA MANUFACTURING UNIT | **Date-02-02-2024**

Product Name- Motorized Single Skin Rolling Shutter (W4000xH2500mm) | **Qty-**01 NOS

Sr.No	Part Name	Drawing no.	Dimension In mm	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain Length	NIHVA/SO/23-24/058	4150 ± 5		4153	4152	4150	Steel Tape	OK
2	Curtain width	NIHVA/SO/23-24/058	75 ± 1.5		76.36	76.25	76.27	Digital Vernier caliper	OK
3	Curtain Thickness	NIHVA/SO/23-24/058	1.2 ± 0.2		1.21	1.21	1.2	Digital Micrometer	OK
4	Curtain Profile	NIHVA/SO/23-24/058	Curved		OK	OK	OK	Visual	OK
5	Hood cover (LxWxH)	NIHVA/SO/23-24/058	4700x360x350	1	4701x360x353	_	_	Steel Tape	OK
6	Hood cover thickness	NIHVA/SO/23-24/058	0.8 ± 0.1		0.760	_	_	Digital Micrometer	OK
7	Roller Length	NIHVA/SO/23-24/058	4200 ± 5	1	4205	_	_	Steel Tape	OK
8	Roller dia.	NIHVA/SO/23-24/058	140 ± 2		138.84			Digital Vernier caliper	OK
9	M.S. Bottom length	NIHVA/SO/23-24/058	4150 ± 5	1	4150	_	_	Steel Tape	OK
10	M.S. Bottom width	NIHVA/SO/23-24/058	125 ± 2		126.31	_	_	Digital Vernier caliper	OK
11	M.S. Bottom thickness	NIHVA/SO/23-24/058	2 ± 0.2		2.011	_	_	Digital Micrometer	OK
12	Guide length	NIHVA/SO/23-24/058	2650 ± 5	2	2650	_	_	Steel Tape	OK
13	M.S. Bracket (LxW)	NIHVA/SO/23-24/058	350x350	2	355x355	_	_	Steel Tape	OK
14	M.S. Bracket thickness	NIHVA/SO/23-24/058	5 ± 0.2		5.025	_	_	Digital Micrometer	OK
15	Motor -Jielong 1PH Indirect drive			1	OK	_	_	Visual	OK
16	Surface Finish	NIHVA/SO/23-24/058	RAL 9006	_	OK	OK	OK	Visual	OK
17	Coating thickness	NIHVA/SO/23-24/058	70-90 µ	_	89.1 µ	71.9 µ	82.3 µ	DFT Meter	OK
18	Product name plate	NIHVA/SO/23-24/058	Available		NMRS 1033			Visual	OK

Remark- All Material Are visually & dimensionally found ok

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Inspected By- Maruti Yamgar

Approved By- Amit Kurhade

NIHVA
NIHVA Technologies Pvt. Ltd.

PRE DISPATCH INSPECTION REPORT

Format no.: NIHVA- QA-F-07
Rev. no.: 00
Rev date:
Date of origin: 01.01.2017

Client Name- Tata Motors Limited | **Report No-**-SO/23-24/0048(2)

Project Name- NTPL-210 | **Location-** NIHVA MANUFACTURING UNIT | **Date-02-02-2024**

Product Name- Motorized Single Skin Rolling Shutter (W4000xH4000mm) | **Qty-**01 NOS

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain Length	NTPL-210	4150 ± 5		4153	4150	4152	Steel Tape	OK
2	Curtain width	NTPL-210	75 ± 1.5		76.35	76.27	76.28	Digital Vernier caliper	OK
3	Curtain Thickness	NTPL-210	1.2 ± 0.2		1.21	1.2	1.2	Digital Micrometer	OK
4	Curtain Profile	NTPL-210	Curved		OK	OK	OK	Visual	OK
5	Honey comb grill length	NTPL-210	4150	1	4150	_	_	Steel Tape	OK
6	Honey comb grill width	NTPL-210	600		600	_	_	Steel Tape	OK
7	Hood cover (LxWxH)	NTPL-210	4700x460x450	1	4700x 458x448	_	_	Steel Tape	OK
8	Hood cover thickness	NTPL-210	0.9 ± 0.2		0.796	_	_	Digital Micrometer	OK
9	Roller Length	NTPL-210	4200 ± 5	1	4204	_	_	Steel Tape	OK
10	Roller dia.	NTPL-210	140 ± 2		139.74			Digital Vernier caliper	OK
11	M.S. Bottom length	NTPL-210	4150 ± 5	1	4148	_	_	Steel Tape	OK
12	M.S. Bottom width	NTPL-210	125 ± 2		126.95	_	_	Digital Vernier caliper	OK
13	M.S. Bottom thickness	NTPL-210	2 ± 0.2		2.027	_	_	Digital Micrometer	OK
14	Guide length(T)	NTPL-210	4150 ± 5	2	4151	4152	_	Steel Tape	OK
15	M.S. Bracket (LxW)	NTPL-210	450x450	2	450x450	_	_	Steel Tape	OK
16	M.S. Bracket thickness	NTPL-210	5 ± 0.2		5.12	_	_	Digital Micrometer	OK
17	Motor -Jielong 1PH Indirect drive			1	OK	_	_	Visual	OK
18	Surface Finish	NTPL-210	RAL 9006	_	OK	OK	OK	Visual	OK
19	Coating thickness	NTPL-210	70-90 µ	_	89.1 µ	71.9 µ	82.3 µ	DFT Meter	OK
20	Product name plate	NTPL-210	Available		NMRS 1034			Visual	OK

Remark- All Material Are visually & dimensionally found ok

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Approved By- Amit Kurhade