ESPIC Commented
06/Nov/2014

NIHVA
NIHVA Technologies Pvt. Ltd.

6. TECHNICAL SPECIFICATION FOR MOTORIZED SLIDING GATE (SS)

Sr. No.	Particulars	Description
1.	Type	See through Stainless Steel Motorized Single Sliding Gate with push button
2.	Qty.	02 nos. sliding gate (01 no SG1 & 01 SG2) 02 nos. wicket gate (01 no. WC1 & 01 no. WC2) Fixed grill (FG) (length given in point 7 & 8)
3.	Material	Stainless Steel SS304 (complete Frame) , rest standard construction
4.	Sliding gate dimensions	Length SG1 - 10000 + 2000 mm (over lap), SG2 – 6000 + 1000 mm (over lap) Height - 1800 mm (refer attached photograph and dwg no 323-A-020)
5.	Wicket gate	Length WC1 - 1500 mmm WC2 - 1900 mm Height - 1800 mm (Design same as the sliding gate)
6.	Stainless steel fix grill (Design same as the sliding gate)	Length FG1 - 2300 mm Height - 1800 mm (Design same as the sliding gate)
7.	Fence above boundary wall	27150 x 1200 mm = 650 Kg. approx.
8.	Gate guide way	~~It will show in drawings~~
9.	Speed	6 sec per meter
10.	Motor	Italy make
11.	Power required	3 phase 415 V
12.	Gate Weight	SG1 + SG2 = 1250 Kg. approx. (SS) WC1 + WC2 + FG1 = 550 Kg. approx. (SS)
	Standard Accessories/ Features:	
1.	Electrical equipment suitable for 3 phase 415 ± 10 % V / single phase 230 V/50 Hz AC supply.	
2.	Robust fabricated structure. **OK**	
3.	Hard chrome plated wheel. **OK**	
4.	Galvanised adjustable upper guide brackets with guide posts duly painted with nylon rollers. **OK**	
5.	MS end of run limit stop and MS post with rubber safety strike rail**. OK**	
6.	Guide way rail along with its suitable clamping arrangement. **OK**	
7.	Manual operation in case of power failure. **OK**	
8.	Foundation bolts, guide ways, roller etc. to be provided by supplier **OK**	
9.	Highly compact dimensions & extremely silent operation. **OK**	
10.	Motor protected by internal thermal switch. **OK**	
11.	Advance electronic control unit permits/allows operation time adjustment, partial opening, automatic closing, step by step control, stop safety, reverse safety. **OK**	
12.	All equipment shall be dust and vermin proof and also capable to work in dusty environment. **OK**	
13.	Electromechanical actuator consisting of a suitable drive unit with suitable rack & electronic system for opening and closing of sliding gate using push button with mechanical over-ride facility. **OK**	
14.	Flashing light indicator shall be installed on posts. **OK**	
15.	Photocell shall be provided to stop the gate in case the traffic is not clear. **OK**	

Not clear. Plz provide layout plan view.

Maintenance free, life long lubricated.

NIHVA Technologies Pvt. Ltd.

16.	Necessary GA drawings to be provided. **OK**
17.	2 Sets of operational & maintenance manual. **OK** List to be provided.
18.	Set of spares for 2 years normal operation as per supplier`s recommendation. **OK**
19.	Supply, installation, erection and commissioning shall be in supplier's scope.**OK**
20.	Above dimensions may vary as per actual layout designing. **OK**
21.	All hinges with aldrop with key & lock facility and necessary fittings for the wicket gates to be provided. **OK**

Note :

For Sliding Gate below the bottum rail ISMC-150 (in client scope).

As per drawing No. 323-A-020, Rev. C Sheet 1 of 1 required : -
FG1 - 2300 MM (W) X 1800 MM (H) - Only SS 304
FG2 - 19650 MM (W) X 1000 MM (H), (Weight - ?) - MS & SS both quoted
FG3 - 19600 MM (W) X 1000 MM (H), (Weight - ?) - MS & SS both quoted
FG4 - 7500 MM (ARCH LENGTH) X 1000 MM (H), (Weight - ?) - MS & SS both quoted.

Optional accessories for sliding gate : -
1. Vertical soft EPDM rubber profile.
2. safety photocell
3. Extra push button.

1. Bidder has to confirm the acceptance of all tender TS 323-MD-023, rev.2 and dwg. No. 323-A-020, rev. C sheet 1/2 & rec. 0 sheet 2/2
2. Following spares also to be provided.
I) limit switch - 1 no.
3. Push button for both sliding gates shall be in security office approx. 25 meter from each side the motor.
4. Sliding movement should be maintenance free, lifelong lubricated.
5. Size may slightly change as per the fixing column sizes.
6. Interconnecting Cabling Shall Be in Supplier's Scope.