NIHVA NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	Format no.: NIHVA- QA-F-07 Rev. no.: 00 Rev date: Date of origin: 01.01.2017

Client Name- Rinac India Pvt. Ltd. | **Report No--**SO/23-24/073

Project Name- Rinac India Pvt. Ltd. | **Location-** NIHVA MANUFACTURING UNIT | **Date-24-04-2024**

Product Name- HMPS DOOR (W3000xH3000mm) | **Qty-**1 NOS

Sr.No	Part Name		Dimension In mm	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Frame height		2390 ± 8	1	2390	_	_	Steel Tape	OK
2	Frame width		2990 ± 8	1	2990	_	_	Steel Tape	OK
3	Leaf length		2345 ± 8	2	2345	2345	_	Steel Tape	OK
4	Leaf width		1445 ± 6		1447	1447	_	Steel Tape	OK
5	Leaf Thickness		46 ± 1.5	1	46	46	_	Steel Tape	OK
6	Window height		450 ± 4	1	450	450	_	Steel Tape	OK
7	window width		300 ± 2.5	1	300	300	_	Steel Tape	OK
8	Infilled material		Resin Bonded Honeycomb Core						OK
9	Sheet Thickness		0.8 ± 0.2	_	0.8	_	_	vernier caliper	OK
10	Surface Finish	RAL CODE	RAL-7035	_	OK	_	_	Visual	OK
		Coating Thickness	60-70 µ	_	68 µ	69 µ	68 µ	DFT meter	OK
11	Product name plate			NOT AVAILABLE					_

Remark- All Material Are visually & dimensionally found ok

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE