GI 1.2mm slot

JSW Steel Coated Products Limited
A-100, MIDC AREA, KALMESHWAR - 441 501, DIST. NAGPUR (M.S.) INDIA
PHONE : (07118) 271401 - 406, 271477 - 478, FAX : (07118) 271405/56/79

ISO 9001 : 2015
ISO 14001 : 2015
ISO 50001 : 2018
ISO 45001 : 2018

IS : 277

CM/L No.1800239

TEST CERTIFICATE FOR GALVANIZED STEEL COILS

Product Description : GI Coils
Mill Certificate No : 7105771935

Invoice No. : 7105771935
Invoice Date : 05.07.2023
Ref. Doc. NO. : 713857611
Ref. Doc. DATE : 08.07.2023
Truck No. : MH12NX1573

It is certified that the material described below fully conforms to IS 277 2018. Chemical composition and Mechanical properties of the product,as tested in accordance with the Scheme of Testing and Inspection contained in the BIS Certification Marks Licence No.CM/L No. 1800239 are as indicated below against each order no.

(PLEASE REFER TO IS 277:2018 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

TEST RESULTS

S. No	Specification Grade	Coating (gsm)	Batch No	Thk (mm)	Width (mm)	Length (mm)	Net Wt (MT)	Chemical Composition C / S	Mn / P	Si / Al	Mechanical Properties YS	UTS	El 50GL	El 80GL	Hardness HRB	No Of Pcs	Passivation	Coil Treat	Zinc Coating (gsm)	Heat No
											(Mpa)									
001	BIS 277_2018 GP	275 000	KGZAOF1781	1.000	1250	650	6.190	0.045 / 0.004	0.215 / 0.007	0.015 / 0.055	NA	NA	NA	NA	61		CR3	STL	277 000	A016277
002	BIS 277_2018 GP	275 000	KGZAOF1778	1.000	1250	640	6.130	0.045 / 0.004	0.215 / 0.007	0.015 / 0.055	NA	NA	NA	NA	61		CR3	STL	277 000	A016277
003	BIS 277_2018 GP	275 000	KGZAOF1965	1.200	1250	525	6.040	0.027 / 0.004	0.227 / 0.015	0.009 / 0.045	NA	NA	NA	NA	57		CR3	STL	280 000	A016279
004	BIS 277_2018 GP	275 000	KGZAOF1962	1.200	1250	530	6.130	0.027 / 0.004	0.227 / 0.015	0.009 / 0.045	NA	NA	NA	NA	57		CR3	STL	280 000	A016279
005	BIS 277_2018 GP	275 000	KGZAOF1964	1.200	1250	520	5.965	0.027 / 0.004	0.227 / 0.015	0.009 / 0.045	NA	NA	NA	NA	57		CR3	STL	280 000	A016279

Name: Nihva Technologies Pvt Ltd.
Bill No. AIPL/0520/23-24
Weight. 6170 kg
Date : 11th sept, 2023

TOTAL .

We hereby certify that the materials described herein has beeninspected in accordance with above specification.
Please store material under the shed.
JSW Steel Coated Products Limited, Kalmeshwar is totally committedto RoHS Compliance and our products contain less hazardous substances than the permissible European Limits.

Head (Quality Assurance)

Vijay V Salpute QUEST 3646 Pune

NIHVA TECHNOLOGIES PVT. LTD. PUNE

22/3/24

AM/NS INDIA

ArcelorMittal Nippon Steel India Limited PRECOATED FACILITY

Works Gat No-740, Sinhanwal, Taluk-Talegaon, Dist-Pune 412208
CIN-U27100PC1978PLC012763

MILL TEST CERTIFICATE

FOR GALVANIZED STEEL STRIPS AND SHEETS(PLAIN & CORRUGATED)

Test Certificate No.	AMNSPCC/2024/07/04/24/6/5050
Sale Order No/Item No	2120487/96140
Equivalent Specification	IS_277_GP250
Test Certificate Date	07.03.2024
Sales Order Date	05.03.2024
Material Description	GALVANIZED STEEL STRIP
Invoice No.	MH2023100025768
Vehicle No.	MH46BF6183

To K. KRISHNA STEEL INDUSTRIES
A-103, 1st FLOOR, RATNA RAJUL CHS L
400067
MUMBAI 13
India

WE CERTIFY THAT THE MATERIAL DESCRIBED BELOW FULLY CONFORMS TO ABOVE SPECIFICATION CHEMICAL COMPOSITION AND MECHANICAL PROPERTIES OF THE PRODUCT, AS TESTED IN ACCORDANCE WITH THE SCHEME OF TESTING AND INSPECTION CONTAINED IN THE BIS CERTIFICATION MARKS LICENCE NO CM/L-3784580 ARE AS INDICATED BELOW AGAINST EACH ORDER NO. ETC

Heat Analysis (%) of AN24100645

Heat No	C	Mn	S	P	Si	Al
Min-->	N.S	N.S	N.S	N.S	N.S	0.020
Max-->	0.080	0.500	0.0250	0.025	0.040	0.080
AN24100645	0.057	0.215	0.0047	0.013	0.005	0.045

Mechanical/Physical Properties

Item No	Batch ID	Thk	Wid	Len	Qty Net	HARD	IMPT	BEND	ST	CFT	ZCOAT
Min-->						N.S	N.S	N.S	N.S	N.S	N.S
Max-->						N.S	N.S	N.S	N.S	N.S	N.S
40	2501SB003P	0.900	1250	652	5.560	58	OK	OK	C	N	60
Total					5.560						

Note:
Due to ageing: The coating surface can vary & change to a dark appearance by oxidation, reduction in formability, cracking of the surface, fluting can occur during processing. Therefore the user should process the material as soon as possible

Legends: Bend: Bend Test Table no 5 (Clause no 8.3), CFT: Coating Finish Type, IMPT: Impact Test (100 Kg-Cm), ST: Surface Treatment, ZCOAT: Zinc Coating in GSM, N.S: Not Specified.

Units of measurement: Thk/Wid(MM), Len(MTR), Qty Net(Quantity Net)(MT), HARD(HRB), ZCOAT(GSM)

MANAGER (QUALITY ASSURANCE)
FOR ArcelorMittal Nippon Steel India Limited PRECOATED FACILITY

QC Verified

22/3/24

Scanned with ACE Scanner

	TEST CERTIFICATE FOR STEEL TUBES	Format No.: QA-F-18 Rev.no. :00 Date :15.12.2023

APL APOLLO TUBES LTD. UNIT-III

Works-Vill-Kudavali Plot No-M-1, Murbad, 421401, Thane (MS)

TEST CERTIFICATE FOR STEEL TUBES

IS: 1161

CM/L-2808361

TEST CERTIFICATE NO. : IS 1161
DATE : 15-01-23
INVOICE NO. : 220423480
VEHICLE NO. : MH12HJ4850
INVOICE DATE : 10-04-23

M/s H VIKAS PIPE & STEEL LLP Pune

We certify that the material described below fully conforms to IS 1161. Chemical composition and mechanical properties of the product, as tested in accordance with the Scheme of Testing and Inspection contained in the BIS Certification Marks License No. CM/L-2808361 are as indicated below against each order no. etc.

(PLEASE REFER TO IS 1161 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

TEST RESULT

Size	Grade/ Type	Cast no./ Lot No	Total Pcs	Actual Wt (MT)	CHEMICAL ANALYSIS (% Max)				MECHANICAL PROPERTIES (Min)					GALVANIZING (Min)	
					C	Mn	P	S	Tensile Strength (Mpa)	Yeild Strength	%El	Drift Expansion	Bend test/ Flattening Test	Weight (g/m2)	Uniformity
Requirements					N/A	N/A	0.04	0.04	360	210	20	12.5 % at 45°	-	400	5 Dip (1Dip/ Minute)
OD 114X3.00 MM	WT 160 / BLK	222101154 / 4222414A	455	7.6	0.037	0.22	0.013	0.013	374	330	34	OK	OK	-	-

It is certify that each steel tube is supplied conforms to standard dimensions and mass tolerances.

% El : Elongation percentage

QC Verified

NIHVA TECHNOLOGIES PVT. LTD. PUNE

22/3/24

Vijay V Satpute QUEST 3046 Pune

AUTHORISED SIGNATORY

APL APOLLO TUBES LTD. MURBAD

PREPARED BY

FOR APL APOLLO TUBES LTD.

	TEST CERTIFICATE FOR STEEL TUBES	Format No.: QA-F-18 Rev.no. :00 Date :10.12.2023

APL APOLLO TUBES LTD. UNIT-III

Works-Vill-Kudavali Plot No-M-1. Murbad. 421401. Thane (MS)

TEST CERTIFICATE FOR STEEL TUBES

IS: 1161

CM/L-2808361

TEST CERTIFICATE NO. : IS 1161
DATE : 05-01-23
INVOICE NO. : 2204234569
VEHICLE NO. : MH12KQ2728
INVOICE DATE : 25-03-23

M/s H VIKAS PIPE & STEEL LLP Pune

We certify that the material described below fully conforms to IS 1161. Chemical composition and mechanical properties of the product, as tested in accordance with the Scheme of Testing and Inspection contained in the BIS Certification Marks License No. CM/L-2808361 are as indicated below against each order no. etc.

(PLEASE REFER TO IS 1161 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

TEST RESULT

Size	Grade/ Type	Cast no./ Lot No	Total Pcs	Actual Wt (MT)	CHEMICAL ANALYSIS (% Max)				MECHANICAL PROPERTIES (Min)					GALVANIZING (Min)	
					C	Mn	P	S	Tensile Strength (Mpa)	Yeild Strength	%El	Drift Expansion	Bend test/ Flattening Test	Weight (g/m2)	Uniformity
Requirements					N/A	N/A	0.04	0.04	360	210	20	12.5 % at 45°	-	400	5 Dip (1Dip/ Minute)
OD 165X5.00 MM	WT 160 / BLK	222101154 / 4222414A	455	9.6	0.037	0.22	0.013	0.013	376	330	34	OK	OK	-	-
OD 140X3.50 MM	WT 160 / BLK	222101154 / 4222414A	455	8.5	0.037	0.22	0.013	0.013	374	330	34	OK	OK	-	-

It is certify that each steel tube is supplied conforms to standard dimensions and mass tolerances.

% El : Elongation percentage

NIHVA TECHNOLOGIES PVT. LTD. PUNE

QC Verified

Vijay V Satpute QUEST 3046 Pune

AUTHORISED SIGNATORY

APL APOLLO TUBES LTD. MURBAD

PREPARED BY

FOR APL APOLLO TUBES LTD.

MS 2mm (Bottom)

TATA STEEL

Tata Steel Limited
Jamshedpur, Jharkhand 831001
Corporate Identity Number: L27100MH1907PLC000260.Website www.tatasteel.com

286

IS 10748
CM/L-1488061

TEST CERTIFICATE

TEST CERTIFICATE NO. : 903007979	**DESPATCH DATE:** 18.01.2024	**SHIP-TO PARTY:** 117509	**SOLD-TO PARTY:** 115806
DO NO. : 9516647426	**CUSTOMER CODE:** 117509	NARESH STEEL INDUSTRIES PVT LTD C/O POONYA STEEL	NARESH STEEL INDUSTRIES PVT LTD C-501, NEELKANTH
INVOICE NO. : 2483438104	**VEHICLE NO.:** MH48AG9078(R)	A-7/2,MIDC,OPP TRANSPOWER,TALOJA	OPP.VIDYA VIHAR RAILWAY STN,
MATERIAL No. : 1108668	**PRODUCT:** HOT_ROLLED_COILS	TALOJA 410208	MUMBAI 400086

We hereby certify that the above mentioned material is tested in accordance with scheme of testing and inspection contained in BIS certification marks License no CM/L-1488061 are as indicated against each section (Please refer to IS 10748 GRADE 1(HOT-ROLLED STEEL STRIP FOR WELDED TUBES AND PIPES:2004)* for details of specification requirements). Legal sanction can be imposed on forging. Improper use of product can cause safety issues To validate test certificate, Scan QR Code.

TDC No: HG01 Q Code:I09497

Chemical Analysis, Specifications and Other Information

Grade: IS 10748 Gr 1		C	Mn	N	P	S	Si	Al	Cu	Cr	Ni	Mo
Section(TxWxL): 2.000x1250.000x0mm		%	%	PPM	%	%	%	%	%	%	%	%
Specification Requirements as per TDC No HG01	Min							0.0200				
	Max	0.1000	0.5000	120	0.0400	0.0400						

Itm	Batch No.	Mother Coil	Cast No.	Tonnage	Pcs.	Test Results										
01	35391171	35391171	V94364	22.550	1	0.0350	0.1660	30	0.0180	0.0080	0.0050	0.0690	0.0070	0.0210	0.0190	0.0001

TDC No: HG01

Mechanical Analysis, Specifications and Other Information

Section (TxWxL): 2.000x1250.000x0mm		BEND	EL %	YS MPa	UTS MPa
Speciifcation Requirements as per TDC No. HG01	Min		30	170	290
	Max				

Itm	Batch No.	Mother Coil	Cast No.	Tonnage		Test Results			
01	35391171	35391171	V94364	22.550	1	OK	38	275	349

1YHBK 220

Route-BOF>LF>CC>HSM
Test Certificate as per EN10204 TYPE 3.1

1 MPa = 1 N/mm2
YS = Yield Strength
UTS = Ultimate Tensile Strength
El= % elongation on standard gauge length
TxWxL = Thickness x Width X Length
CE (Carbon Equivalent) = (C+Mn/6+(Cr+Mo+V)/5+(Ni+Cu)/15)

*For further details please visit www.bis.gov.in

Killing type:Steel is fully Aluminium killed
Material is ROHS Compliant
Tensile Sample testing transverse to rolling direction

Material clearance date

04.01.2024
This TC is electronically generated

Vijay V Satpute QUEST 3046 Pune

22/3/24

Date:2023.01.1815:53:27IST

NIHAR TECHNOLOGIES PVT. LTD. PUNE

STEEL AUTHORITY OF INDIA LIMITED
ROURKELA STEEL PLANT
ROURKELA - 769011 (ODISHA)
RESEARCH AND CONTROL LABORATORY

IS 2062 Page 1 of 1

Test Certificate For: HOT ROLLED MEDIUM AND HIGH TENSILE STRUCTURAL STEEL

Test Certificate No.: 436945 | Dated: 26.06.2022 | Product: HR Plate

To : LITTLESTAR PROJECTS PVT LTD C-12, SETH DEOKARAN DASS ROURKELA 769012

It is cerified that the materials described below fullyconforms to IS 2062 - 2011. The chemical composition and Mechanical properties of the product as tested in accordance with the scheme of Testing and Inspection contained in BIS Certification marks License No. CM / L 0000053223 are as indicated against each order. Thematerial supplied conforms to standard Rolling and weight tolerances. (PLEASE REFER TO IS 2062 - 2011 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

Ladle Analysis

Cast No	C%	Mn%	P%	S%	Si%	Al%	CE
2009864	0.1400	0.7900	0.0290	0.0190	0.1080	0.0290	0.2680
2009889	0.1400	0.8700	0.0275	0.0150	0.1570	0.0170	0.2780

Sl. No.	MP / SC No.	Cast / Batch No.	Size(mm) (TxWxL)	Weight(T)	Grade / Mode Of Killing	YS (MPa)	UTS (MPa)	El (%)	Bend Test
1	1400462204	2009884 / N9761801	1250X2500X5 MM	26.45	IS 2062 E250BR / ALSIK	294	449	34	OK
2	1400462204	2009884 / N9761801	1250X2500X3 MM	30.20	IS 2062 E250BR / ALSIK	291	444	32	OK

Total Pieces : 20 Total Weight(Tons) : 56.65

Remarks : PROCESS ROUTE: BOF-LHF-CC-HSM

QC Verified

NIHA TECHNOLOGIES PVT. LTD. PUNE

22/3/22

Vijay V Satpute QUEST 3046 Pune

K PATWARI
DGM , R&C Lab
Rourkela Steel Plant

Dispatch Advice No.: 811307979 Dated: 26.06.2022 Truck No: OD14P1023