Fraunhofer

TESTED® DEVICE

Albany Door Systems
RapidRoll Clean
Report No. AL 1003-514

Qualification Certificate

This is to certify that the products mentioned below provided by the company

Albany Door Systems GmbH

Am Mondschein 25
59557 Lippstadt
Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number AL 1003-514.

The High Performance Door RapidRoll Clean with control system MCC with cover as well as with control system ACS50 with cover is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 5 according to ISO 14644-1.

The operating utility is herewith recommended for use in hygienic areas possessing a maximum cleanliness level of GMP Cleanliness Class C. However, this only applies to the operating utility when in a resting state; an overall assessment of the production environment is required after installation of the utility. Additionally pressure tightness tests at the test bench of the company were performed.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.
The validity of this certificate applies only to the above mentioned product in this particular condition. For further information visit our website at www.ipa-qualification.com.

Stuttgart, June 23, 2010

i. A.
Project manager

Fraunhofer
IPA