NIHVA
NIHVA Technologies Pvt. Ltd.

PRE DISPATCH INSPECTION REPORT

Format no.: NIHVA- QA-F-07
Rev. no.: 00
Rev date:
Date of origin: 01.01.2017

Client Name-Power Erectors Pvt Ltd | **Report No--**SO/23-24/070(1)

Project Name- | **Location-** NIHVA MANUFACTURING UNIT | **Date-09-03-2024**

Product Name- Motorized Single Skin Rolling Shutter (W4000xH4500mm) | **Qty-**01 NOS

Sr.No	Part Name		Dimension In mm	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain Length		4150 ± 5		4090	4092	4090	Steel Tape	NOT OK
2	Curtain width				82.44	82.4	82.39	Digital Vernier caliper	OK
3	Curtain Thickness		1.0 ± 0.2		1.21	1.21	1.2	Digital Micrometer	Conditionaly accepted
4	Curtain Profile		Curved		Flat	Flat	Flat	Visual	NOT OK
5	Hood cover length		4600 ± 8		4700	_	_	Steel Tape	Conditionaly accepted
6	Hood cover width		400 ± 2.5		400	_		Steel Tape	OK
7	Hood cover height		400 ± 2.5	1	400	_	_	Steel Tape	OK
8	Hood cover thickness		0.9 ± 0.2		0.760	_	_	Digital Micrometer	OK
9	Roller Length		4200 ± 8	1	4210	_	_	Steel Tape	Conditionaly accepted
10	Roller dia.		114 ± 2		114.61	_	_	Digital Vernier caliper	OK
11	Aluminium bottom Length		4150 ± 5		4100	_	_	Steel Tape	NOT OK
12	Aluminium bottom width		125 ± 2.5		127.37	_	_	Digital Vernier caliper	OK
13	Guide length		4650 ± 8	2	4650	4652	_	Steel Tape	OK
14	Guide width		75 ± 1.5	2	108	111	_	Steel Tape	NOT OK
15	Guide thickness		2 ± 0.2	2	2.535	2.558	_	Digital Micrometer	Conditionaly accepted
16	M.S. Bracket (LxW)		400x400	2	OK	OK	_	Steel Tape	OK
17	M.S. Bracket thickness		5 ± 0.2		4.971	5.013	_	Digital Micrometer	OK
18	Motor -Jielong 1PH, 600kg Indirect drive			1	OK	_	_	Visual	OK
19	Surface Finish		Duco paint RAL 5015		OK	OK	OK	Visual	OK
20	Coating thickness		70-90 µ	_	85.3 µ	81.3 µ	87.5 µ	DFT Meter	OK
21	Product name plate		Available		NMRS1075-01			Visual	OK

Remark- All Material Are visually & dimensionally found ok

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk





Inspected By- Maruti Yamgar

Approved By- Amit Kurhade