	Top Cover: Top cover/hood made out of 1.25 mm thick GI sheet. **Painting**: Two coats of synthetic enamel paint of approved color over and including two coats of zinc chromate primer. The cost to include providing and fixing any additional supports required to erect the shutter in the structural opening, making chases in wall/floor and grouting the guides and brackets in M25 concrete or welding to insert plates provided in the structural opening complete with all by-works as per specification, drawings, good engineering practice and directed by EIC. Partial grills and special stiffening members shall be provided wherever necessary. Area of clear structural opening shall be measured and paid for. The guide/hood/ hood cover area will not be measured separately for payment.				
CJ1RS1.1	Size 3000 mm (W) x 4000 mm (H)	Nos	1.00		
CJ1RS1.2	Size: 3000 mm (W) x 4000mm (H), partly grilled for 600 mm at a height of 900 mm from finished floor level. M.S. links 150 x 75 mm in the rolling grill portion with link opening of 115 x 45 mm.	Nos	3.00		
CJ1RS1.3	Size 3000 mm (W) x 3000 mm (H)	Nos	1.00		
CJ1RS1.4	Size 2500 mm (W) x 3000 mm (H)	Nos	1.00		
CJ2RS1	**GI Rolling Shutters, Gear Type, Hand Operated, Painted:** Providing, assembling, erecting in position rolling shutters of approved make as per the following specification **Shutter:** Shutter shall be made of G.I laths, 18 G thick, 80 mm wide, interlocked and held together throughout their length using 10mm dia. hard drawn seamless tubes and the end sealed with GI clips, 10G reinforced lock plate riveted to 40 x 40 x 6mm angle with 40 x 40 x 6mm stiffener welded on rear side, necessary locking arrangements from inside and outside,. The assembly shall be mounted on specially designed pipe shaft with superior flat springs, bearing arrangement and with all other necessary fixtures for the shutter. **Shutter Guides:** The side guide and bracket arrangements shall be made out of GI channel 75 x 25 x 3.15 mm thick. **Operating Mechanism:** Gearbox with rotating handle arrangement for manual winding/unwinding operation from inside and outside, extended shaft with ball bearing and necessary counter gear arrangement on the pipe shaft of the shutter. **Top Cover:** Top cover/hood made out of 1.25 mm thick GI sheet. **Painting**: Two coats of synthetic enamel paint of approved color over and including two coats of zinc chromate primer. The cost to include providing and fixing any additional supports required to erect the shutter in the structural opening, making chases in wall/floor and grouting the guides, gearbox and brackets in M25 concrete or weld to insert plates provided in the				