FORM 13
REPORT OF EXAMINATION OF PRESSURE PLANT/VESSEL/GAS HOLDER
(See Rules 65 and 73-A)

1	Name and address of the Factory	:	NIHVA TECHNOLOGIES PVT LTD 187, G-BLOCK, MIDC, THERMAX CHOWK, MIDC, ABOVE RENAULT SHOWROOM, PIMPRI- CHINCHWAD 0, PUNE, 411019
2	Name, Description and distinctive number of Pressure Plant / Vessel / Gas Holder	:	Receiver 1. Air Compressor Tank, Cap. 500 Ltrs., Sr./Id No. 072, AR-01, Loca. Work Shop
3	Name and address of maker	:	KND
4	Nature of process in which it is used	:	For Storing and supply of comp. air
5	Particulars of Plant/Vessel-	:	
5 (a)	Date of Construction	:	12-12-2019
5 (b)	Thickness of Walls	:	Shell -5.0 mm, Head -4.9 mm
5 (c)	Date on which it was first taken into use	:	12-12-2019
5 (d)	Safe working pressure recommended by maker	:	07 Kg/cm2
5A	Particulars of Plant/ Vessel/ Gas Holder		
a	Parts of the gas holders examined by electronics or other accurate devices or by cutting sample discs and results thereof	:	Not applicable.
b	Particulars as to the condition of:-		
	i) Crown	:	Not applicable.
	ii) Side sheeting including grips and cups	:	Not applicable.
	iii) Guiding mechanism (roller carriages, roller, pins, guide, ropes etc.	:	Not applicable.
	iv) Tank	:	Not applicable.
	v) Other structure, if any, columns (Framing and bracking)	:	Not applicable.
C	Particulars as to the position of the lift at the time of examination	:	Not applicable.
d	Particulars as to whether the tank and lifts were found sufficiently level for safe working	:	Not applicable.
6	Date of -		
i)	Last External Examination	:	Record not available.
ii)	Last Internal Examination	:	Inaccessible.
iii)	Last Hydraulic Examination	:	Record not available.
iv)	Last Ultrasonic Test	:	Record not available.
6A	By Whom it is carried out?	:	RECORD NOT AVAILABLE.

FORM 13
REPORT OF EXAMINATION OF PRESSURE PLANT/VESSEL/GAS HOLDER
(See Rules 65 and 73-A)

7	Whether lagging was removed for purpose of examination	:	No Lagging.
8	Description of examinations carried out and findings...	-	
I	External Examination (Give reasons if it is not carried out six monthly)	:	Good.
Ii	Internal Examination (Give reasons if it is not carried out six monthly)	:	Inaccessible.
Iii	Hydraulic Test (Give reasons if this is not carried out at interval of 2 years or 4 years.)	:	Not done.
iv	Ultrasonic Test (Please quote number and date of the certificate issued by Chief Inspector, permitting ultrasonic test in lieu of internal examination and hydraulic test)	:	Head- 5.0, 5.0 mm, Shell- 4.9, 5.0 mm
9	Safe Working Pressure calculated as per methods given in sub rule 5 (c) (ii) for sizing cylinders-	:	Not applicable.
10	Condition of Pressure Plant	-	
a	Vessel	:	Good.
b	Piping	:	Okay.
11	Conditions of fittings and appliances	:	
i)	Pressure Gauges	:	Okay.
ii)	Safety Valves	:	Okay.
iii)	Stop Valve	:	Nil.
iv)	Reducing Valves (give reasons if not necessary)	:	Nil.
v)	Additional safety valve (required in case reducing valve is necessary)	:	Nil.
vi)	Other devices (please specify particularly in case of jacketed vessel)	:	Nil.
vii)	Are all fittings and appliances properly maintained and in good condition, repairs if any required and period within which they should be executed.	:	Yes, maintained in good condition.

FORM 13
REPORT OF EXAMINATION OF PRESSURE PLANT/VESSEL/GAS HOLDER
(See Rules 65 and 73-A)

12	Safe working pressure recommended after examination (specify the allowances made for condition of working such as heat, corrosion etc.)	:	07 Kg/cm2
13	Specify repairs if any and period within which they should be executed	:	No repairs.
14	Specify reduced working pressure pending repairs	:	Nil.
15	Other observation /conditions subject to which the plant is to be operated	:	At the time of examination/test was found okay and satisfactory. Shall be properly maintained in safe working condition.

I certify that on **24-11-2023** the pressure plant / vessel described above was thoroughly cleaned and (so far as its construction permits) made accessible for thorough examination and for such tests as were necessary for thorough examination and that on the said date. I thoroughly examined this pressure vessel/Plant including its fittings and that the above is true report of my examination.

Signature of Competent Person :

Preetam Dattatray Deshpande
Digitally signed by Preetam Dattatray Deshpande

Name of Competent Person		PREETAM DESHPANDE, CPC NO.MS/DISH/CPC/D-065
Qualification		D.M.E., ADIS, B.E. (MECH.)
Address		Neel-Padma, Build.No.5, Flat No.9, Savarkarnagar, Manikbag, Sinhgad Road,
Date		24-11-2023

FORM 13
REPORT OF EXAMINATION OF PRESSURE PLANT/VESSEL/GAS HOLDER
(See Rules 65 and 73-A)

1	Name and address of the Factory	:	NIHVA TECHNOLOGIES PVT LTD 187, G-BLOCK, MIDC, THERMAX CHOWK, MIDC, ABOVE RENAULT SHOWROOM, PIMPRI- CHINCHWAD 0, PUNE, 411019
2	Name, Description and distinctive number of Pressure Plant / Vessel / Gas Holder	:	Receiver 2. Air Compressor Tank, Cap. 500 Ltrs., Sr./Id No. AR-02, Loca. Work Shop
3	Name and address of maker	:	Aeris Vibrant Air Solution
4	Nature of process in which it is used	:	For Storing and supply of comp. air
5	Particulars of Plant/Vessel-	:	
5 (a)	Date of Construction	:	12-12-2019
5 (b)	Thickness of Walls	:	Shell -5.0 mm, Head -4.9 mm
5 (c)	Date on which it was first taken into use	:	12-12-2019
5 (d)	Safe working pressure recommended by maker	:	07 Kg/cm2
5A	Particulars of Plant/ Vessel/ Gas Holder		
a	Parts of the gas holders examined by electronics or other accurate devices or by cutting sample discs and results thereof	:	Not applicable.
b	Particulars as to the condition of:-		
	i) Crown	:	Not applicable.
	ii) Side sheeting including grips and cups	:	Not applicable.
	iii) Guiding mechanism (roller carriages, roller, pins, guide, ropes etc.	:	Not applicable.
	iv) Tank	:	Not applicable.
	v) Other structure, if any, columns (Framing and bracking)	:	Not applicable.
C	Particulars as to the position of the lift at the time of examination	:	Not applicable.
d	Particulars as to whether the tank and lifts were found sufficiently level for safe working	:	Not applicable.
6	Date of -		
i)	Last External Examination	:	Record not available.
ii)	Last Internal Examination	:	Inaccessible.
iii)	Last Hydraulic Examination	:	Record not available.
iv)	Last Ultrasonic Test	:	Record not available.
6A	By Whom it is carried out?	:	RECORD NOT AVAILABLE.

FORM 13
REPORT OF EXAMINATION OF PRESSURE PLANT/VESSEL/GAS HOLDER
(See Rules 65 and 73-A)

7	Whether lagging was removed for purpose of examination	:	No Lagging.
8	Description of examinations carried out and findings...	-	
I	External Examination (Give reasons if it is not carried out six monthly)	:	Good.
Ii	Internal Examination (Give reasons if it is not carried out six monthly)	:	Inaccessible.
Iii	Hydraulic Test (Give reasons if this is not carried out at interval of 2 years or 4 years.)	:	Not done.
iv	Ultrasonic Test (Please quote number and date of the certificate issued by Chief Inspector, permitting ultrasonic test in lieu of internal examination and hydraulic test)	:	Head- 4.9, 5.0 mm, Shell- 5.0, 5.0 mm
9	Safe Working Pressure calculated as per methods given in sub rule 5 (c) (ii) for sizing cylinders-	:	Not applicable.
10	Condition of Pressure Plant	-	
a	Vessel	:	Good.
b	Piping	:	Okay.
11	Conditions of fittings and appliances	:	
i)	Pressure Gauges	:	Okay.
ii)	Safety Valves	:	Okay.
iii)	Stop Valve	:	Nil.
iv)	Reducing Valves (give reasons if not necessary)	:	Nil.
v)	Additional safety valve (required in case reducing valve is necessary)	:	Nil.
vi)	Other devices (please specify particularly in case of jacketed vessel)	:	Nil.
vii)	Are all fittings and appliances properly maintained and in good condition, repairs if any required and period within which they should be executed.	:	Yes, maintained in good condition.

FORM 13
REPORT OF EXAMINATION OF PRESSURE PLANT/VESSEL/GAS HOLDER
(See Rules 65 and 73-A)

12	Safe working pressure recommended after examination (specify the allowances made for condition of working such as heat, corrosion etc.)	:	07 Kg/cm2
13	Specify repairs if any and period within which they should be executed	:	No repairs.
14	Specify reduced working pressure pending repairs	:	Nil.
15	Other observation /conditions subject to which the plant is to be operated	:	At the time of examination/test was found okay and satisfactory. Shall be properly maintained in safe working condition.

I certify that on **24-11-2023** the pressure plant / vessel described above was thoroughly cleaned and (so far as its construction permits) made accessible for thorough examination and for such tests as were necessary for thorough examination and that on the said date. I thoroughly examined this pressure vessel/Plant including its fittings and that the above is true report of my examination.

Signature of Competent Person :

Preetam Dattatray Deshpande
Digitally signed by Preetam Dattatray Deshpande

Name of Competent Person		PREETAM DESHPANDE, CPC NO.MS/DISH/CPC/D-065
Qualification		D.M.E., ADIS, B.E. (MECH.)
Address		Neel-Padma, Build.No.5, Flat No.9, Savarkarnagar, Manikbag, Sinhgad Road,
Date		24-11-2023