NIHVA NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	Format no.: NIHVA- QA-F-07 Rev. no.: 00 Rev date: Date of origin: 01.01.2017

Client Name- Rinac India Limited | **Report No--**

Project Name- NTPL- | **Location-** NIHVA MANUFACTURING UNIT | **Date-17-03-2024**

Product Name- Motorised rolling shutter (W4500 mm X H 4200 mm) | **Qty-**01 NOS

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain	Curtain Length	4660	65	4660	4660	4660	Steel tape	OK
		Curtain width	75		75	75	75	DVC	OK
		Curtain Thickness	1.2		1.2	1.2	1.2	DMM	OK
		Curtain Profile	Curved		OK	OK	OK	Visual	OK
2	Roller shaft	Roller Length	4720	1	4720	_	_	Steel tape	OK
		Roller dia.	140		140	_	_	DVC	OK
3	Hood cover	Hood cover Length	4970	1	4970	_	_	Steel tape	OK
		Hood cover width	380		380	_	_	Steel tape	OK
		Hood cover thickness	0.9		0.8	_	_	DMM	OK
4	Guide	Guide length	4200	2	4200	4200	_	Steel tape	OK
		Guide width	100		100	100	_	Steel tape	OK
		Guide thickness	2		2	2	_	DMM	OK
5	Motor			JIELONG make				Visual	OK
6	Surface finish	Matched with RAL PAD						Visual	OK
		Coating Thickness	70-80µ		76µ	79µ	78µ	DFT meter	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

Vijay V Satpute QUEST 3046 Pune

22/3/24

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

NIHVA NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	Format no.: NIHVA- QA-F-07 Rev. no.: 00 Rev date: Date of origin: 01.01.2017

Client Name- Rinac India Limited | **Report No--**

Project Name- NTPL- | **Location-** NIHVA MANUFACTURING UNIT | **Date-17-03-2024**

Product Name- Motorised rolling shutter (W6000 mm X H 8000 mm) | **Qty-**01 NOS

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain	Curtain Length	6160	65	6160	6160	6160	Steel tape	OK
		Curtain width	75		75	75	75	DVC	OK
		Curtain Thickness	1.2		1.2	1.2	1.2	DMM	OK
		Curtain Profile	Curved		OK	OK	OK	Visual	OK
2	Roller shaft	Roller Length	6260	1	6260	_	_	Steel tape	OK
		Roller dia.	165		165	_	_	DVC	OK
3	Hood cover	Hood cover Length	6570	1	6570	_	_	Steel tape	OK
		Hood cover width	535		535	_	_	Steel tape	OK
		Hood cover thickness	0.9		O.8	_	_	DMM	OK
4	Guide	Guide length	8150	2	8150	8150	_	Steel tape	OK
		Guide width	std		OK	OK	_	Steel tape	OK
		Guide thickness	3		3	3	_	DMM	OK
5	Motor			JIELONG-make				Visual	OK
6	Surface finish	Matched with RAL PAD						Visual	OK
		Coating Thickness	70-80µ		76µ	79µ	78µ	DFT meter	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

22/3/24

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Vijay V Satpute QUEST 3046 Pune

NIHVA NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	ormat no.: NIHVA- QA-F-07 Rev. no.: 00 Rev date: Date of origin: 01.01.2017

Client Name- Rinac India Limited | **Report No--**

Project Name- NTPL- | **Location-** NIHVA MANUFACTURING UNIT | **Date-17-03-2024**

Product Name- Motorised rolling shutter (W6000 mm X H 6000 mm) | **Qty-**02 NOS

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain	Curtain Length	6160	65	6160	6160	6160	Steel tape	OK
		Curtain width	75		75	75	75	DVC	OK
		Curtain Thickness	1.2		1.2	1.2	1.2	DMM	OK
		Curtain Profile	Curved		OK	OK	OK	Visual	OK
2	Roller shaft	Roller Length	6260	2	6260	6260	_	Steel tape	OK
		Roller dia.	165		165	165	_	DVC	OK
3	Hood cover	Hood cover Length	6570	2	6570	6570	_	Steel tape	OK
		Hood cover width	455		455	455	_	Steel tape	OK
		Hood cover thickness	0.9		0.8	0.8	_	DMM	OK
4	Guide	Guide length	6150	4	6150	6150	6150	Steel tape	OK
		Guide width	std		OK	OK	OK	Steel tape	OK
		Guide thickness	3		3	3	3	DMM	OK
5	Motor			JIELONG make				Visual	OK
6	Surface finish	Matched with RAL PAD						Visual	OK
		Coating Thickness	70-80µ		76µ	79µ	78µ	DFT meter	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

22/3/24

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Vijay V Satpute QUEST 3046 Puna

NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	ormat no.: NIHVA- QA-F-07
		Rev. no.: 00
		Rev date:
		Date of origin: 01.01.2017

Client Name- Rinac India Limited | **Report No--**

Project Name- NTPL- | **Location-** NIHVA MANUFACTURING UNIT | **Date-17-03-2024**

Product Name- Motorised rolling shutter (W4500 mm X H 4500 mm) | **Qty-**07 NOS

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain	Curtain Length	4660	490	4660	4661	4660	Steel tape	OK
		Curtain width	75		75	75	75	DVC	OK
		Curtain Thickness	1.2		1.2	1.2	1.2	DMM	OK
		Curtain Profile	Curved		OK	Ok	OK	Visual	OK
2	Roller shaft	Roller Length	4730	7	4730	4730	4730	Steel tape	OK
		Roller dia.	140		140	140	140	DVC	OK
3	Hood cover	Hood cover Length	4970	7	4970	4970	4970	Steel tape	OK
		Hood cover width	380		380	380	380	Steel tape	OK
		Hood cover thickness	0.9		0.8	0.8	0.8	DMM	OK
4	Guide	Guide length	4500	14	4500	4500	4500	Steel tape	OK
		Guide width	100		100	100	100	Steel tape	OK
		Guide thickness	2		2	2	2	DMM	OK
5	Motor			JIELONG-make				Visual	OK
6	Surface finish	Matched with RAL PAD						Visual	OK
		Coating Thickness	70-80µ		76µ	79µ	78µ	DFT meter	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

22/3/24

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Vijay V Satpute QUEST 3046 Pune

NIHVA NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	ormat no.: NIHVA- QA-F-07 Rev. no.: 00 Rev date: Date of origin: 01.01.2017

Client Name- Rinac India Limited | **Report No--**

Project Name- NTPL- | **Location-** NIHVA MANUFACTURING UNIT | **Date-17-03-2024**

Product Name- Motorised rolling shutter (W3000 mm X H 3500 mm) | **Qty-**06 NOS

Sr.No	Part Name	Drawing no.	Specification	QTY	Observation			Instrument used	Remark
					1	2	3		
1	Curtain	Curtain Length	3160		3160	3160	3160	Steel tape	OK
		Curtain width	75		75	75	75	DVC	OK
		Curtain Thickness	1.2		1.2	1.2	1.2	DMM	OK
		Curtain Profile	Curved		OK	OK	OK	Visual	OK
2	Roller shaft	Roller Length	3230	6	3230	3230	3230	Steel tape	OK
		Roller dia.	114		114	114	114	DVC	OK
3	Hood cover	Hood cover Length	3470	6	3470	3470	3470	Steel tape	OK
		Hood cover width	360		360	360	360	Steel tape	OK
		Hood cover thickness	0.9		0.8	0.8	0.8	DMM	OK
4	Guide	Guide length	3500	12	3500	3500	3500	Steel tape	OK
		Guide width	100		100	100	100	Steel tape	OK
		Guide thickness	2		2	2	2	DMM	OK
5	Motor			JIELONG make				Visual	OK
6	Surface finish	Matched with RAL PAD						Visual	OK
		Coating Thickness	70-80µ		76µ	79µ	78µ	DFT meter	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

22/3/24

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Vijay V Satpute QUEST 3046 Pune