3. CEN Performance

The following tests have been carried out by the Swedish National Testing and Research Institute (SP) in Borås.

3.1 Lifetime expectation

- 100.000 door cycles

3.2 Resistance to wind load

EN12424	
Test result	Class 2-5 (depending on door size).

Class	**Pressure Pa (N/m^2)**	**Specification**
0	-	No performance determined
1	300	
2	450	
3	700	
4	1000	
5	> 1000	Exceptional : Agreement between manufacturer and supplier

3.3 Resistance to water penetration

EN12425	
Test result	Class 3 (110 Pa)

Class	**Pressure Pa (N/m^2)**	**Specification**
0	-	No performance determined
1	30	Water spray for 15 minutes
2	50	Water spray for 20 minutes
3	> 50	Exceptional : Agreement between manufacturer and supplier

3.4 Air permeability

EN12426	
Test result	Class 2

Class	**Air permeability dp at a pressure of 50 Pa (m^3/m^2/h)**
0	-
1	24
2	12
3	6
4	3
5	1,5
6	Exceptional : Agreement between manufacturer and supplier

3.5 Thermal transmittance

EN12428	
Thermal transmittance	Depending on door size. Specific data available on request.

3.6 Acoustic insulation

ISO 717	
Acoustic insulation	15 dB

3.7 Operating forces and safe openings

EN12453 & EN12604	**Crushing force N**	**Crushing force N**	**Crushing force N**
Opening gap mm	200 mm from lateral border right from outside	In the middle of the door opening	200 mm from lateral border left from outside
50 mm	passed	passed	passed
300 mm	passed	passed	passed

The crushing force is the force needed for the safety edge to be activated. The maximum force allowed, according to EN12453 safety in use of power operated doors is 400 N within a maximum period of time of 0.75s.