NIHVA

NIHVA Technologies Pvt. Ltd.

PRE DISPATCH INSPECTION REPORT

ormat no.: NIHVA- QA-F-07

Rev. no.: 00

Rev date:

Date of origin: 01.01.2017

Client Name- Rinac India Limited

Report No-SO/23-24/073(2)

Project Name- NTPL-

Location- NIHVA MANUFACTURING UNIT

Date-21-03-2024

Product Name- Double wall rolling shutter (W3000 mm X H3500 mm)

Qty-06 NOS

Sr.No	Part Name	Parameter	Specification	QTY	Observation			Instrument used	Remark
					1	2	3		
1	Curtain	Curtain Length	3130	40	3130	3130	3130	Steel tape	OK
		Curtain width	95		95	95	95	DVC	OK
		Visual			OK	OK	OK	Visual	OK
2	Roller shaft	Roller Length	3195	1	3195	_	_	Steel tape	OK
		Roller dia.	140		140	_	_	DVC	OK
3	Hood cover	Hood cover Length	3700	1	3705	_	_	Steel tape	OK
		Hood cover width	410		410	_	_	Steel tape	OK
		Hood cover thickness	1.5		1.5	_	_	DMM	OK
4	Guide	Guide length	3650	2	3650	3650	_	Steel tape	OK
		Guide width	106		106	106	_	Steel tape	OK
		Guide thickness	3		3	3	_	DMM	OK
5	Motor	JIELONG make						Visual	OK
6	Surface finish	Matched with RAL PAD						Visual	OK
		Coating Thickness	70-80µ		76µ	79µ	78µ	DFT meter	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

22/3/24

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Vijay V Satpute QUEST 3046 Pune