Date: 04.02.2020

Minutes of meeting

for additional requirement for each prodcut , the discussions on to understand detail requirement of product & additional technical inputs / additional accessories

Attendees From
Endraes & Hausser Mr.Vishal Chhatraband , Mr. Siddharth Kadu Mr. Jayendra Bhirud
Flowtech Pvt Ltd

Attendee From NIHVA: Mr. Vijay Tarak

Sr. No	Product	Discussed points
1	Flap Barrier	Required in SS material
		Double laefType
		Need to be integrated with clients RFID card
		Client will provide RFID tag with receiver
		Detail Technical specs to be provided by client (BOQ)
2	Sliding Gate	Client has considered rectrable sliding gate but after deatiled technical discussion NIHVA has proposed Telescopic Sliding Gate
		Sliding gate needs to Hot dip galavanised
		Client will provide detail dimension along with single leaf or double leaft type & reqiuired accessories
		Make: NIHVA
3	Rolling Shutter	Electric Motor need to be consider Direct Drive
		Curtain Profile need to be considered curved type & perforated type
		Rolling shutter need to be powder coated (RAL 9006)
		NIHVA has to quote in two options: NIHVA mae & Teckentrup GMBH made in Germant
4	Sectional Door	Same as per BOQ
		Mounting Type: STd Lift which will be confirmed on final drawing approval by client
		Sectional door ned to be interlock with DL & scissor lift
		Make ASSA ABLOY
5	High Speed Door	Same as per BOQ
		Horizontal single vision ROW
		Anticrash mechanism + soft safety edge & other safety parameters need to be considered
		Make: ASSA ABLOY
6	Dock leveler	Dock leveler need to quote in two options for different size
		A: W 2000 mm X L 2500 mm
		B W 2000 mm x L 3000 mm
		Dock Leveler need to be Hot Dip Galvanised
		Make: ASSA ABLOY
7	Dock Shelter	The front white patch on the dock shelter need to be reflective strip
		Retractable Dock Shelter
		Make: ASSA ABLOY
8	Scissor Lift	Hot Dip Galvanised
		All platform four edges should have safety edge
		Safet Below need to be consider
		Interlock with Dock Leveler & Sectional Door
		Make : NIHVA