NIHVA

PRE DISPATCH INSPECTION REPORT

NIHVA- QA-F-07

Client Name- Shree Pre Fab

Report No-PDIR-SPF-02

Project Name-Shree Pre Fab

Location- NIHVA SHOP

Date-25/09/2023

Product Name- Rolling Shutter (W4000xH4000mm)(Gear Oprated)

Qty-05 NOS

Sr.No	Part Name	Drawing No	Dimention In mm	Qty per Product	Observation			Remark
					1	2	3	
1	Curtain(HxWxT)	NIHVA/23-24/MFG/0134_SPF	4150x4100x1.2	330	OK	OK	OK	Acceptable
2	Curtain Panel Size	NIHVA/23-24/MFG/0134_SPF	85 wide	330	85	85	85	Acceptable
3	Curtain Profile	NIHVA/23-24/MFG/0134_SPF	Curved	330	OK	OK	OK	Acceptable
4	Roller Cage(LxD)	NIHVA/23-24/MFG/0134_SPF	4350x200	4	OK	OK	OK	Acceptable
5	Hood Cover (LxWxT)	NIHVA/23-24/MFG/0134_SPF	4700x462x1.2	4	4700x462x1.2	4700x462x1.2	4700x462x1.2	Acceptable
6	M.S. Bottom (LxWxT)	NIHVA/23-24/MFG/0134_SPF	4150x100x3	4	4150x100x3	4150x100x3	4150x100x3	Acceptable
7	Guide(LxWxT)	NIHVA/23-24/MFG/0134_SPF	4150x3.2	4	4150x3.2	4150x3.2	4150x3.2	Acceptable
8	M.S. Bracket (LxWxT)	NIHVA/23-24/MFG/0134_SPF	380x380x3	8	380x380x3	380x380x3	380x380x3	Acceptable
9	Surface Finish	NIHVA/23-24/MFG/0134_SPF	Powder Coating RAL Coad-9001(Cream Color)		OK	OK	OK	Acceptable

Remark- All Material Are visually & dimensionally found ok

Inspected By- Rohit Shinde

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Checked By- Rohit Shinde

Approved By- Amit Kurhade

Client Name- Shree Pre Fab								**Report No-**PDIR-SPF-04
Project Name-Shree Pre Fab				**Location-** NIHVA SHOP				**Date-25/09/2023**
Product Name- Rolling Shutter (W6000xH6000mm)(Motor Operated)					**Qty-**04 NOS			
Sr.No	**Part Name**	**Drawing No**	**Dimention In mm**	**Qty per Product**	**Observation**			**Remark**
					1	2	3	
1	Curtain(HxWxT)	NIHVA/23-24/HC_SPF	6150x6180x1.2	380	OK	OK	OK	Acceptable
2	Curtain Panel Size	NIHVA/23-24/HC_SPF	80 wide	380	80	80	80	Acceptable
3	Curtain Profile	NIHVA/23-24/HC_SPF	Curved	380	OK	OK	OK	Acceptable
4	Roller (LxD)	NIHVA/23-24/HC_SPF	6230x165	2	OK	OK	OK	Acceptable
5	Hood Cover (LxWxT)	NIHVA/23-24/HC_SPF	6700x537x1.2	2	6700x537x1.2	6700x537x1.2	6700x537x1.2	Acceptable
6	M.S. Bottom (LxWxT)	NIHVA/23-24/HC_SPF	6180x100x3	2	6180x100x3	6180x100x3	6180x100x3	Acceptable
7	Guide(LxWxT)	NIHVA/23-24/HC_SPF	6150x3.2	4	6150x3.2	6150x3.2	6150x3.2	Acceptable
8	M.S. Bracket (LxWxT)	NIHVA/23-24/HC_SPF	455x455x3	4	455x455x3	455x455x3	455x455x3	Acceptable
9	Surface Finish	NIHVA/23-24/HC_SPF	Powder Coating RAL Coad-9001(Cream Color)		OK	OK	OK	Acceptable
Remark- All Material Are visually & dimensionally found ok								
Inspected By- Rohit Shinde				**Checked By-** Rohit Shinde			**Approved By-** Amit Kurhade	

