NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	Format no.: NIHVA- QA-F-07
		Rev. no.: 00
		Rev date:
		Date of origin: 01.01.2017

Client Name- Rinac India Limited — **Report No-SO/23-24/073(2)**

Project Name- NTPL- — **Location-** NIHVA MANUFACTURING UNIT — **Date-22-03-2024**

Product Name- Double wall rolling shutter (W3000 mm X H3500 mm) — **Qty-**01 NOS

Sr.No	Part Name	Parameter	Specification	QTY	Observation			Instrument used	Remark
					1	2	3		
1	Curtain	Curtain Length	3130	40	3130	3130	3130	Steel tape	OK
		Curtain width	95		95	95	95	DVC	OK
		Visual			OK	OK	OK	Visual	OK
2	Roller shaft	Roller Length	3195	1	3195	_	_	Steel tape	OK
		Roller dia.	140		140	_	_	DVC	OK
3	Hood cover	Hood cover Length	3700	1	3705	_	_	Steel tape	OK
		Hood cover width	410		410	_	_	Steel tape	OK
		Hood cover thickness	1.5		1.5	_	_	DMM	OK
4	Guide	Guide length	3650	2	3650	3650	_	Steel tape	OK
		Guide width	106		106	106	_	Steel tape	OK
		Guide thickness	3		3	3	_	DMM	OK
5	Motor	JIELONG make						Visual	OK
6	Surface finish	Matched with RAL 9006						Visual	OK
		Coating Thickness	70-80µ		76µ	79µ	78µ	DFT meter	OK

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

For Renew Power

Vijay V Satpute QUEST 3046 Pune