MURBAD, INDIA	**TEST CERTIFICATE FOR STEEL TUBES**	**Format No.: QA-F-18** **Rev.no. : 00** **Date : 10.10.2017**

APL APOLLO TUBES LIMITED UNIT-III

Works-Vill-Kudavali Plot No-M-1, Murbad, 421401, Thane (MS)

IS: 4923

CM/L-3850769

TEST CERTIFICATE NO :	**IS4923/210/IS0813**
DATE :	**18-11-20**
INVOICE NO	**2005004801**
INVOICE DATE	**18-11-20**

M/s S MAHIPAL STEEL

We certify that the material described below fully conformed to IS 4923 : 2017. Chemical composition and Mechanical properties of the product, as tested in tested in accordance with the scheme of testing and inspection contained in the BIS certification marks license no. CM/L-3850769 are as indicated below against each order no.

TEST RESULT

Size	**Grade/ Type**	**HEAT NO./ BATCH NO.**	**Pcs.**	**TOTAL Wt (MT)**	**CHEMICAL ANALYSIS (% Max)**				**MECHANICAL PROPERTIES (Min)**			**GALVANIZING (Min)**	
					C	**Mn**	**P**	**S**	**Tensile Strength (Mpa)**	**Yeild Strenth (Mpa)**	**%El**	**Weight (g/m2)**	**Uniformity**
Requirements					**0.12**	**0.60**	**0.04**	**0.04**	**330**	**210**	**20**	**N/A**	**N/A**
96 X 48 X 2.90 mm	BLK RHS (YST-210)	**20104414 / 7201115B**	144	5.19	0.04	0.104	0.015	0.005	401	315	34	_	_
72 X 72 X 4.00 mm	BLK SHS (YST-210)	**20202974 / 7201112B**	108	5.6	0.04	0.115	0.019	0.004	396	312	31	_	_
80 X 40 X 5.00 mm	BLK RHS (YST-210)	**20104189 / 6201108A**	91	4.77	0.038	0.114	0.01	0.007	388	304	32	_	_

It is certified that Material supplied conforms to standard dimensions and mass tolerances.

AUTHORISED SIGNATORY

PREPARED BY

FOR APL APOLLO TUBES LIMITED