NIHVA Technologies Pvt. Ltd.	PRE DISPATCH INSPECTION REPORT	Format no.: NIHVA-QA-F-07
		Rev. no.: 00
		Rev date:
		Date of origin: 01.01.2017

Client Name- SHREE PRE FAB STEELS PVT LTD			Report No--SO/23-24/059(2)
Project Name- NTPL-208	Location- NIHVA MANUFACTURING UNIT		Date-12-03-2024
Product Name- GI 1.2mm Gear Opearated Rolling Shutter (W 5000 mm X H 6000 mm)		Qty-01 NOS	

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain Length	NIHVA/22-23/SO/060	5150 ± 8	90	5150	5149	5152	Steel Tape	OK
2	Curtain width	NIHVA/22-23/SO/060	75 ± 1.5		76.24	76.23	76.38	Digital Vernier caliper	OK
3	Curtain Thickness	NIHVA/22-23/SO/060	1.2 ± 0.2		1.21	1.2	1.2	Digital Micrometer	OK
4	Curtain Profile	NIHVA/22-23/SO/060	Curved		OK	OK	OK	Visual	OK
5	M.S. Bottom length	NIHVA/22-23/SO/060	5150 ± 8	1	5152	–	–	Steel Tape	OK
6	M.S. Bottom width	NIHVA/22-23/SO/060	125 ± 2.5		127.2	–	–	Digital Vernier caliper	OK
7	M.S. Bottom thickness	NIHVA/22-23/SO/060	2 ± 0.2		2.006	–	–	Digital Micrometer	OK
8	Bottom lock	NIHVA/22-23/SO/060	–	2	OK	–	–	Visual	OK
9	Shaft assembly	NIHVA/22-23/SO/060	–	1	OK	–	–	Visual	OK
10	Hood cover Length	NIHVA/22-23/SO/060	5700 ± 8	1	5694	–	–	Steel Tape	OK
11	Hood cover width	NIHVA/22-23/SO/060	450 ± 4		452	–	–	Steel Tape	OK
12	Hood cover height	NIHVA/22-23/SO/060	450 ± 4		453	–	–	Steel Tape	OK
13	Hood cover thickness	NIHVA/22-23/SO/060	0.9 ± 0.2		0.8	–	–	Digital Micrometer	OK
14	Guide length	NIHVA/22-23/SO/060	6150 ± 8	2	6153	6153	–	Steel Tape	OK
15	Guide width	NIHVA/22-23/SO/060	130 ± 2.5		130	131	–	Steel Tape	OK
16	Guide thickness	NIHVA/22-23/SO/060	3.0 ± 0.2		2.896	2.987	–	Digital Micrometer	OK
17	M.S. Bracket (LxW)	NIHVA/22-23/SO/060	450x450	2	OK	OK	–	Steel Tape	OK
18	M.S. Bracket thickness	NIHVA/22-23/SO/060	5 ± 0.5		5.087	5.076	–	Digital Micrometer	OK
19	Gear Box & Handle	NIHVA/22-23/SO/060			OK	–	–	Visual	OK
20	Product name plate				NGRS1077			Visual	OK

Note-1) All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Approved By- Amit Karhade