NIHVA
NIHVA TECHNOLOGIES PVT. LTD.

Site Pre-installation Check Sheet NIHVA-PRJ-F-03

03/04/23

Client Name & Location	:-	~~Sa~~ John Deere India Pvt Ltd.
Product location	:-	Aggregate Paint Shop.
Product Type	:-	Air Curtain
Product size	:-	QTY :

Sr.No	INSPECTION POINTS	DESCRIPTION	Yes/No	Client scope	Nihva Scope
1	Site readyness-dimensions				
2	Power Supply-location	cable= mtr			
3	Height Arrangement - scissorlift/boomlift/scaffolding				
4	Local Travelling/Hotels				
5	Installation Plan	Discussed Air curtain Installation			
6	Saftey equipements required				
7	Gatepass/Work permit proedure	any documents require for gatpass and work permit			
8	NIHVA Material check	ensure material as per BOQ			
9	Tools Required				
10					
11					
12					
13					

Remarks (if any) :- Discussed Air Curtain Installation Location and plan.

NIHVA Inspection /Maintanance person Name	:-	Sandip Mandavkar
Sign of Inspection / maintanance person	:-	
User/Client Shift Engg. / Manager Name & Sign	:-	Manish Chak

NIHVA
NIHVA TECHNOLOGIES PVT. LTD.

Site Pre-installation Check Sheet NIHVA-PRJ-F-03

Client Name & Location :-	Srusti associate	
Product location :-	new building	
Product Type :-	motorized rolling shutter	
Product size :-	8000×8500 (W×H)	QTY : 02

Sr.No	INSPECTION POINTS	DESCRIPTION	Yes/No	Client scope	Nihva Scope
1	Site readyness-dimensions	Clear width-8000 clear height 8500 mm structure size 8000×9000 mm			
2	Power Supply-location	cable= mtr shutter moto location top right side-3ph			
3	Height Arrangement - scissorlift/boomlift/scaffolding	client scope. use for safety work			
4	Local Travelling/Hotels	NIHVA scope Accommodation			
5	Installation Plan	After Competition structure work			
6	Saftey equipements required	PPE kit			
7	Gatepass/Work permit proedure	any documents require for gatpass and work permit Gate pass or ~~Re~~ permit client scope			
8	NIHVA Material check	ensure material as per BOQ material verified by quality & project			
9	Tools Required	as per std for shutter installation			
10					
1					
12					
13					

Remarks (if any) :- ① we need to structure as per structure drawing ② clear width-8000mm & clear height 9000 mm ③ Power supply should be top right in motor side-3ph ④ canopy must for rain avoid & work safety ⑤ structure channel -100×50×5mm ~~re~~quired ⑥ structure should be in one Plinth level

NIHVA Inspection /Maintanance person Name :- Vijay Rathod

Sign of Inspection / maintanance person :- Faridp pandurede

User/Client Shift Engg. / Manager Name & Sign :- Faridkey 7350679227 17/03/25