SECTIONAL DOORS	NIHVA TECHNOLOGIES PVT. LTD.
Specification	**Crawford - NIHVA Assaabloy**
Door type	1042P
Clear Opening dimension	(W)2500 x (H)3000 mm
Opening Direction	Standard
Type of Mounting	Standard
Door produced Based on which	Doors produced according to ISO 9000 or ISO 14000
Opening/Closing Speed	0,28/0,28 m/s
Door Material	GI Steel
Panel Thickness	42mm
Panel colour	RAL 9002 Powder coated
External surface of the panel	diamond grid design with a glossy finish at the
inside surface of the panel	Monolithic surface on the inside of the door
Broken cold bridge	Section joints with broken cold bridges
Panels are euipped with ?	Panels to have integrated steel reinforcement for
Door sealent	All door sealants made of EPDM rubber,
All Panek height	All panels should be 545mm high
Panel Inside insulation metrial	Insulation material to be CFC free polyuretane foam.
Panel Flam Retardent standrad	Flame retardant polyurethane foam according
Steel component Material	All steel components to be electro galvanized
Hinge Material	Glass fibre reinforced Polyamide
Panel Thickness	42 mm
Spring Material surface finish	Powder coated
Spings transport till plant	Pre tensioned spring package
Water Penetration	EN 12425 class 3
Air Permealibity	EN12426 class 3
Wind Load	EN21424 class 3
Thermal Transittance	EN 12428 1.10W /m2K
Bottom sealing	Bottom of the door to be equiped with three lip
Door saftey device 1	Doors equiped with spring break device
Door saftey device 2	Door equiped with pneumatic safety edge
Door saftey 3	Having hinges flush with the inside door surface is a
Incase of Power failuer	Doors to be equiped with quick release fuction
Operator power conumption	**Operator to have a maximum power consumption**
Frequency converter	Built in Frequency converter
Drive Unit & Mounting Type	Single phase 230V direct drive on shaft
Emergency Operation	by Disengagement rope manual
Operating Switch	Up/Down Keypad + stopbutton
Environmental Green Product Declaration	as per ISO 14025 and EN 15804