WIKA Instruments India Pvt.Ltd.
Plot No. 40, Gat No. 94+100, High Cliff Industrial Estate, Village Kesnand, Pune - 412207.
Tel : 00-91-20-66293200 -, Fax 66293325, Himanshu.Sharda@wika.com

ISO 9001-2015 Certified

TEST & GUARANTEE CERTIFICATE ACCORDING TO EN10204-2.2
FOR PRESSURE/TEMPERATURE MEASURING INSTRUMENTS

Custom **S.A ELECTRONIC PRIVATE LIMITED**
Plot no.T-165/3/11, Priyadarshani Mahila Swayamrojgar Ind. Premises, Co-op Soc. Ltd., MIDC Bhosari,Pune 411026

Certificate No.:CER. QA-22-10846
Date : 21-Dec-22

Order N **0429** **OA No:** **SO00082942** **Our Invoice No**

Date: 11/11/2022 **Date:** **11-Nov-22** **GST-MH09332-2223**

This is to certify that following Measuring Instruments are manufactured as per specifaction & only inspection passed materials have been used.

Execution of instruments/Systems as applicable has been carried out by following the WIKA Quality Assurance Procedures.
Visual, Workmanship & Functional tests for instruments & accessories are carried out and passed successfully.
Quality Inspection was successfully passed.

WIKA Instruments (India) Pvt.Ltd. undertake a Guarantee of 12 months from the date of supply of Instruments for any manufacturing defects/wrong materials used which are not in accordance with the relevant specifications.

Instruments are tested for Accuracy,Repeatability,Hysteresis,over range protection,linearity, leak rates as applicable; and found within specified limits -as per applicable standards- given below:-

EN 837 (PG)/ISO 5171 (WPG)/EN13190 (TG)/IEC 60751 (RTD)/IEC 584 (TC)/ ASME B40.1 (PG)

Item No	QTY	WIKA Item No.	Customer Item No.	Model Code	Accuracy	Range
1	2	71101152	-	S5550/4	±2.0ºC	0 to 160ºC
2	1	82369926	-	R52.100/4	±2.0ºC	0 to 120ºC
3	1	65884816	-	R5503/4	±5.0ºC	0 to 300ºC

For WIKA Instruments India Pvt Ltd.
S. N. Patil

WIKA QA

Quality Assurance