```
**************************************************
*                                                *
*          STAAD.Pro CONNECT Edition             *
*          Version  22.02.00.26                  *
*          Proprietary Program of                *
*          Bentley Systems, Inc.                 *
*          Date=    NOV  5, 2022                 *
*          Time=    19:15: 0                     *
*                                                *
*  Licensed to: only @ ::LAVTeam:: (R)           *
**************************************************
```

```
     1. STAAD SPACE
INPUT FILE: C:\Users\HARSHA~1\OneDrive\Salt\1729HY~1\STAAD\1729 HYD Hanger door 05-11-2022.STD
     2. START JOB INFORMATION
     3. ENGINEER DATE 11-SEP-22
     4. END JOB INFORMATION
     5. INPUT WIDTH 79
     6. UNIT METER KN
     7. JOINT COORDINATES
     8. 1 -0.213 0 -0.250001; 2 2.49201 0 -0.250001; 3 81.7462 0 -0.250001
     9. 4 84.4202 0 -0.250001; 5 96.3202 0 -0.250001; 6 100.3 0 -0.250001
    10. 7 191.677 0 -0.250001; 8 195.688 0 -0.250001; 10 -0.213 31.5501 -0.250001
    11. 13 84.4202 31.5501 -0.250001; 19 42.1191 32.3401 -0.250001
    12. 22 -0.213 25.45 -0.250001; 23 2.49201 25.45 -0.250001
    13. 24 81.7462 25.45 -0.250001; 25 84.4202 25.45 -0.250001
    14. 26 42.1191 25.45 -0.250001; 27 48.1191 25.45 -0.250001
    15. 28 54.1191 25.45 -0.250001; 29 60.1191 25.45 -0.250001
    16. 30 66.1191 25.45 -0.250001; 31 72.1192 25.45 -0.250001
    17. 32 78.1192 25.45 -0.250001; 33 36.1191 25.45 -0.250001
    18. 34 30.1191 25.45 -0.250001; 35 24.1191 25.45 -0.250001
    19. 36 18.119 25.45 -0.250001; 37 12.119 25.45 -0.250001
    20. 38 6.11902 25.45 -0.250001; 63 -0.213 16.7 -0.250001
    21. 64 2.49201 16.7 -0.250001; 65 81.7462 16.7 -0.250001
    22. 66 84.4202 16.7 -0.250001; 67 36.1191 16.7 -0.250001
    23. 68 48.1191 16.7 -0.250001; 83 6.11902 16.7 -0.250001; 84 12.119 16.7 -0.250001
    24. 85 19.243 16.7 -0.250001; 86 24.1191 16.7 -0.250001; 87 30.1191 16.7 -0.250001
    25. 88 54.1191 16.7 -0.250001; 89 60.1191 16.7 -0.250001
    26. 90 64.9951 16.7 -0.250001; 91 72.1192 16.7 -0.250001
    27. 92 78.1192 16.7 -0.250001; 105 -0.213 4.17501 -0.250001
    28. 106 -0.213 8.35002 -0.250001; 107 -0.213 12.525 -0.250001
    29. 108 2.49201 4.17501 -0.250001; 109 2.49201 8.35002 -0.250001
    30. 110 2.49201 12.525 -0.250001; 111 81.7462 4.17501 -0.250001
    31. 112 81.7462 7.67702 -0.250001; 113 81.7462 12.525 -0.250001
    32. 114 84.4202 4.17501 -0.250001; 115 84.4202 7.67702 -0.250001
    33. 116 84.4202 12.525 -0.250001; 122 96.3202 24.67 -0.250001
    34. 123 195.688 24.67 -0.250001; 124 100.3 24.7509 -0.250001
    35. 125 191.677 24.7509 -0.250001; 175 2.49201 31.599 -0.250001
    36. 176 6.11902 31.663 -0.250001; 177 12.119 31.7758 -0.250001
    37. 178 18.119 31.8887 -0.250001; 179 24.1191 32.0015 -0.250001
    38. 180 30.1191 32.1144 -0.250001; 181 36.1191 32.2272 -0.250001
```

39. 182 48.1191 32.2272 -0.250001; 183 54.1191 32.1144 -0.250001
40. 184 60.1191 32.0015 -0.250001; 185 66.1191 31.8887 -0.250001
41. 186 72.1192 31.7758 -0.250001; 187 78.1192 31.663 -0.250001
42. 188 81.7462 31.5971 -0.250001; 189 96.3202 16.7 -0.250001
43. 190 100.3 16.7 -0.250001; 191 191.677 16.7 -0.250001
44. 192 195.688 16.7 -0.250001; 212 96.3202 4.17501 -0.250001
45. 213 96.3202 7.67702 -0.250001; 214 96.3202 12.525 -0.250001
46. 215 100.3 4.17501 -0.250001; 216 100.3 7.67702 -0.250001
47. 217 100.3 12.525 -0.250001; 218 191.677 4.17501 -0.250001
48. 219 191.677 7.67702 -0.250001; 220 191.677 12.525 -0.250001
49. 221 195.688 4.17501 -0.250001; 222 195.688 7.67702 -0.250001
50. 223 195.688 12.525 -0.250001; 246 2.49198 28.528 -0.250001
51. 247 81.7466 28.528 -0.250001; 248 146.004 25.67 -0.250001
52. 249 146.004 16.7 -0.250001; 251 140.004 16.7 -0.250001
53. 253 134.004 16.7 -0.250001; 255 130.717 16.7 -0.250001
54. 257 122.004 16.7 -0.250001; 259 116.562 16.7 -0.250001
55. 261 110.004 16.7 -0.250001; 263 104.004 16.7 -0.250001
56. 265 152.004 16.7 -0.250001; 267 158.004 16.7 -0.250001
57. 269 161.291 16.7 -0.250001; 271 170.004 16.7 -0.250001
58. 273 175.447 16.7 -0.250001; 275 182.004 16.7 -0.250001
59. 277 188.004 16.7 -0.250001; 278 188.004 24.8248 -0.250001
60. 279 182.004 24.9455 -0.250001; 280 176.004 25.0663 -0.250001
61. 281 170.004 25.187 -0.250001; 282 164.004 25.3078 -0.250001
62. 283 158.004 25.4285 -0.250001; 284 152.004 25.5493 -0.250001
63. 285 140.004 25.5493 -0.250001; 286 134.004 25.4287 -0.250001
64. 287 128.004 25.308 -0.250001; 288 122.004 25.1874 -0.250001
65. 289 116.004 25.0667 -0.250001; 290 110.004 24.946 -0.250001
66. 291 104.004 24.8254 -0.250001; 292 100.3 20.7235 -0.250001
67. 293 191.677 20.7233 -0.250001; 294 98.3102 18.7117 -0.250001
68. 295 83.0832 21.075 -0.250001; 307 -0.213 31.5501 -5.12501
69. 308 84.4202 31.5501 -5.12501; 309 42.1191 32.3401 -5.12501
70. 310 -0.213 27.342 -5.12501; 311 84.4202 27.342 -5.12501
71. 312 42.1191 27.342 -5.12501; 313 48.1191 27.342 -5.12501
72. 314 54.1191 27.342 -5.12501; 315 60.1191 27.342 -5.12501
73. 316 66.1191 27.342 -5.12501; 317 72.1192 27.342 -5.12501
74. 318 78.1192 27.342 -5.12501; 319 36.1191 27.342 -5.12501
75. 320 30.1191 27.342 -5.12501; 321 24.1191 27.342 -5.12501
76. 322 18.119 27.342 -5.12501; 323 12.119 27.342 -5.12501
77. 324 6.11902 27.342 -5.12501; 325 6.11902 31.663 -5.12501
78. 326 12.119 31.7758 -5.12501; 327 18.119 31.8887 -5.12501
79. 328 24.1191 32.0015 -5.12501; 329 30.1191 32.1144 -5.12501
80. 330 36.1191 32.2272 -5.12501; 331 48.1191 32.2272 -5.12501
81. 332 54.1191 32.1144 -5.12501; 333 60.1191 32.0015 -5.12501
82. 334 66.1191 31.8887 -5.12501; 335 72.1192 31.7758 -5.12501
83. 336 78.1192 31.663 -5.12501; 337 96.3202 24.67 -5.12501
84. 338 195.688 24.67 -5.12501; 339 146.004 25.67 -5.12501
85. 340 188.004 24.8248 -5.12501; 341 182.004 24.9455 -5.12501
86. 342 176.004 25.0663 -5.12501; 343 170.004 25.187 -5.12501
87. 344 164.004 25.3078 -5.12501; 345 158.004 25.4285 -5.12501
88. 346 152.004 25.5493 -5.12501; 347 140.004 25.5493 -5.12501
89. 348 134.004 25.4287 -5.12501; 349 128.004 25.308 -5.12501
90. 350 122.004 25.1874 -5.12501; 351 116.004 25.0667 -5.12501
91. 352 110.004 24.946 -5.12501; 353 104.004 24.8254 -5.12501
92. 354 146.004 19.677 -5.12501; 355 140.004 19.677 -5.12501
93. 356 134.004 19.677 -5.12501; 357 128.004 19.677 -5.12501
94. 358 122.004 19.677 -5.12501; 359 116.004 19.677 -5.12501

95. 360 110.004 19.677 -5.12501; 361 104.004 19.677 -5.12501
96. 362 152.004 19.677 -5.12501; 363 158.004 19.677 -5.12501
97. 364 164.004 19.677 -5.12501; 365 170.004 19.677 -5.12501
98. 366 176.004 19.677 -5.12501; 367 182.004 19.677 -5.12501
99. 368 188.004 19.677 -5.12501; 369 2.49201 27.342 -5.12501
100. 370 81.7462 27.342 -5.12501; 371 96.3202 16.7 -5.12501
101. 372 100.3 19.677 -5.12501; 373 191.677 19.677 -5.12501
102. 374 195.688 16.7 -5.12501; 375 195.688 7.67701 -5.12501
103. 376 96.3198 7.67701 -5.12501; 377 -0.213 15.342 -5.12501
104. 378 84.4202 15.342 -5.12501; 385 1.13951 21.075 -0.250001; 386 -0.213 0 1.25
105. 387 2.49201 0 1.25; 388 81.7462 0 1.25; 389 84.4202 0 1.25; 390 96.3202 0 1.25
106. 391 100.3 0 1.25; 392 191.677 0 1.25; 393 195.688 0 1.25; 394 90.3702 0 1.25
107. 395 -0.213 31.5501 1.25; 396 84.4202 31.5501 1.25; 397 42.1191 32.3401 1.25
108. 398 -0.213 25.45 1.25; 399 2.49201 25.45 1.25; 400 81.7462 25.45 1.25
109. 401 84.4202 25.45 1.25; 402 42.1191 25.45 1.25; 403 48.1191 25.45 1.25
110. 404 54.1191 25.45 1.25; 405 60.1191 25.45 1.25; 406 66.1191 25.45 1.25
111. 407 72.1192 25.45 1.25; 408 78.1192 25.45 1.25; 409 36.1191 25.45 1.25
112. 410 30.1191 25.45 1.25; 411 24.1191 25.45 1.25; 412 18.119 25.45 1.25
113. 413 12.119 25.45 1.25; 414 6.11902 25.45 1.25; 415 -0.213 16.7 1.25
114. 416 2.49201 16.7 1.25; 417 81.7462 16.7 1.25; 418 84.4202 16.7 1.25
115. 419 36.1191 16.7 1.25; 420 48.1191 16.7 1.25; 421 6.11902 16.7 1.25
116. 422 12.119 16.7 1.25; 423 19.243 16.7 1.25; 424 24.1191 16.7 1.25
117. 425 30.1191 16.7 1.25; 426 54.1191 16.7 1.25; 427 60.1191 16.7 1.25
118. 428 64.9951 16.7 1.25; 429 72.1192 16.7 1.25; 430 78.1192 16.7 1.25
119. 431 -0.213 4.17501 1.25; 432 -0.213 8.35002 1.25; 433 -0.213 12.525 1.25
120. 434 2.49201 4.17501 1.25; 435 2.49201 8.35002 1.25; 436 2.49201 12.525 1.25
121. 437 81.7462 4.17501 1.25; 438 81.7462 7.67702 1.25; 439 81.7462 12.525 1.25
122. 440 84.4202 4.17501 1.25; 441 84.4202 7.67702 1.25; 442 84.4202 12.525 1.25
123. 443 96.3202 24.67 1.25; 444 195.688 24.67 1.25; 445 100.3 24.7509 1.25
124. 446 191.677 24.7509 1.25; 447 2.49201 31.599 1.25; 448 6.11902 31.663 1.25
125. 449 12.119 31.7758 1.25; 450 18.119 31.8887 1.25; 451 24.1191 32.0015 1.25
126. 452 30.1191 32.1144 1.25; 453 36.1191 32.2272 1.25; 454 48.1191 32.2272 1.25
127. 455 54.1191 32.1144 1.25; 456 60.1191 32.0015 1.25; 457 66.1191 31.8887 1.25
128. 458 72.1192 31.7758 1.25; 459 78.1192 31.663 1.25; 460 81.7462 31.5971 1.25
129. 461 96.3202 16.7 1.25; 462 100.3 16.7 1.25; 463 191.677 16.7 1.25
130. 464 195.688 16.7 1.25; 465 96.3202 4.17501 1.25; 466 96.3202 7.67702 1.25
131. 467 96.3202 12.525 1.25; 468 100.3 4.17501 1.25; 469 100.3 7.67702 1.25
132. 470 100.3 12.525 1.25; 471 191.677 4.17501 1.25; 472 191.677 7.67702 1.25
133. 473 191.677 12.525 1.25; 474 195.688 4.17501 1.25; 475 195.688 7.67702 1.25
134. 476 195.688 12.525 1.25; 477 90.3702 16.7 1.25; 478 90.3702 12.525 1.25
135. 479 90.3702 7.67702 1.25; 480 90.3702 4.17501 1.25; 481 90.3702 25.06 1.25
136. 482 2.49198 28.528 1.25; 483 81.7466 28.528 1.25; 484 146.004 25.67 1.25
137. 485 146.004 16.7 1.25; 486 140.004 16.7 1.25; 487 134.004 16.7 1.25
138. 488 130.717 16.7 1.25; 489 122.004 16.7 1.25; 490 116.562 16.7 1.25
139. 491 110.004 16.7 1.25; 492 104.004 16.7 1.25; 493 152.004 16.7 1.25
140. 494 158.004 16.7 1.25; 495 161.291 16.7 1.25; 496 170.004 16.7 1.25
141. 497 175.447 16.7 1.25; 498 182.004 16.7 1.25; 499 188.004 16.7 1.25
142. 500 188.004 24.8248 1.25; 501 182.004 24.9455 1.25; 502 176.004 25.0663 1.25
143. 503 170.004 25.187 1.25; 504 164.004 25.3078 1.25; 505 158.004 25.4285 1.25
144. 506 152.004 25.5493 1.25; 507 140.004 25.5493 1.25; 508 134.004 25.4287 1.25
145. 509 128.004 25.308 1.25; 510 122.004 25.1874 1.25; 511 116.004 25.0667 1.25
146. 512 110.004 24.946 1.25; 513 104.004 24.8254 1.25; 514 100.3 20.7235 1.25
147. 515 191.677 20.7233 1.25; 516 98.3102 18.7117 1.25; 517 83.0832 21.075 1.25
148. 518 93.3093 20.6723 1.25; 519 87.5698 20.8552 1.25
149. 520 36.1191 -3.41065E-05 0.500001; 521 48.1191 -3.41065E-05 0.500001
150. 522 19.243 -3.41065E-05 0.500001; 523 64.9951 -3.41065E-05 0.500001

151. 524 146.004 -3.41065E-05 0.500001; 525 130.717 -3.41065E-05 0.500001
152. 526 116.562 -3.41065E-05 0.500001; 527 161.291 -3.41065E-05 0.500001
153. 528 175.447 -3.41065E-05 0.500001; 535 1.13951 21.075 1.25
154. 536 19.243 16.7 0.500001; 537 64.9951 16.7 0.500001; 538 36.1191 16.7 0.500001
155. 539 48.1191 16.7 0.500001; 540 146.004 16.7 0.500001
156. 541 161.291 16.7 0.500001; 542 175.447 16.7 0.500001
157. 543 130.717 16.7 0.500001; 544 116.562 16.7 0.500001
158. 545 18.119 16.7 -0.250001; 546 18.119 16.7 1.25; 547 66.1191 16.7 1.25
159. 548 66.1191 16.7 -0.250001; 549 116.004 16.7 -0.250001; 550 116.004 16.7 1.25
160. 551 128.004 16.7 -0.250001; 552 128.004 16.7 1.25; 553 164.004 16.7 1.25
161. 554 164.004 16.7 -0.250001; 555 176.004 16.7 1.25; 556 176.004 16.7 -0.250001
162. 557 6.11902 18.2 1.25; 558 6.11902 18.2 -0.250001; 559 36.1191 18.2 -0.250001
163. 560 48.1191 18.2 -0.250001; 561 12.119 18.2 -0.250001
164. 562 24.1191 18.2 -0.250001; 563 30.1191 18.2 -0.250001
165. 564 54.1191 18.2 -0.250001; 565 60.1191 18.2 -0.250001
166. 566 72.1192 18.2 -0.250001; 567 78.1192 18.2 -0.250001; 568 36.1191 18.2 1.25
167. 569 48.1191 18.2 1.25; 570 12.119 18.2 1.25; 571 24.1191 18.2 1.25
168. 572 30.1191 18.2 1.25; 573 54.1191 18.2 1.25; 574 60.1191 18.2 1.25
169. 575 72.1192 18.2 1.25; 576 78.1192 18.2 1.25; 577 18.119 18.2 -0.250001
170. 578 18.119 18.2 1.25; 579 66.1191 18.2 1.25; 580 66.1191 18.2 -0.250001
171. 581 2.49201 18.2 1.25; 582 2.49201 18.2 -0.250001; 583 81.7462 18.2 1.25
172. 584 81.7462 18.2 -0.250001; 585 36.1191 23.6375 -0.250001
173. 586 36.1191 21.825 -0.250001; 587 36.1191 20.0125 -0.250001
174. 588 48.1191 23.6375 -0.250001; 589 48.1191 21.825 -0.250001
175. 590 48.1191 20.0125 -0.250001; 591 6.11902 23.6375 -0.250001
176. 592 6.11902 21.825 -0.250001; 593 6.11902 20.0125 -0.250001
177. 594 12.119 23.6375 -0.250001; 595 12.119 21.825 -0.250001
178. 596 12.119 20.0125 -0.250001; 597 18.119 23.6375 -0.250001
179. 598 18.119 21.825 -0.250001; 599 18.119 20.0125 -0.250001
180. 600 24.1191 23.6375 -0.250001; 601 24.1191 21.825 -0.250001
181. 602 24.1191 20.0125 -0.250001; 603 30.1191 23.6375 -0.250001
182. 604 30.1191 21.825 -0.250001; 605 30.1191 20.0125 -0.250001
183. 606 54.1191 23.6375 -0.250001; 607 54.1191 21.825 -0.250001
184. 608 54.1191 20.0125 -0.250001; 609 60.1191 23.6375 -0.250001
185. 610 60.1191 21.825 -0.250001; 611 60.1191 20.0125 -0.250001
186. 612 66.1191 23.6375 -0.250001; 613 66.1191 21.825 -0.250001
187. 614 66.1191 20.0125 -0.250001; 615 72.1192 23.6375 -0.250001
188. 616 72.1192 21.825 -0.250001; 617 72.1192 20.0125 -0.250001
189. 618 78.1192 23.6375 -0.250001; 619 78.1192 21.825 -0.250001
190. 620 78.1192 20.0125 -0.250001; 621 36.1191 23.6375 1.25
191. 622 36.1191 21.825 1.25; 623 36.1191 20.0125 1.25; 624 48.1191 23.6375 1.25
192. 625 48.1191 21.825 1.25; 626 48.1191 20.0125 1.25; 627 6.11902 23.6375 1.25
193. 628 6.11902 21.825 1.25; 629 6.11902 20.0125 1.25; 630 12.119 23.6375 1.25
194. 631 12.119 21.825 1.25; 632 12.119 20.0125 1.25; 633 18.119 23.6375 1.25
195. 634 18.119 21.825 1.25; 635 18.119 20.0125 1.25; 636 24.1191 23.6375 1.25
196. 637 24.1191 21.825 1.25; 638 24.1191 20.0125 1.25; 639 30.1191 23.6375 1.25
197. 640 30.1191 21.825 1.25; 641 30.1191 20.0125 1.25; 642 54.1191 23.6375 1.25
198. 643 54.1191 21.825 1.25; 644 54.1191 20.0125 1.25; 645 60.1191 23.6375 1.25
199. 646 60.1191 21.825 1.25; 647 60.1191 20.0125 1.25; 648 66.1191 23.6375 1.25
200. 649 66.1191 21.825 1.25; 650 66.1191 20.0125 1.25; 651 72.1192 23.6375 1.25
201. 652 72.1192 21.825 1.25; 653 72.1192 20.0125 1.25; 654 78.1192 23.6375 1.25
202. 655 78.1192 21.825 1.25; 656 78.1192 20.0125 1.25; 657 2.49201 20.0125 1.25
203. 658 2.49201 21.825 1.25; 659 2.49201 23.6375 1.25
204. 660 2.49201 20.0125 -0.250001; 661 2.49201 21.825 -0.250001
205. 662 2.49201 23.6375 -0.250001; 663 81.7462 20.0125 1.25
206. 664 81.7462 21.825 1.25; 665 81.7462 23.6375 1.25

207. 666 81.7462 20.0125 -0.250001; 667 81.7462 21.825 -0.250001
208. 668 81.7462 23.6375 -0.250001; 669 42.1191 30.0434 -0.250001
209. 670 42.1191 27.7467 -0.250001; 671 42.1191 30.0434 1.25
210. 672 42.1191 27.7467 1.25; 673 78.1192 30.0434 1.25; 674 78.1192 27.7467 1.25
211. 675 78.1192 30.0434 -0.250001; 676 78.1192 27.7467 -0.250001
212. 677 48.1191 30.0434 -0.250001; 678 48.1191 27.7467 -0.250001
213. 679 54.1191 30.0434 -0.250001; 680 54.1191 27.7467 -0.250001
214. 681 60.1191 30.0434 -0.250001; 682 60.1191 27.7467 -0.250001
215. 683 66.1191 30.0434 -0.250001; 684 66.1191 27.7467 -0.250001
216. 685 72.1192 30.0434 -0.250001; 686 72.1192 27.7467 -0.250001
217. 687 48.1191 30.0434 1.25; 688 48.1191 27.7467 1.25; 689 54.1191 30.0434 1.25
218. 690 54.1191 27.7467 1.25; 691 60.1191 30.0434 1.25; 692 60.1191 27.7467 1.25
219. 693 66.1191 30.0434 1.25; 694 66.1191 27.7467 1.25; 695 72.1192 30.0434 1.25
220. 696 72.1192 27.7467 1.25; 697 6.11902 27.7467 1.25; 698 6.11902 30.0434 1.25
221. 699 6.11902 30.0434 -0.250001; 700 6.11902 27.7467 -0.250001
222. 701 12.119 30.0434 -0.250001; 702 12.119 27.7467 -0.250001
223. 703 18.119 30.0434 -0.250001; 704 18.119 27.7467 -0.250001
224. 705 24.1191 30.0434 -0.250001; 706 24.1191 27.7467 -0.250001
225. 707 30.1191 30.0434 -0.250001; 708 30.1191 27.7467 -0.250001
226. 709 36.1191 30.0434 -0.250001; 710 36.1191 27.7467 -0.250001
227. 711 12.119 30.0434 1.25; 712 12.119 27.7467 1.25; 713 18.119 30.0434 1.25
228. 714 18.119 27.7467 1.25; 715 24.1191 30.0434 1.25; 716 24.1191 27.7467 1.25
229. 717 30.1191 30.0434 1.25; 718 30.1191 27.7467 1.25; 719 36.1191 30.0434 1.25
230. 720 36.1191 27.7467 1.25; 721 1.13951 25.45 -0.250001; 722 1.13951 25.45 1.25
231. 723 4.30551 25.45 -0.250001; 724 4.30551 25.45 1.25
232. 725 7.61902 25.45 -0.250001; 726 9.11901 25.45 -0.250001
233. 727 10.619 25.45 -0.250001; 728 7.61902 25.45 1.25; 729 9.11901 25.45 1.25
234. 730 10.619 25.45 1.25; 731 13.619 25.45 -0.250001; 732 13.619 25.45 1.25
235. 733 15.119 25.45 -0.250001; 734 15.119 25.45 1.25; 735 16.619 25.45 -0.250001
236. 736 16.619 25.45 1.25; 737 19.619 25.45 -0.250001; 738 19.619 25.45 1.25
237. 739 21.119 25.45 -0.250001; 740 21.119 25.45 1.25; 741 22.619 25.45 -0.250001
238. 742 22.619 25.45 1.25; 743 25.6191 25.45 -0.250001; 744 25.6191 25.45 1.25
239. 745 27.119 25.45 -0.250001; 746 27.119 25.45 1.25; 747 28.619 25.45 -0.250001
240. 748 28.619 25.45 1.25; 749 31.6191 25.45 -0.250001; 750 31.6191 25.45 1.25
241. 751 33.1191 25.45 -0.250001; 752 33.1191 25.45 1.25
242. 753 34.6191 25.45 -0.250001; 754 34.6191 25.45 1.25
243. 755 37.6191 25.45 -0.250001; 756 37.6191 25.45 1.25
244. 757 39.1191 25.45 -0.250001; 758 39.1191 25.45 1.25
245. 759 40.6191 25.45 -0.250001; 760 40.6191 25.45 1.25
246. 761 43.6191 25.45 -0.250001; 762 43.6191 25.45 1.25
247. 763 45.1191 25.45 -0.250001; 764 45.1191 25.45 1.25
248. 765 46.6191 25.45 -0.250001; 766 46.6191 25.45 1.25
249. 767 49.6191 25.45 -0.250001; 768 49.6191 25.45 1.25
250. 769 51.1191 25.45 -0.250001; 770 51.1191 25.45 1.25
251. 771 52.6191 25.45 -0.250001; 772 52.6191 25.45 1.25
252. 773 55.6191 25.45 -0.250001; 774 55.6191 25.45 1.25
253. 775 57.1191 25.45 -0.250001; 776 57.1191 25.45 1.25
254. 777 58.6191 25.45 -0.250001; 778 58.6191 25.45 1.25
255. 779 61.6191 25.45 -0.250001; 780 61.6191 25.45 1.25
256. 781 63.1191 25.45 -0.250001; 782 63.1191 25.45 1.25
257. 783 64.6191 25.45 -0.250001; 784 64.6191 25.45 1.25
258. 785 67.6191 25.45 -0.250001; 786 67.6191 25.45 1.25
259. 787 69.1191 25.45 -0.250001; 788 69.1191 25.45 1.25
260. 789 70.6191 25.45 -0.250001; 790 70.6191 25.45 1.25
261. 791 73.6193 25.45 -0.250001; 792 73.6193 25.45 1.25
262. 793 75.1192 25.45 -0.250001; 794 75.1192 25.45 1.25

263. 795 76.6192 25.45 -0.250001; 796 76.6192 25.45 1.25
264. 797 83.0832 25.45 -0.250001; 798 79.9327 25.45 -0.250001
265. 799 83.0832 25.45 1.25; 800 79.9327 25.45 1.25; 801 1.13951 16.7 -0.250001
266. 802 1.13951 16.7 1.25; 803 4.30551 16.7 -0.250001; 804 4.30551 16.7 1.25
267. 805 7.61902 16.7 -0.250001; 806 7.61902 16.7 1.25; 807 9.11901 16.7 -0.250001
268. 808 9.11901 16.7 1.25; 809 10.619 16.7 -0.250001; 810 10.619 16.7 1.25
269. 811 13.619 16.7 -0.250001; 812 13.619 16.7 1.25; 813 15.119 16.7 -0.250001
270. 814 15.119 16.7 1.25; 815 16.619 16.7 -0.250001; 816 16.619 16.7 1.25
271. 817 21.119 16.7 -0.250001; 818 21.119 16.7 1.25; 819 22.619 16.7 -0.250001
272. 820 22.619 16.7 1.25; 821 25.6191 16.7 -0.250001; 822 25.6191 16.7 1.25
273. 823 27.119 16.7 -0.250001; 824 27.119 16.7 1.25; 825 28.619 16.7 -0.250001
274. 826 28.619 16.7 1.25; 827 31.6191 16.7 -0.250001; 828 31.6191 16.7 1.25
275. 829 33.1191 16.7 -0.250001; 830 33.1191 16.7 1.25; 831 34.6191 16.7 -0.250001
276. 832 34.6191 16.7 1.25; 833 49.6191 16.7 -0.250001; 834 49.6191 16.7 1.25
277. 835 51.1191 16.7 -0.250001; 836 51.1191 16.7 1.25; 837 52.6191 16.7 -0.250001
278. 838 52.6191 16.7 1.25; 839 55.6191 16.7 -0.250001; 840 55.6191 16.7 1.25
279. 841 57.1191 16.7 -0.250001; 842 57.1191 16.7 1.25; 843 58.6191 16.7 -0.250001
280. 844 58.6191 16.7 1.25; 845 61.6191 16.7 -0.250001; 846 61.6191 16.7 1.25
281. 847 63.1191 16.7 -0.250001; 848 63.1191 16.7 1.25; 849 67.6191 16.7 -0.250001
282. 850 67.6191 16.7 1.25; 851 69.1191 16.7 -0.250001; 852 69.1191 16.7 1.25
283. 853 70.6191 16.7 -0.250001; 854 70.6191 16.7 1.25; 855 73.6193 16.7 -0.250001
284. 856 73.6193 16.7 1.25; 857 75.1192 16.7 -0.250001; 858 75.1192 16.7 1.25
285. 859 76.6192 16.7 -0.250001; 860 76.6192 16.7 1.25; 861 79.9327 16.7 -0.250001
286. 862 79.9327 16.7 1.25; 863 83.0832 16.7 -0.250001; 864 83.0832 16.7 1.25
287. 865 146.004 23.4275 -0.250001; 866 146.004 21.185 -0.250001
288. 867 146.004 19.4425 -0.250001; 868 146.004 23.4275 1.25
289. 869 146.004 21.185 1.25; 870 146.004 19.4425 1.25; 871 188.004 23.4275 1.25
290. 872 188.004 21.185 1.25; 873 188.004 19.4425 1.25
291. 874 188.004 23.4275 -0.250001; 875 188.004 21.185 -0.250001
292. 876 188.004 19.4425 -0.250001; 877 104.004 23.4275 -0.250001
293. 878 104.004 21.185 -0.250001; 879 104.004 19.4425 -0.250001
294. 880 104.004 23.4275 1.25; 881 104.004 21.185 1.25; 882 104.004 19.4425 1.25
295. 883 140.004 19.4425 -0.250001; 884 140.004 21.185 -0.250001
296. 885 140.004 23.4275 -0.250001; 886 134.004 19.4425 -0.250001
297. 887 134.004 21.185 -0.250001; 888 134.004 23.4275 -0.250001
298. 889 128.004 19.4425 -0.250001; 890 128.004 21.185 -0.250001
299. 891 128.004 23.4275 -0.250001; 892 122.004 19.4425 -0.250001
300. 893 122.004 21.185 -0.250001; 894 122.004 23.4275 -0.250001
301. 895 116.004 19.4425 -0.250001; 896 116.004 21.185 -0.250001
302. 897 116.004 23.4275 -0.250001; 898 110.004 19.4425 -0.250001
303. 899 110.004 21.185 -0.250001; 900 110.004 23.4275 -0.250001
304. 901 152.004 19.4425 -0.250001; 902 152.004 21.185 -0.250001
305. 903 152.004 23.4275 -0.250001; 904 158.004 19.4425 -0.250001
306. 905 158.004 21.185 -0.250001; 906 158.004 23.4275 -0.250001
307. 907 164.004 19.4425 -0.250001; 908 164.004 21.185 -0.250001
308. 909 164.004 23.4275 -0.250001; 910 170.004 19.4425 -0.250001
309. 911 170.004 21.185 -0.250001; 912 170.004 23.4275 -0.250001
310. 913 176.004 19.4425 -0.250001; 914 176.004 21.185 -0.250001
311. 915 176.004 23.4275 -0.250001; 916 182.004 19.4425 -0.250001
312. 917 182.004 21.185 -0.250001; 918 182.004 23.4275 -0.250001
313. 919 140.004 19.4425 1.25; 920 140.004 21.185 1.25; 921 140.004 23.4275 1.25
314. 922 134.004 19.4425 1.25; 923 134.004 21.185 1.25; 924 134.004 23.4275 1.25
315. 925 128.004 19.4425 1.25; 926 128.004 21.185 1.25; 927 128.004 23.4275 1.25
316. 928 122.004 19.4425 1.25; 929 122.004 21.185 1.25; 930 122.004 23.4275 1.25
317. 931 116.004 19.4425 1.25; 932 116.004 21.185 1.25; 933 116.004 23.4275 1.25
318. 934 110.004 19.4425 1.25; 935 110.004 21.185 1.25; 936 110.004 23.4275 1.25

319. 937 152.004 19.4425 1.25; 938 152.004 21.185 1.25; 939 152.004 23.4275 1.25
320. 940 158.004 19.4425 1.25; 941 158.004 21.185 1.25; 942 158.004 23.4275 1.25
321. 943 164.004 19.4425 1.25; 944 164.004 21.185 1.25; 945 164.004 23.4275 1.25
322. 946 170.004 19.4425 1.25; 947 170.004 21.185 1.25; 948 170.004 23.4275 1.25
323. 949 176.004 19.4425 1.25; 950 176.004 21.185 1.25; 951 176.004 23.4275 1.25
324. 952 182.004 19.4425 1.25; 953 182.004 21.185 1.25; 954 182.004 23.4275 1.25
325. 955 98.3101 16.7 -0.250001; 956 102.152 16.7 -0.250001; 957 98.3101 16.7 1.25
326. 958 102.152 16.7 1.25; 959 146.004 17.7025 -0.250001; 960 146.004 17.7025 1.25
327. 961 188.004 17.7025 -0.250001; 962 188.004 17.7025 1.25
328. 963 104.004 17.7025 -0.250001; 964 104.004 17.7025 1.25
329. 965 140.004 17.7025 -0.250001; 966 140.004 17.7025 1.25
330. 967 134.004 17.7025 -0.250001; 968 134.004 17.7025 1.25
331. 969 128.004 17.7025 -0.250001; 970 128.004 17.7025 1.25
332. 971 122.004 17.7025 -0.250001; 972 122.004 17.7025 1.25
333. 973 116.004 17.7025 -0.250001; 974 116.004 17.7025 1.25
334. 975 110.004 17.7025 -0.250001; 976 110.004 17.7025 1.25
335. 977 152.004 17.7025 -0.250001; 978 152.004 17.7025 1.25
336. 979 158.004 17.7025 -0.250001; 980 158.004 17.7025 1.25
337. 981 164.004 17.7025 -0.250001; 982 164.004 17.7025 1.25
338. 983 170.004 17.7025 -0.250001; 984 170.004 17.7025 1.25
339. 985 176.004 17.7025 -0.250001; 986 176.004 17.7025 1.25
340. 987 182.004 17.7025 -0.250001; 988 182.004 17.7025 1.25
341. 989 105.504 16.7 -0.250001; 990 107.004 16.7 -0.250001
342. 991 108.504 16.7 -0.250001; 992 105.504 16.7 1.25; 993 107.004 16.7 1.25
343. 994 108.504 16.7 1.25; 995 111.504 16.7 -0.250001; 996 111.504 16.7 1.25
344. 997 114.504 16.7 -0.250001; 998 114.504 16.7 1.25; 999 113.004 16.7 -0.250001
345. 1000 123.504 16.7 -0.250001; 1001 123.504 16.7 1.25
346. 1002 126.504 16.7 -0.250001; 1003 126.504 16.7 1.25
347. 1004 125.004 16.7 -0.250001; 1005 135.504 16.7 -0.250001
348. 1006 135.504 16.7 1.25; 1007 138.504 16.7 -0.250001; 1008 138.504 16.7 1.25
349. 1009 137.004 16.7 -0.250001; 1010 141.504 16.7 -0.250001
350. 1011 141.504 16.7 1.25; 1012 144.504 16.7 -0.250001; 1013 144.504 16.7 1.25
351. 1014 143.004 16.7 -0.250001; 1015 147.504 16.7 -0.250001
352. 1016 147.504 16.7 1.25; 1017 150.504 16.7 -0.250001; 1018 150.504 16.7 1.25
353. 1019 149.004 16.7 -0.250001; 1020 153.504 16.7 -0.250001
354. 1021 153.504 16.7 1.25; 1022 156.504 16.7 -0.250001; 1023 156.504 16.7 1.25
355. 1024 155.004 16.7 -0.250001; 1025 165.504 16.7 -0.250001
356. 1026 165.504 16.7 1.25; 1027 168.504 16.7 -0.250001; 1028 168.504 16.7 1.25
357. 1029 167.004 16.7 -0.250001; 1030 177.504 16.7 -0.250001
358. 1031 177.504 16.7 1.25; 1032 180.504 16.7 -0.250001; 1033 180.504 16.7 1.25
359. 1034 179.004 16.7 -0.250001; 1035 183.504 16.7 -0.250001
360. 1036 183.504 16.7 1.25; 1037 186.504 16.7 -0.250001; 1038 186.504 16.7 1.25
361. 1039 185.004 16.7 -0.250001; 1040 113.004 16.7 1.25; 1041 125.004 16.7 1.25
362. 1042 137.004 16.7 1.25; 1043 143.004 16.7 1.25; 1044 149.004 16.7 1.25
363. 1045 155.004 16.7 1.25; 1046 167.004 16.7 1.25; 1047 185.004 16.7 1.25
364. 1048 179.004 16.7 1.25; 1049 193.683 16.7 -0.250001
365. 1050 189.841 16.7 -0.250001; 1051 193.683 16.7 1.25; 1052 189.841 16.7 1.25
366. 1053 118.376 16.7 -0.250001; 1054 120.19 16.7 -0.250001
367. 1055 118.376 16.7 1.25; 1056 120.19 16.7 1.25; 1057 171.818 16.7 -0.250001
368. 1058 173.633 16.7 -0.250001; 1059 171.818 16.7 1.25; 1060 173.633 16.7 1.25
369. 1061 96.3202 20.685 -0.250001; 1062 96.3202 20.685 1.25
370. 1063 195.688 20.685 -0.250001; 1064 195.688 20.685 1.25
371. 1065 84.4202 28.5001 -0.250001; 1066 84.4202 21.075 -0.250001
372. 1067 84.4202 28.5001 1.25; 1068 84.4202 21.075 1.25
373. 1069 -0.213 28.5001 -0.250001; 1070 -0.213 21.075 -0.250001
374. 1071 -0.213 28.5001 1.25; 1072 -0.213 21.075 1.25

375. 1073 43.6191 32.3119 -0.250001; 1074 45.1191 32.2837 -0.250001
376. 1075 46.6191 32.2554 -0.250001; 1076 7.61902 31.6912 -0.250001
377. 1077 9.11901 31.7194 -0.250001; 1078 10.619 31.7476 -0.250001
378. 1079 13.619 31.804 -0.250001; 1080 15.119 31.8323 -0.250001
379. 1081 16.619 31.8605 -0.250001; 1082 19.619 31.9169 -0.250001
380. 1083 21.1191 31.9451 -0.250001; 1084 22.6191 31.9733 -0.250001
381. 1085 25.6191 32.0297 -0.250001; 1086 27.1191 32.0579 -0.250001
382. 1087 28.6191 32.0862 -0.250001; 1088 31.6191 32.1426 -0.250001
383. 1089 33.1191 32.1708 -0.250001; 1090 34.6191 32.199 -0.250001
384. 1091 37.6191 32.2554 -0.250001; 1092 39.1191 32.2837 -0.250001
385. 1093 40.6191 32.3119 -0.250001; 1094 49.6191 32.199 -0.250001
386. 1095 51.1191 32.1708 -0.250001; 1096 52.6191 32.1426 -0.250001
387. 1097 55.6191 32.0862 -0.250001; 1098 57.1191 32.0579 -0.250001
388. 1099 58.6191 32.0297 -0.250001; 1100 61.6191 31.9733 -0.250001
389. 1101 63.1191 31.9451 -0.250001; 1102 64.6191 31.9169 -0.250001
390. 1103 67.6191 31.8605 -0.250001; 1104 69.1192 31.8323 -0.250001
391. 1105 70.6192 31.804 -0.250001; 1106 73.6192 31.7476 -0.250001
392. 1107 75.1192 31.7194 -0.250001; 1108 76.6192 31.6912 -0.250001
393. 1109 43.6191 32.3119 1.25; 1110 45.1191 32.2837 1.25
394. 1111 46.6191 32.2554 1.25; 1112 7.61902 31.6912 1.25
395. 1113 9.11901 31.7194 1.25; 1114 10.619 31.7476 1.25; 1115 13.619 31.804 1.25
396. 1116 15.119 31.8323 1.25; 1117 16.619 31.8605 1.25; 1118 19.619 31.9169 1.25
397. 1119 21.1191 31.9451 1.25; 1120 22.6191 31.9733 1.25
398. 1121 25.6191 32.0297 1.25; 1122 27.1191 32.0579 1.25
399. 1123 28.6191 32.0862 1.25; 1124 31.6191 32.1426 1.25
400. 1125 33.1191 32.1708 1.25; 1126 34.6191 32.199 1.25; 1127 37.6191 32.2554 1.25
401. 1128 39.1191 32.2837 1.25; 1129 40.6191 32.3119 1.25; 1130 49.6191 32.199 1.25
402. 1131 51.1191 32.1708 1.25; 1132 52.6191 32.1426 1.25
403. 1133 55.6191 32.0862 1.25; 1134 57.1191 32.0579 1.25
404. 1135 58.6191 32.0297 1.25; 1136 61.6191 31.9733 1.25
405. 1137 63.1191 31.9451 1.25; 1138 64.6191 31.9169 1.25
406. 1139 67.6191 31.8605 1.25; 1140 69.1192 31.8323 1.25; 1141 70.6192 31.804 1.25
407. 1142 73.6192 31.7476 1.25; 1143 75.1192 31.7194 1.25
408. 1144 76.6192 31.6912 1.25; 1145 7.61901 31.6912 -5.12501
409. 1146 9.11901 31.7194 -5.12501; 1147 10.619 31.7476 -5.12501
410. 1148 13.619 31.804 -5.12501; 1149 15.119 31.8323 -5.12501
411. 1150 16.619 31.8605 -5.12501; 1151 19.619 31.9169 -5.12501
412. 1152 21.1191 31.9451 -5.12501; 1153 22.6191 31.9733 -5.12501
413. 1154 25.6191 32.0297 -5.12501; 1155 27.1191 32.0579 -5.12501
414. 1156 28.6191 32.0862 -5.12501; 1157 31.6191 32.1426 -5.12501
415. 1158 33.1191 32.1708 -5.12501; 1159 34.6191 32.199 -5.12501
416. 1160 37.6191 32.2554 -5.12501; 1161 39.1191 32.2837 -5.12501
417. 1162 40.6191 32.3119 -5.12501; 1163 43.6191 32.3119 -5.12501
418. 1164 45.1191 32.2837 -5.12501; 1165 46.6191 32.2554 -5.12501
419. 1166 49.6191 32.199 -5.12501; 1167 51.1191 32.1708 -5.12501
420. 1168 52.6191 32.1426 -5.12501; 1169 55.6191 32.0862 -5.12501
421. 1170 57.1191 32.0579 -5.12501; 1171 58.6191 32.0297 -5.12501
422. 1172 61.6191 31.9733 -5.12501; 1173 63.1191 31.9451 -5.12501
423. 1174 64.6191 31.9169 -5.12501; 1175 67.6191 31.8605 -5.12501
424. 1176 69.1191 31.8323 -5.12501; 1177 70.6191 31.804 -5.12501
425. 1178 73.6192 31.7476 -5.12501; 1179 75.1192 31.7194 -5.12501
426. 1180 76.6192 31.6912 -5.12501; 1181 4.30551 31.631 -0.250001
427. 1182 4.30551 31.631 1.25; 1183 4.30551 31.631 -5.12501
428. 1184 2.492 31.599 -5.12501; 1185 79.9327 31.63 -0.250001
429. 1186 79.9327 31.63 1.25; 1187 79.9327 31.63 -5.12501
430. 1188 81.7462 31.5971 -5.12501; 1189 147.504 25.6398 -0.250001

431. 1190 149.004 25.6097 -0.250001; 1191 150.504 25.5795 -0.250001
432. 1192 183.504 24.9153 -0.250001; 1193 185.004 24.8852 -0.250001
433. 1194 186.504 24.855 -0.250001; 1195 177.504 25.0361 -0.250001
434. 1196 179.004 25.0059 -0.250001; 1197 180.504 24.9757 -0.250001
435. 1198 171.504 25.1568 -0.250001; 1199 173.004 25.1266 -0.250001
436. 1200 174.504 25.0965 -0.250001; 1201 165.504 25.2776 -0.250001
437. 1202 167.004 25.2474 -0.250001; 1203 168.504 25.2172 -0.250001
438. 1204 159.504 25.3983 -0.250001; 1205 161.004 25.3681 -0.250001
439. 1206 162.504 25.338 -0.250001; 1207 153.504 25.5191 -0.250001
440. 1208 155.004 25.4889 -0.250001; 1209 156.504 25.4587 -0.250001
441. 1210 141.504 25.5795 -0.250001; 1211 143.004 25.6097 -0.250001
442. 1212 144.504 25.6398 -0.250001; 1213 135.504 25.4588 -0.250001
443. 1214 137.004 25.489 -0.250001; 1215 138.504 25.5191 -0.250001
444. 1216 129.504 25.3382 -0.250001; 1217 131.004 25.3684 -0.250001
445. 1218 132.504 25.3985 -0.250001; 1219 123.504 25.2176 -0.250001
446. 1220 125.004 25.2477 -0.250001; 1221 126.504 25.2779 -0.250001
447. 1222 117.504 25.0969 -0.250001; 1223 119.004 25.127 -0.250001
448. 1224 120.504 25.1572 -0.250001; 1225 111.504 24.9762 -0.250001
449. 1226 113.004 25.0064 -0.250001; 1227 114.504 25.0365 -0.250001
450. 1228 105.504 24.8555 -0.250001; 1229 107.004 24.8857 -0.250001
451. 1230 108.504 24.9158 -0.250001; 1231 147.504 25.6398 1.25
452. 1232 149.004 25.6097 1.25; 1233 150.504 25.5795 1.25
453. 1234 183.504 24.9153 1.25; 1235 185.004 24.8852 1.25; 1236 186.504 24.855 1.25
454. 1237 177.504 25.0361 1.25; 1238 179.004 25.0059 1.25
455. 1239 180.504 24.9757 1.25; 1240 171.504 25.1568 1.25
456. 1241 173.004 25.1266 1.25; 1242 174.504 25.0965 1.25
457. 1243 165.504 25.2776 1.25; 1244 167.004 25.2474 1.25
458. 1245 168.504 25.2172 1.25; 1246 159.504 25.3983 1.25
459. 1247 161.004 25.3681 1.25; 1248 162.504 25.338 1.25; 1249 153.504 25.5191 1.25
460. 1250 155.004 25.4889 1.25; 1251 156.504 25.4587 1.25
461. 1252 141.504 25.5795 1.25; 1253 143.004 25.6097 1.25
462. 1254 144.504 25.6398 1.25; 1255 135.504 25.4588 1.25; 1256 137.004 25.489 1.25
463. 1257 138.504 25.5191 1.25; 1258 129.504 25.3382 1.25
464. 1259 131.004 25.3684 1.25; 1260 132.504 25.3985 1.25
465. 1261 123.504 25.2176 1.25; 1262 125.004 25.2477 1.25
466. 1263 126.504 25.2779 1.25; 1264 117.504 25.0969 1.25; 1265 119.004 25.127 1.25
467. 1266 120.504 25.1572 1.25; 1267 111.504 24.9762 1.25
468. 1268 113.004 25.0064 1.25; 1269 114.504 25.0365 1.25
469. 1270 105.504 24.8555 1.25; 1271 107.004 24.8857 1.25
470. 1272 108.504 24.9158 1.25; 1273 105.504 24.8555 -5.12501
471. 1274 107.004 24.8857 -5.12501; 1275 108.504 24.9158 -5.12501
472. 1276 111.504 24.9762 -5.12501; 1277 113.004 25.0064 -5.12501
473. 1278 114.504 25.0365 -5.12501; 1279 117.504 25.0969 -5.12501
474. 1280 119.004 25.127 -5.12501; 1281 120.504 25.1572 -5.12501
475. 1282 123.504 25.2176 -5.12501; 1283 125.004 25.2477 -5.12501
476. 1284 126.504 25.2779 -5.12501; 1285 129.504 25.3382 -5.12501
477. 1286 131.004 25.3684 -5.12501; 1287 132.504 25.3985 -5.12501
478. 1288 135.504 25.4588 -5.12501; 1289 137.004 25.489 -5.12501
479. 1290 138.504 25.5191 -5.12501; 1291 141.504 25.5795 -5.12501
480. 1292 143.004 25.6097 -5.12501; 1293 144.504 25.6398 -5.12501
481. 1294 147.504 25.6398 -5.12501; 1295 149.004 25.6097 -5.12501
482. 1296 150.504 25.5795 -5.12501; 1297 153.504 25.5191 -5.12501
483. 1298 155.004 25.4889 -5.12501; 1299 156.504 25.4587 -5.12501
484. 1300 159.504 25.3983 -5.12501; 1301 161.004 25.3681 -5.12501
485. 1302 162.504 25.338 -5.12501; 1303 165.504 25.2776 -5.12501
486. 1304 167.004 25.2474 -5.12501; 1305 168.504 25.2172 -5.12501

487. 1306 171.504 25.1568 -5.12501; 1307 173.004 25.1266 -5.12501
488. 1308 174.504 25.0965 -5.12501; 1309 177.504 25.0361 -5.12501
489. 1310 179.004 25.0059 -5.12501; 1311 180.504 24.9757 -5.12501
490. 1312 183.504 24.9153 -5.12501; 1313 185.004 24.8852 -5.12501
491. 1314 186.504 24.855 -5.12501; 1315 189.504 24.7946 -0.250001
492. 1316 189.504 24.7946 1.25; 1317 191.003 24.7645 -0.250001
493. 1318 191.003 24.7645 1.25; 1319 192.507 24.7342 -0.250001
494. 1320 192.507 24.7342 1.25; 1321 194.007 24.7039 -0.250001
495. 1322 194.007 24.7039 1.25; 1323 189.504 24.7946 -5.12501
496. 1324 191.003 24.7645 -5.12501; 1325 192.507 24.7342 -5.12501
497. 1326 194.007 24.7039 -5.12501; 1327 102.504 24.7952 -0.250001
498. 1328 102.504 24.7952 1.25; 1329 101.005 24.7651 -0.250001
499. 1330 101.005 24.7651 1.25; 1331 99.5002 24.7346 -0.250001
500. 1332 99.5002 24.7346 1.25; 1333 98.0005 24.7042 -0.250001
501. 1334 98.0005 24.7042 1.25; 1335 102.504 24.7952 -5.12501
502. 1336 101.005 24.7651 -5.12501; 1337 99.5002 24.7346 -5.12501
503. 1338 98.0005 24.7042 -5.12501; 1339 100.3 16.7 0.500001
504. 1340 191.677 16.7 0.500001; 1341 140.004 16.7 0.500001
505. 1342 134.004 16.7 0.500001; 1343 122.004 16.7 0.500001
506. 1344 110.004 16.7 0.500001; 1345 104.004 16.7 0.500001
507. 1346 152.004 16.7 0.500001; 1347 158.004 16.7 0.500001
508. 1348 170.004 16.7 0.500001; 1349 182.004 16.7 0.500001
509. 1350 188.004 16.7 0.500001; 1351 116.004 16.7 0.500001
510. 1352 128.004 16.7 0.500001; 1353 164.004 16.7 0.500001
511. 1354 176.004 16.7 0.500001; 1355 102.152 16.7 0.500001
512. 1356 105.504 16.7 0.500001; 1357 107.004 16.7 0.500001
513. 1358 108.504 16.7 0.500001; 1359 111.504 16.7 0.500001
514. 1360 114.504 16.7 0.500001; 1361 123.504 16.7 0.500001
515. 1362 126.504 16.7 0.500001; 1363 135.504 16.7 0.500001
516. 1364 138.504 16.7 0.500001; 1365 141.504 16.7 0.500001
517. 1366 144.504 16.7 0.500001; 1367 147.504 16.7 0.500001
518. 1368 150.504 16.7 0.500001; 1369 153.504 16.7 0.500001
519. 1370 156.504 16.7 0.500001; 1371 165.504 16.7 0.500001
520. 1372 168.504 16.7 0.500001; 1373 177.504 16.7 0.500001
521. 1374 180.504 16.7 0.500001; 1375 183.504 16.7 0.500001
522. 1376 186.504 16.7 0.500001; 1377 113.004 16.7 0.500001
523. 1378 125.004 16.7 0.500001; 1379 137.004 16.7 0.500001
524. 1380 143.004 16.7 0.500001; 1381 149.004 16.7 0.500001
525. 1382 155.004 16.7 0.500001; 1383 167.004 16.7 0.500001
526. 1384 185.004 16.7 0.500001; 1385 179.004 16.7 0.500001
527. 1386 189.841 16.7 0.500001; 1387 118.376 16.7 0.500001
528. 1388 120.19 16.7 0.500001; 1389 173.633 16.7 0.500001
529. 1390 171.818 16.7 0.500001; 1391 85.9077 0 1.25; 1392 87.3952 0 1.25
530. 1393 88.8827 0 1.25; 1394 91.8577 0 1.25; 1395 93.3452 0 1.25
531. 1396 94.8327 0 1.25; 1397 85.9077 0 -0.250001; 1398 87.3952 0 -0.250001
532. 1399 88.8827 0 -0.250001; 1400 90.3702 0 -0.250001; 1401 91.8577 0 -0.250001
533. 1402 93.3452 0 -0.250001; 1403 94.8327 0 -0.250001; 1404 85.9077 25.3525 1.25
534. 1405 87.3952 25.255 1.25; 1406 88.8827 25.1575 1.25; 1407 94.8327 24.7675 1.25
535. 1408 93.3452 24.865 1.25; 1409 91.8577 24.9625 1.25
536. 1410 85.9077 25.3525 -0.250001; 1411 87.3952 25.255 -0.250001
537. 1412 88.8827 25.1575 -0.250001; 1413 90.3702 25.06 -0.250001
538. 1414 91.8577 24.9625 -0.250001; 1415 93.3452 24.865 -0.250001
539. 1416 94.8327 24.7675 -0.250001; 1417 85.9077 7.67702 1.25
540. 1418 85.9077 7.67702 -0.250001; 1419 87.3952 7.67702 1.25
541. 1420 87.3952 7.67702 -0.250001; 1421 88.8827 7.67702 1.25
542. 1422 88.8827 7.67702 -0.250001; 1423 90.3702 7.67702 -0.250001

543. 1424 91.8577 7.67702 1.25; 1425 91.8577 7.67702 -0.250001
544. 1426 93.3452 7.67702 1.25; 1427 93.3452 7.67702 -0.250001
545. 1428 94.8327 7.67702 1.25; 1429 94.8327 7.67702 -0.250001
546. 1430 85.9077 16.7 1.25; 1431 85.9077 16.7 -0.250001; 1432 87.3952 16.7 1.25
547. 1433 87.3952 16.7 -0.250001; 1434 88.8827 16.7 1.25
548. 1435 88.8827 16.7 -0.250001; 1436 90.3702 16.7 -0.250001
549. 1437 91.8577 16.7 1.25; 1438 91.8577 16.7 -0.250001; 1439 93.3452 16.7 1.25
550. 1440 93.3452 16.7 -0.250001; 1441 94.8327 16.7 1.25
551. 1442 94.8327 16.7 -0.250001; 1443 42.1191 25.45 0.499999
552. 1444 43.6191 25.45 0.499999; 1445 36.1191 25.45 0.499999
553. 1446 37.6191 25.45 0.499999; 1447 2.49201 16.7 0.499999
554. 1448 4.30551 16.7 0.499999; 1449 49.6191 16.7 0.499999
555. 1450 6.11902 16.7 0.499999; 1451 7.61902 16.7 0.499999
556. 1452 12.119 16.7 0.499999; 1453 13.619 16.7 0.499999
557. 1454 21.119 16.7 0.499999; 1455 24.1191 16.7 0.499999
558. 1456 25.6191 16.7 0.499999; 1457 30.1191 16.7 0.499999
559. 1458 31.6191 16.7 0.499999; 1459 54.1191 16.7 0.499999
560. 1460 55.6191 16.7 0.499999; 1461 60.1191 16.7 0.499999
561. 1462 61.6191 16.7 0.499999; 1463 66.1191 16.7 0.499999
562. 1464 72.1192 16.7 0.499999; 1465 73.6193 16.7 0.499999
563. 1466 78.1192 16.7 0.499999; 1467 79.9327 16.7 0.499999
564. 1468 18.119 16.7 0.499999; 1469 67.6191 16.7 0.499999
565. 1470 39.1191 25.45 0.499999; 1471 40.6191 25.45 0.499999
566. 1472 45.1191 25.45 0.499999; 1473 46.6191 25.45 0.499999
567. 1474 48.1191 25.45 0.499999; 1475 9.11901 16.7 0.499999
568. 1476 10.619 16.7 0.499999; 1477 15.119 16.7 0.499999
569. 1478 16.619 16.7 0.499999; 1479 22.619 16.7 0.499999
570. 1480 27.119 16.7 0.499999; 1481 28.619 16.7 0.499999
571. 1482 33.1191 16.7 0.499999; 1483 34.6191 16.7 0.499999
572. 1484 51.1191 16.7 0.499999; 1485 52.6191 16.7 0.499999
573. 1486 57.1191 16.7 0.499999; 1487 58.6191 16.7 0.499999
574. 1488 63.1191 16.7 0.499999; 1489 69.1191 16.7 0.499999
575. 1490 70.6191 16.7 0.499999; 1491 75.1192 16.7 0.499999
576. 1492 76.6192 16.7 0.499999; 1493 81.7462 16.7 0.499999
577. 1494 93.3452 10.101 1.25
578. MEMBER INCIDENCES
579. 1 1 105; 2 2 108; 3 3 111; 4 4 114; 5 5 212; 6 6 215; 7 7 218; 8 8 221
580. 16 22 1069; 19 25 1065; 20 22 721; 21 23 723; 22 24 797; 23 26 761; 24 19 669
581. 25 27 767; 26 28 773; 27 29 779; 28 30 785; 29 31 791; 30 32 798; 31 33 755
582. 32 34 749; 33 35 743; 34 36 737; 35 37 731; 36 38 725; 73 63 1070; 74 64 582
583. 75 65 584; 76 66 1066; 77 63 801; 78 64 803; 79 65 863; 81 33 585; 82 68 833
584. 83 27 588; 118 83 805; 119 38 591; 120 84 811; 121 37 594; 122 85 817
585. 123 36 597; 124 86 821; 125 35 600; 126 87 827; 127 34 603; 128 88 839
586. 129 28 606; 130 89 845; 131 29 609; 132 90 548; 133 30 612; 134 91 855
587. 135 31 615; 136 92 861; 137 32 618; 174 64 385; 175 65 295; 176 105 106
588. 177 106 107; 178 107 63; 179 108 109; 180 109 110; 181 110 64; 182 111 112
589. 183 112 113; 184 113 65; 185 114 115; 186 115 116; 187 116 66; 188 107 110
590. 189 106 109; 190 105 108; 191 113 116; 192 112 115; 193 111 114; 194 65 116
591. 195 116 112; 196 112 114; 197 114 3; 198 64 107; 199 107 109; 200 109 105
592. 201 105 2; 216 125 1319; 217 124 1331; 218 122 1061; 221 123 1063; 306 10 175
593. 307 19 1073; 308 175 1181; 309 176 1076; 310 177 1079; 311 178 1082
594. 312 179 1085; 313 180 1088; 314 181 1091; 315 23 246; 316 38 700; 317 37 702
595. 318 36 704; 319 35 706; 320 34 708; 321 33 710; 322 182 1094; 323 183 1097
596. 324 184 1100; 325 185 1103; 326 186 1106; 327 187 1185; 328 188 13; 329 27 678
597. 330 28 680; 331 29 682; 332 30 684; 333 31 686; 334 32 676; 335 24 247
598. 338 176 37; 339 177 36; 340 178 35; 341 179 34; 342 180 33; 343 181 26

599. 344 26 182; 345 27 183; 346 28 184; 347 29 185; 348 30 186; 349 31 187
600. 360 124 292; 361 125 293; 366 189 955; 368 191 1049; 433 212 213; 434 213 214
601. 435 214 189; 436 215 216; 437 216 217; 438 217 190; 439 218 219; 440 219 220
602. 441 220 191; 442 221 222; 443 222 223; 444 223 192; 445 212 215; 446 213 216
603. 447 214 217; 448 218 221; 449 219 222; 450 220 223; 508 190 214; 509 214 216
604. 510 216 212; 511 212 6; 522 22 246; 523 38 175; 524 32 188; 527 246 10
605. 528 247 13; 529 247 25; 530 246 175; 531 247 188; 533 248 1189; 534 291 1327
606. 536 190 956; 537 249 1015; 538 248 865; 539 251 1010; 541 253 1005
607. 543 255 253; 545 257 1000; 547 259 1053; 549 261 995; 551 263 989
608. 553 265 1020; 554 267 269; 555 269 554; 556 271 1057; 557 273 556
609. 558 275 1035; 559 277 1050; 567 278 1315; 568 279 1192; 569 280 1195
610. 570 281 1198; 571 282 1201; 572 283 1204; 573 284 1207; 574 285 1210
611. 575 286 1213; 576 287 1216; 577 288 1219; 578 289 1222; 579 290 1225
612. 580 291 1228; 581 285 885; 582 286 888; 583 287 891; 584 288 894; 585 289 897
613. 586 290 900; 587 291 877; 588 284 903; 589 283 906; 590 282 909; 591 281 912
614. 592 280 915; 593 279 918; 594 278 874; 595 249 285; 596 249 284; 597 265 283
615. 598 267 282; 599 554 281; 600 271 280; 601 556 279; 602 275 278; 605 251 286
616. 606 253 287; 607 551 288; 608 257 289; 609 549 290; 610 261 291; 611 263 124
617. 612 189 294; 613 277 125; 614 192 293; 617 292 122; 619 292 190; 620 293 123
618. 622 293 191; 623 192 220; 624 220 222; 625 222 218; 626 218 8; 627 294 292
619. 628 294 190; 629 295 25; 630 295 66; 646 10 307; 647 13 308; 648 19 309
620. 649 22 310; 650 25 311; 651 26 312; 652 27 313; 653 28 314; 654 29 315
621. 655 30 316; 656 31 317; 657 32 318; 658 33 319; 659 34 320; 660 35 321
622. 661 36 322; 662 37 323; 663 38 324; 664 176 325; 665 177 326; 666 178 327
623. 667 179 328; 668 180 329; 669 181 330; 670 182 331; 671 183 332; 672 184 333
624. 673 185 334; 674 186 335; 675 187 336; 676 324 83; 677 323 84; 678 322 545
625. 679 321 86; 680 320 87; 681 319 67; 682 313 68; 683 314 88; 684 315 89
626. 685 316 548; 686 317 91; 687 318 92; 688 122 337; 689 123 338; 690 248 339
627. 691 278 340; 692 279 341; 693 280 342; 694 281 343; 695 282 344; 696 283 345
628. 697 284 346; 698 285 347; 699 286 348; 700 287 349; 701 288 350; 702 289 351
629. 703 290 352; 704 291 353; 705 249 354; 706 251 355; 707 253 356; 708 551 357
630. 709 257 358; 710 549 359; 711 261 360; 712 263 361; 713 265 362; 714 267 363
631. 715 554 364; 716 271 365; 717 556 366; 718 275 367; 719 277 368; 720 23 369
632. 721 24 370; 722 189 371; 723 190 372; 724 191 373; 725 192 374; 726 222 375
633. 727 213 376; 728 63 377; 729 66 378; 730 64 377; 731 65 378; 732 216 376
634. 733 219 375; 734 23 310; 735 24 311; 748 385 22; 749 385 63; 759 10 395
635. 760 13 396; 761 19 397; 762 22 398; 763 23 399; 764 24 400; 765 25 401
636. 766 26 1443; 767 27 1474; 768 28 404; 769 29 405; 770 30 406; 771 31 407
637. 772 32 408; 773 33 1445; 774 34 410; 775 35 411; 776 36 412; 777 37 413
638. 778 38 414; 779 63 415; 780 64 1447; 781 65 1493; 782 66 418; 783 67 538
639. 784 68 539; 785 83 1450; 786 84 1452; 787 85 536; 788 86 1455; 789 87 1457
640. 790 88 1459; 791 89 1461; 792 90 537; 793 91 1464; 794 92 1466; 795 105 431
641. 796 106 432; 797 107 433; 798 108 434; 799 109 435; 800 110 436; 801 111 437
642. 802 112 438; 803 113 439; 804 114 440; 805 115 441; 806 116 442; 807 122 443
643. 808 123 444; 809 124 445; 810 125 446; 811 175 447; 812 176 448; 813 177 449
644. 814 178 450; 815 179 451; 816 180 452; 817 181 453; 818 182 454; 819 183 455
645. 820 184 456; 821 185 457; 822 186 458; 823 187 459; 824 188 460; 825 189 461
646. 826 190 1339; 827 191 1340; 828 192 464; 829 212 465; 830 213 466; 831 214 467
647. 832 215 468; 833 216 469; 834 217 470; 835 218 471; 836 219 472; 837 220 473
648. 838 221 474; 839 222 475; 840 223 476; 846 246 482; 847 247 483; 848 248 484
649. 849 249 540; 850 251 1341; 851 253 1342; 852 255 543; 853 257 1343
650. 854 259 544; 855 261 1344; 856 263 1345; 857 265 1346; 858 267 1347
651. 859 269 541; 860 271 1348; 861 273 542; 862 275 1349; 863 277 1350
652. 864 278 500; 865 279 501; 866 280 502; 867 281 503; 868 282 504; 869 283 505
653. 870 284 506; 871 285 507; 872 286 508; 873 287 509; 874 288 510; 875 289 511
654. 876 290 512; 877 291 513; 878 292 514; 879 293 515; 880 294 516; 881 295 517

655. 899 385 535; 900 386 431; 901 387 434; 902 388 437; 903 389 440; 904 390 465
656. 905 391 468; 906 392 471; 907 393 474; 908 394 480; 909 398 1071; 910 401 1067
657. 911 398 722; 912 399 724; 913 400 799; 914 402 762; 915 397 671; 916 403 768
658. 917 404 774; 918 405 780; 919 406 786; 920 407 792; 921 408 800; 922 409 756
659. 923 410 750; 924 411 744; 925 412 738; 926 413 732; 927 414 728; 928 415 1072
660. 929 416 581; 930 417 583; 931 418 1068; 932 415 802; 933 416 804; 934 417 864
661. 935 409 621; 936 420 834; 937 403 624; 938 421 806; 939 414 627; 940 422 812
662. 941 413 630; 942 423 818; 943 412 633; 944 424 822; 945 411 636; 946 425 828
663. 947 410 639; 948 426 840; 949 404 642; 950 427 846; 951 405 645; 952 428 547
664. 953 406 648; 954 429 856; 955 407 651; 956 430 862; 957 408 654; 968 416 535
665. 969 417 517; 970 431 432; 971 432 433; 972 433 415; 973 434 435; 974 435 436
666. 975 436 416; 976 437 438; 977 438 439; 978 439 417; 979 440 441; 980 441 442
667. 981 442 418; 982 433 436; 983 432 435; 984 431 434; 985 439 442; 986 438 441
668. 987 437 440; 988 417 442; 989 442 438; 990 438 440; 991 440 388; 992 416 433
669. 993 433 435; 994 435 431; 995 431 387; 996 446 1320; 997 445 1332
670. 998 443 1062; 999 444 1064; 1000 395 447; 1001 397 1109; 1002 447 1182
671. 1003 448 1112; 1004 449 1115; 1005 450 1118; 1006 451 1121; 1007 452 1124
672. 1008 453 1127; 1009 399 482; 1010 414 697; 1011 413 712; 1012 412 714
673. 1013 411 716; 1014 410 718; 1015 409 720; 1016 454 1130; 1017 455 1133
674. 1018 456 1136; 1019 457 1139; 1020 458 1142; 1021 459 1186; 1022 460 396
675. 1023 403 688; 1024 404 690; 1025 405 692; 1026 406 694; 1027 407 696
676. 1028 408 674; 1029 400 483; 1030 448 413; 1031 449 412; 1032 450 411
677. 1033 451 410; 1034 452 409; 1035 453 402; 1036 402 454; 1037 403 455
678. 1038 404 456; 1039 405 457; 1040 406 458; 1041 407 459; 1042 445 514
679. 1043 446 515; 1044 461 957; 1045 463 1051; 1046 465 466; 1047 466 467
680. 1048 467 461; 1049 468 469; 1050 469 470; 1051 470 462; 1052 471 472
681. 1053 472 473; 1054 473 463; 1055 474 475; 1056 475 476; 1057 476 464
682. 1058 465 468; 1059 466 469; 1060 467 470; 1061 471 474; 1062 472 475
683. 1063 473 476; 1064 418 1430; 1065 477 481; 1066 477 1437; 1067 467 478
684. 1068 466 1428; 1069 465 480; 1070 478 477; 1071 479 478; 1072 480 479
685. 1073 478 442; 1074 479 1421; 1075 480 440; 1076 401 1404; 1077 443 1407
686. 1078 477 442; 1079 442 479; 1080 479 440; 1081 440 394; 1082 477 467
687. 1083 467 1494; 1084 479 465; 1085 465 394; 1086 462 467; 1087 467 469
688. 1088 469 465; 1089 465 391; 1092 398 482; 1093 414 447; 1094 408 460
689. 1097 482 395; 1098 483 396; 1099 483 401; 1100 482 447; 1101 483 460
690. 1102 484 1231; 1103 513 1328; 1104 462 958; 1105 485 1016; 1106 484 868
691. 1107 486 1011; 1108 487 1006; 1109 488 487; 1110 489 1001; 1111 490 1055
692. 1112 491 996; 1113 492 992; 1114 493 1021; 1115 494 495; 1116 495 553
693. 1117 496 1059; 1118 497 555; 1119 498 1036; 1120 499 1052; 1121 500 1316
694. 1122 501 1234; 1123 502 1237; 1124 503 1240; 1125 504 1243; 1126 505 1246
695. 1127 506 1249; 1128 507 1252; 1129 508 1255; 1130 509 1258; 1131 510 1261
696. 1132 511 1264; 1133 512 1267; 1134 513 1270; 1135 507 921; 1136 508 924
697. 1137 509 927; 1138 510 930; 1139 511 933; 1140 512 936; 1141 513 880
698. 1142 506 939; 1143 505 942; 1144 504 945; 1145 503 948; 1146 502 951
699. 1147 501 954; 1148 500 871; 1149 485 507; 1150 485 506; 1151 493 505
700. 1152 494 504; 1153 553 503; 1154 496 502; 1155 555 501; 1156 498 500
701. 1157 486 508; 1158 487 509; 1159 552 510; 1160 489 511; 1161 550 512
702. 1162 491 513; 1163 492 445; 1164 461 516; 1165 499 446; 1166 464 515
703. 1167 477 518; 1168 477 519; 1169 514 443; 1171 514 462; 1172 515 444
704. 1174 515 463; 1175 464 473; 1176 473 475; 1177 475 471; 1178 471 393
705. 1179 516 514; 1180 516 462; 1181 517 401; 1182 517 418; 1183 418 519
706. 1184 481 518; 1185 518 443; 1186 519 401; 1187 519 481; 1188 518 461
707. 1189 538 520; 1190 539 521; 1191 536 522; 1192 537 523; 1193 540 524
708. 1194 543 525; 1195 544 526; 1196 541 527; 1197 542 528; 1210 535 398
709. 1211 535 415; 1212 536 423; 1213 537 428; 1214 538 419; 1215 539 420
710. 1216 540 485; 1217 541 495; 1218 542 497; 1219 543 488; 1220 544 490

711. 1221 545 85; 1223 546 423; 1224 545 1468; 1225 547 850; 1227 548 849
712. 1228 548 1463; 1229 549 259; 1231 550 490; 1232 550 1351; 1233 551 255
713. 1235 552 488; 1236 551 1352; 1237 553 1026; 1239 554 1025; 1240 554 1353
714. 1241 555 1031; 1243 556 1030; 1244 556 1354; 1245 557 421; 1246 558 83
715. 1247 559 67; 1248 560 68; 1249 561 84; 1250 562 86; 1251 563 87; 1252 564 88
716. 1253 565 89; 1254 566 91; 1255 567 92; 1256 568 419; 1257 569 420
717. 1258 570 422; 1259 571 424; 1260 572 425; 1261 573 426; 1262 574 427
718. 1263 575 429; 1264 576 430; 1265 577 545; 1266 578 546; 1267 579 547
719. 1268 580 548; 1269 558 557; 1270 561 570; 1271 577 578; 1272 562 571
720. 1273 563 572; 1274 559 568; 1275 560 569; 1276 564 573; 1277 565 574
721. 1278 580 579; 1279 566 575; 1280 567 576; 1281 581 657; 1283 582 660
722. 1284 582 581; 1285 583 663; 1287 584 666; 1288 584 583; 1289 585 586
723. 1290 586 587; 1291 587 559; 1292 588 589; 1293 589 590; 1294 590 560
724. 1295 591 592; 1296 592 593; 1297 593 558; 1298 594 595; 1299 595 596
725. 1300 596 561; 1301 597 598; 1302 598 599; 1303 599 577; 1304 600 601
726. 1305 601 602; 1306 602 562; 1307 603 604; 1308 604 605; 1309 605 563
727. 1310 606 607; 1311 607 608; 1312 608 564; 1313 609 610; 1314 610 611
728. 1315 611 565; 1316 612 613; 1317 613 614; 1318 614 580; 1319 615 616
729. 1320 616 617; 1321 617 566; 1322 618 619; 1323 619 620; 1324 620 567
730. 1325 621 622; 1326 622 623; 1327 623 568; 1328 624 625; 1329 625 626
731. 1330 626 569; 1331 627 628; 1332 628 629; 1333 629 557; 1334 630 631
732. 1335 631 632; 1336 632 570; 1337 633 634; 1338 634 635; 1339 635 578
733. 1340 636 637; 1341 637 638; 1342 638 571; 1343 639 640; 1344 640 641
734. 1345 641 572; 1346 642 643; 1347 643 644; 1348 644 573; 1349 645 646
735. 1350 646 647; 1351 647 574; 1352 648 649; 1353 649 650; 1354 650 579
736. 1355 651 652; 1356 652 653; 1357 653 575; 1358 654 655; 1359 655 656
737. 1360 656 576; 1361 657 658; 1362 658 659; 1363 659 399; 1364 660 661
738. 1365 661 662; 1366 662 23; 1367 663 664; 1368 664 665; 1369 665 400
739. 1370 666 667; 1371 667 668; 1372 668 24; 1373 558 557; 1374 559 568
740. 1375 560 569; 1376 561 570; 1377 562 571; 1378 563 572; 1379 564 573
741. 1380 565 574; 1381 566 575; 1382 567 576; 1383 577 578; 1384 580 579
742. 1385 582 581; 1386 584 583; 1387 585 621; 1388 586 622; 1389 587 623
743. 1390 588 624; 1391 589 625; 1392 590 626; 1393 591 627; 1394 592 628
744. 1395 593 629; 1396 594 630; 1397 595 631; 1398 596 632; 1399 597 633
745. 1400 598 634; 1401 599 635; 1402 600 636; 1403 601 637; 1404 602 638
746. 1405 603 639; 1406 604 640; 1407 605 641; 1408 606 642; 1409 607 643
747. 1410 608 644; 1411 609 645; 1412 610 646; 1413 611 647; 1414 612 648
748. 1415 613 649; 1416 614 650; 1417 615 651; 1418 616 652; 1419 617 653
749. 1420 618 654; 1421 619 655; 1422 620 656; 1423 660 657; 1424 661 658
750. 1425 662 659; 1426 666 663; 1427 667 664; 1428 668 665; 1429 399 662
751. 1430 662 658; 1431 658 660; 1432 660 581; 1433 414 591; 1434 591 628
752. 1435 628 593; 1436 593 557; 1437 413 594; 1438 594 631; 1439 631 596
753. 1440 596 570; 1441 412 597; 1442 597 634; 1443 634 599; 1444 599 578
754. 1445 411 600; 1446 600 637; 1447 637 602; 1448 602 571; 1449 410 603
755. 1450 603 640; 1451 640 605; 1452 605 572; 1453 409 585; 1454 585 622
756. 1455 622 587; 1456 587 568; 1457 403 588; 1458 588 625; 1459 625 590
757. 1460 590 569; 1461 404 606; 1462 606 643; 1463 643 608; 1464 608 573
758. 1465 405 609; 1466 609 646; 1467 646 611; 1468 611 574; 1469 406 612
759. 1470 612 649; 1471 649 614; 1472 614 579; 1473 407 615; 1474 615 652
760. 1475 652 617; 1476 617 575; 1477 408 618; 1478 618 655; 1479 655 620
761. 1480 620 576; 1481 400 668; 1482 668 664; 1483 664 666; 1484 666 583
762. 1485 669 670; 1486 670 26; 1487 671 672; 1488 672 402; 1489 673 459
763. 1491 674 673; 1493 675 187; 1495 676 675; 1497 677 182; 1498 678 677
764. 1499 679 183; 1500 680 679; 1501 681 184; 1502 682 681; 1503 683 185
765. 1504 684 683; 1505 685 186; 1506 686 685; 1507 687 454; 1508 688 687
766. 1509 689 455; 1510 690 689; 1511 691 456; 1512 692 691; 1513 693 457

767. 1514 694 693; 1515 695 458; 1516 696 695; 1517 669 671; 1518 670 672
768. 1519 675 673; 1520 676 674; 1521 677 687; 1522 678 688; 1523 679 689
769. 1524 680 690; 1525 681 691; 1526 682 692; 1527 683 693; 1528 684 694
770. 1529 685 695; 1530 686 696; 1531 19 671; 1532 671 670; 1533 670 402
771. 1534 687 678; 1535 678 403; 1536 689 680; 1537 680 404; 1538 691 682
772. 1539 682 405; 1540 693 684; 1541 684 406; 1542 695 686; 1543 686 407
773. 1544 673 676; 1545 676 408; 1546 182 687; 1547 183 689; 1548 184 691
774. 1549 185 693; 1550 186 695; 1551 187 673; 1552 697 698; 1554 698 448
775. 1556 699 176; 1558 700 699; 1560 701 177; 1561 702 701; 1562 703 178
776. 1563 704 703; 1564 705 179; 1565 706 705; 1566 707 180; 1567 708 707
777. 1568 709 181; 1569 710 709; 1570 711 449; 1571 712 711; 1572 713 450
778. 1573 714 713; 1574 715 451; 1575 716 715; 1576 717 452; 1577 718 717
779. 1578 719 453; 1579 720 719; 1580 700 697; 1581 699 698; 1582 701 711
780. 1583 702 712; 1584 703 713; 1585 704 714; 1586 705 715; 1587 706 716
781. 1588 707 717; 1589 708 718; 1590 709 719; 1591 710 720; 1592 719 710
782. 1593 710 409; 1594 717 708; 1595 708 410; 1596 715 706; 1597 706 411
783. 1598 713 704; 1599 704 412; 1600 711 702; 1601 702 413; 1602 698 700
784. 1603 700 414; 1604 176 698; 1605 177 711; 1606 178 713; 1607 179 715
785. 1608 180 717; 1609 181 719; 1610 721 23; 1611 722 399; 1612 721 722
786. 1613 22 722; 1614 722 23; 1615 723 38; 1616 724 414; 1617 723 724; 1618 23 724
787. 1619 724 38; 1620 725 726; 1621 726 727; 1622 727 37; 1623 728 729
788. 1624 729 730; 1625 730 413; 1626 725 728; 1627 726 729; 1628 727 730
789. 1629 38 728; 1630 728 726; 1631 726 730; 1632 730 37; 1633 731 733
790. 1634 732 734; 1635 731 732; 1636 733 735; 1637 734 736; 1638 733 734
791. 1639 735 36; 1640 736 412; 1641 735 736; 1642 37 732; 1643 732 733
792. 1644 733 736; 1645 736 36; 1646 737 739; 1647 738 740; 1648 737 738
793. 1649 739 741; 1650 740 742; 1651 739 740; 1652 741 35; 1653 742 411
794. 1654 741 742; 1655 36 738; 1656 738 739; 1657 739 742; 1658 742 35
795. 1659 743 745; 1660 744 746; 1661 743 744; 1662 745 747; 1663 746 748
796. 1664 745 746; 1665 747 34; 1666 748 410; 1667 747 748; 1668 35 744
797. 1669 744 745; 1670 745 748; 1671 748 34; 1672 749 751; 1673 750 752
798. 1674 749 750; 1675 751 753; 1676 752 754; 1677 751 752; 1678 753 33
799. 1679 754 409; 1680 753 754; 1681 34 750; 1682 750 751; 1683 751 754
800. 1684 754 33; 1685 755 757; 1686 756 758; 1687 755 1446; 1688 757 759
801. 1689 758 760; 1690 757 1470; 1691 759 26; 1692 760 402; 1693 759 1471
802. 1694 33 756; 1695 756 757; 1696 757 760; 1697 760 26; 1698 761 763
803. 1699 762 764; 1700 761 1444; 1701 763 765; 1702 764 766; 1703 763 1472
804. 1704 765 27; 1705 766 403; 1706 765 1473; 1707 26 762; 1708 762 763
805. 1709 763 766; 1710 766 27; 1711 767 769; 1712 768 770; 1713 767 768
806. 1714 769 771; 1715 770 772; 1716 769 770; 1717 771 28; 1718 772 404
807. 1719 771 772; 1720 27 768; 1721 768 769; 1722 769 772; 1723 772 28
808. 1724 773 775; 1725 774 776; 1726 773 774; 1727 775 777; 1728 776 778
809. 1729 775 776; 1730 777 29; 1731 778 405; 1732 777 778; 1733 28 774
810. 1734 774 775; 1735 775 778; 1736 778 29; 1737 779 781; 1738 780 782
811. 1739 779 780; 1740 781 783; 1741 782 784; 1742 781 782; 1743 783 30
812. 1744 784 406; 1745 783 784; 1746 29 780; 1747 780 781; 1748 781 784
813. 1749 784 30; 1750 785 787; 1751 786 788; 1752 785 786; 1753 787 789
814. 1754 788 790; 1755 787 788; 1756 789 31; 1757 790 407; 1758 789 790
815. 1759 30 786; 1760 786 787; 1761 787 790; 1762 790 31; 1763 791 793
816. 1764 792 794; 1765 791 792; 1766 793 795; 1767 794 796; 1768 793 794
817. 1769 795 32; 1770 796 408; 1771 795 796; 1772 31 792; 1773 792 793
818. 1774 793 796; 1775 796 32; 1776 797 25; 1777 798 24; 1778 799 401
819. 1779 800 400; 1780 798 800; 1781 797 799; 1782 32 800; 1783 800 24
820. 1784 24 799; 1785 799 25; 1786 801 64; 1787 802 416; 1788 801 802; 1789 63 802
821. 1790 802 64; 1791 803 83; 1792 804 421; 1793 803 1448; 1794 64 804
822. 1795 804 83; 1796 805 807; 1797 806 808; 1798 805 1451; 1799 807 809

823. 1800 808 810; 1801 807 1475; 1802 809 84; 1803 810 422; 1804 809 1476
824. 1805 83 806; 1806 806 807; 1807 807 810; 1808 810 84; 1809 811 813
825. 1810 812 814; 1811 811 1453; 1812 813 815; 1813 814 816; 1814 813 1477
826. 1815 815 545; 1816 816 546; 1817 815 1478; 1818 84 812; 1819 812 813
827. 1820 813 816; 1821 816 545; 1822 817 819; 1823 818 820; 1824 817 1454
828. 1825 819 86; 1826 820 424; 1827 819 1479; 1828 817 820; 1829 820 86
829. 1830 821 823; 1831 822 824; 1832 821 1456; 1833 823 825; 1834 824 826
830. 1835 823 1480; 1836 825 87; 1837 826 425; 1838 825 1481; 1839 86 822
831. 1840 822 823; 1841 823 826; 1842 826 87; 1843 827 829; 1844 828 830
832. 1845 827 1458; 1846 829 831; 1847 830 832; 1848 829 1482; 1849 831 67
833. 1850 832 419; 1851 831 1483; 1852 87 828; 1853 828 829; 1854 829 832
834. 1855 832 67; 1856 545 423; 1857 423 817; 1858 833 835; 1859 834 836
835. 1860 833 1449; 1861 835 837; 1862 836 838; 1863 835 1484; 1864 837 88
836. 1865 838 426; 1866 837 1485; 1867 68 834; 1868 834 835; 1869 835 838
837. 1870 838 88; 1871 839 841; 1872 840 842; 1873 839 1460; 1874 841 843
838. 1875 842 844; 1876 841 1486; 1877 843 89; 1878 844 427; 1879 843 1487
839. 1880 88 840; 1881 840 841; 1882 841 844; 1883 844 89; 1884 845 847
840. 1885 846 848; 1886 845 1462; 1887 847 90; 1888 848 428; 1889 847 1488
841. 1890 89 846; 1891 846 847; 1892 849 851; 1893 850 852; 1894 849 1469
842. 1895 851 853; 1896 852 854; 1897 851 1489; 1898 853 91; 1899 854 429
843. 1900 853 1490; 1901 548 850; 1902 850 851; 1903 851 854; 1904 854 91
844. 1905 855 857; 1906 856 858; 1907 855 1465; 1908 857 859; 1909 858 860
845. 1910 857 1491; 1911 859 92; 1912 860 430; 1913 859 1492; 1914 91 856
846. 1915 856 857; 1916 857 860; 1917 860 92; 1918 861 65; 1919 862 417
847. 1920 861 1467; 1921 863 66; 1922 864 418; 1923 863 864; 1924 92 862
848. 1925 862 65; 1926 65 864; 1927 864 66; 1928 847 428; 1929 428 548
849. 1930 460 247; 1931 247 400; 1932 447 246; 1933 246 399; 1934 865 866
850. 1935 866 867; 1936 867 959; 1937 868 869; 1938 869 870; 1939 870 960
851. 1940 871 872; 1942 872 873; 1944 873 962; 1946 874 875; 1948 875 876
852. 1950 876 961; 1952 877 878; 1954 878 879; 1956 879 963; 1958 880 881
853. 1960 881 882; 1962 882 964; 1964 883 965; 1965 884 883; 1966 885 884
854. 1967 886 967; 1968 887 886; 1969 888 887; 1970 889 969; 1971 890 889
855. 1972 891 890; 1973 892 971; 1974 893 892; 1975 894 893; 1976 895 973
856. 1977 896 895; 1978 897 896; 1979 898 975; 1980 899 898; 1981 900 899
857. 1982 901 977; 1983 902 901; 1984 903 902; 1985 904 979; 1986 905 904
858. 1987 906 905; 1988 907 981; 1989 908 907; 1990 909 908; 1991 910 983
859. 1992 911 910; 1993 912 911; 1994 913 985; 1995 914 913; 1996 915 914
860. 1997 916 987; 1998 917 916; 1999 918 917; 2000 919 966; 2001 920 919
861. 2002 921 920; 2003 922 968; 2004 923 922; 2005 924 923; 2006 925 970
862. 2007 926 925; 2008 927 926; 2009 928 972; 2010 929 928; 2011 930 929
863. 2012 931 974; 2013 932 931; 2014 933 932; 2015 934 976; 2016 935 934
864. 2017 936 935; 2018 937 978; 2019 938 937; 2020 939 938; 2021 940 980
865. 2022 941 940; 2023 942 941; 2024 943 982; 2025 944 943; 2026 945 944
866. 2027 946 984; 2028 947 946; 2029 948 947; 2030 949 986; 2031 950 949
867. 2032 951 950; 2033 952 988; 2034 953 952; 2035 954 953; 2036 865 868
868. 2037 866 869; 2038 867 870; 2039 874 871; 2040 875 872; 2041 876 873
869. 2042 877 880; 2043 878 881; 2044 879 882; 2045 883 919; 2046 884 920
870. 2047 885 921; 2048 886 922; 2049 887 923; 2050 888 924; 2051 889 925
871. 2052 890 926; 2053 891 927; 2054 892 928; 2055 893 929; 2056 894 930
872. 2057 895 931; 2058 896 932; 2059 897 933; 2060 898 934; 2061 899 935
873. 2062 900 936; 2063 901 937; 2064 902 938; 2065 903 939; 2066 904 940
874. 2067 905 941; 2068 906 942; 2069 907 943; 2070 908 944; 2071 909 945
875. 2072 910 946; 2073 911 947; 2074 912 948; 2075 913 949; 2076 914 950
876. 2077 915 951; 2078 916 952; 2079 917 953; 2080 918 954; 2082 882 878
877. 2083 878 880; 2084 880 291; 2086 934 899; 2087 899 936; 2089 931 896
878. 2090 896 933; 2092 928 893; 2093 893 930; 2095 925 890; 2096 890 927

879. 2098 922 887; 2099 887 924; 2101 919 884; 2102 884 921; 2104 870 866
880. 2105 866 868; 2107 937 902; 2108 902 939; 2110 940 905; 2111 905 942
881. 2113 943 908; 2114 908 945; 2116 946 911; 2117 911 948; 2119 949 914
882. 2120 914 951; 2122 952 917; 2123 917 954; 2125 873 875; 2126 875 871
883. 2127 936 290; 2128 933 289; 2129 930 288; 2130 927 287; 2131 924 286
884. 2132 921 285; 2133 868 248; 2134 939 284; 2135 942 283; 2136 945 282
885. 2137 948 281; 2138 951 280; 2139 954 279; 2140 871 278; 2141 125 515
886. 2142 515 191; 2143 124 514; 2144 514 190; 2145 955 190; 2146 956 263
887. 2147 957 462; 2148 958 492; 2149 955 957; 2150 956 1355; 2151 959 249
888. 2152 960 485; 2153 959 960; 2154 961 277; 2155 962 499; 2156 961 962
889. 2157 963 263; 2158 964 492; 2159 963 964; 2160 965 251; 2161 966 486
890. 2162 965 966; 2163 967 253; 2164 968 487; 2165 967 968; 2166 969 551
891. 2167 970 552; 2168 969 970; 2169 971 257; 2170 972 489; 2171 971 972
892. 2172 973 549; 2173 974 550; 2174 973 974; 2175 975 261; 2176 976 491
893. 2177 975 976; 2178 977 265; 2179 978 493; 2180 977 978; 2181 979 267
894. 2182 980 494; 2183 979 980; 2184 981 554; 2185 982 553; 2186 981 982
895. 2187 983 271; 2188 984 496; 2189 983 984; 2190 985 556; 2191 986 555
896. 2192 985 986; 2193 987 275; 2194 988 498; 2195 987 988; 2196 882 963
897. 2197 934 975; 2198 931 973; 2199 928 971; 2200 925 969; 2201 922 967
898. 2202 919 965; 2203 870 959; 2204 937 977; 2205 940 979; 2206 943 981
899. 2207 946 983; 2208 949 985; 2209 952 987; 2210 873 961; 2211 189 957
900. 2212 957 190; 2213 190 958; 2214 958 263; 2215 989 990; 2216 990 991
901. 2217 991 261; 2218 992 993; 2219 993 994; 2220 994 491; 2221 989 1356
902. 2222 990 1357; 2223 991 1358; 2224 263 992; 2225 990 992; 2226 990 994
903. 2227 994 261; 2228 995 999; 2229 996 1040; 2230 995 1359; 2231 997 549
904. 2232 998 550; 2233 997 1360; 2234 261 996; 2235 999 997; 2236 999 996
905. 2237 999 998; 2238 998 549; 2239 1000 1004; 2240 1001 1041; 2241 1000 1361
906. 2242 1002 551; 2243 1003 552; 2244 1002 1362; 2245 257 1001; 2246 1004 1002
907. 2247 1004 1001; 2248 1004 1003; 2249 1003 551; 2250 1005 1009; 2251 1006 1042
908. 2252 1005 1363; 2253 1007 251; 2254 1008 486; 2255 1007 1364; 2256 253 1006
909. 2257 1009 1007; 2258 1009 1006; 2259 1009 1008; 2260 1008 251; 2261 1010 1014
910. 2262 1011 1043; 2263 1010 1365; 2264 1012 249; 2265 1013 485; 2266 1012 1366
911. 2267 251 1011; 2268 1014 1012; 2269 1014 1011; 2270 1014 1013; 2271 1013 249
912. 2272 1015 1019; 2273 1016 1044; 2274 1015 1367; 2275 1017 265; 2276 1018 493
913. 2277 1017 1368; 2278 249 1016; 2279 1019 1017; 2280 1019 1016; 2281 1019 1018
914. 2282 1018 265; 2283 1020 1024; 2284 1021 1045; 2285 1020 1369; 2286 1022 267
915. 2287 1023 494; 2288 1022 1370; 2289 265 1021; 2290 1024 1022; 2291 1024 1021
916. 2292 1024 1023; 2293 1023 267; 2294 1025 1029; 2295 1026 1046; 2296 1025 1371
917. 2297 1027 271; 2298 1028 496; 2299 1027 1372; 2300 554 1026; 2301 1029 1027
918. 2302 1029 1026; 2303 1029 1028; 2304 1028 271; 2305 1030 1034; 2306 1031 1048
919. 2307 1030 1373; 2308 1032 275; 2309 1033 498; 2310 1032 1374; 2311 556 1031
920. 2312 1034 1032; 2313 1034 1031; 2314 1034 1033; 2315 1033 275; 2316 1035 1039
921. 2317 1036 1047; 2318 1035 1375; 2319 1037 277; 2320 1038 499; 2321 1037 1376
922. 2322 275 1036; 2323 1039 1037; 2324 1039 1036; 2325 1039 1038; 2326 1038 277
923. 2327 1040 998; 2328 999 1377; 2329 1041 1003; 2330 1004 1378; 2331 1042 1008
924. 2332 1009 1379; 2333 1043 1013; 2334 1014 1380; 2335 1044 1018; 2336 1019 1381
925. 2337 1045 1023; 2338 1024 1382; 2339 1046 1028; 2340 1029 1383; 2341 1047 1038
926. 2342 1039 1384; 2343 1048 1033; 2344 1034 1385; 2345 1049 192; 2346 1050 191
927. 2347 1051 464; 2348 1052 463; 2349 277 1052; 2350 1052 191; 2351 191 1051
928. 2352 1051 192; 2353 1051 1049; 2354 1052 1386; 2355 267 495; 2356 495 554
929. 2357 551 488; 2358 488 253; 2359 549 490; 2360 1053 1054; 2361 1054 257
930. 2362 1055 1056; 2363 1056 489; 2364 1053 1387; 2365 1054 1388; 2366 490 1053
931. 2367 1053 1056; 2368 1056 257; 2369 556 497; 2370 1057 1058; 2371 1058 273
932. 2372 1059 1060; 2373 1060 497; 2374 271 1059; 2375 1059 1058; 2376 1058 497
933. 2377 1058 1389; 2378 1057 1390; 2379 1061 189; 2380 1062 461; 2381 1061 1062
934. 2382 122 1062; 2383 1062 189; 2384 189 467; 2385 467 213; 2386 213 465

935. 2387 465 5; 2388 190 470; 2389 470 216; 2390 216 468; 2391 468 6
936. 2392 1063 192; 2393 1064 464; 2394 1063 1064; 2395 123 1064; 2396 1064 192
937. 2397 192 476; 2398 476 222; 2399 222 474; 2400 474 8; 2401 191 473
938. 2402 473 219; 2403 219 471; 2404 471 7; 2405 1065 13; 2406 1066 25
939. 2407 1067 396; 2408 1068 401; 2409 1065 1067; 2410 1066 1068; 2411 13 1067
940. 2412 1067 25; 2413 25 1068; 2414 1068 66; 2415 66 442; 2416 442 115
941. 2417 115 440; 2418 440 4; 2419 65 439; 2420 439 112; 2421 112 437; 2422 437 3
942. 2423 1069 10; 2424 1070 22; 2425 1071 395; 2426 1072 398; 2427 1069 1071
943. 2428 1070 1072; 2429 10 1071; 2430 1071 22; 2431 22 1072; 2432 1072 63
944. 2433 63 433; 2434 433 106; 2435 106 431; 2436 431 1; 2437 64 436; 2438 436 109
945. 2439 109 434; 2440 434 2; 2441 369 64; 2442 370 65; 2443 26 319; 2444 26 313
946. 2445 27 314; 2446 33 320; 2447 1073 1074; 2448 1074 1075; 2449 1075 182
947. 2450 1076 1077; 2451 1077 1078; 2452 1078 177; 2453 1079 1080; 2454 1080 1081
948. 2455 1081 178; 2456 1082 1083; 2457 1083 1084; 2458 1084 179; 2459 1085 1086
949. 2460 1086 1087; 2461 1087 180; 2462 1088 1089; 2463 1089 1090; 2464 1090 181
950. 2465 1091 1092; 2466 1092 1093; 2467 1093 19; 2468 1094 1095; 2469 1095 1096
951. 2470 1096 183; 2471 1097 1098; 2472 1098 1099; 2473 1099 184; 2474 1100 1101
952. 2475 1101 1102; 2476 1102 185; 2477 1103 1104; 2478 1104 1105; 2479 1105 186
953. 2480 1106 1107; 2481 1107 1108; 2482 1108 187; 2483 1109 1110; 2484 1110 1111
954. 2485 1111 454; 2486 1112 1113; 2487 1113 1114; 2488 1114 449; 2489 1115 1116
955. 2490 1116 1117; 2491 1117 450; 2492 1118 1119; 2493 1119 1120; 2494 1120 451
956. 2495 1121 1122; 2496 1122 1123; 2497 1123 452; 2498 1124 1125; 2499 1125 1126
957. 2500 1126 453; 2501 1127 1128; 2502 1128 1129; 2503 1129 397; 2504 1130 1131
958. 2505 1131 1132; 2506 1132 455; 2507 1133 1134; 2508 1134 1135; 2509 1135 456
959. 2510 1136 1137; 2511 1137 1138; 2512 1138 457; 2513 1139 1140; 2514 1140 1141
960. 2515 1141 458; 2516 1142 1143; 2517 1143 1144; 2518 1144 459; 2519 1076 1145
961. 2520 1076 1112; 2521 1077 1146; 2522 1077 1113; 2523 1078 1147; 2524 1078 1114
962. 2525 1079 1148; 2526 1079 1115; 2527 1080 1149; 2528 1080 1116; 2529 1081 1150
963. 2530 1081 1117; 2531 1082 1151; 2532 1082 1118; 2533 1083 1152; 2534 1083 1119
964. 2535 1084 1153; 2536 1084 1120; 2537 1085 1154; 2538 1085 1121; 2539 1086 1155
965. 2540 1086 1122; 2541 1087 1156; 2542 1087 1123; 2543 1088 1157; 2544 1088 1124
966. 2545 1089 1158; 2546 1089 1125; 2547 1090 1159; 2548 1090 1126; 2549 1091 1160
967. 2550 1091 1127; 2551 1092 1161; 2552 1092 1128; 2553 1093 1162; 2554 1093 1129
968. 2555 1073 1163; 2556 1073 1109; 2557 1074 1164; 2558 1074 1110; 2559 1075 1165
969. 2560 1075 1111; 2561 1094 1166; 2562 1094 1130; 2563 1095 1167; 2564 1095 1131
970. 2565 1096 1168; 2566 1096 1132; 2567 1097 1169; 2568 1097 1133; 2569 1098 1170
971. 2570 1098 1134; 2571 1099 1171; 2572 1099 1135; 2573 1100 1172; 2574 1100 1136
972. 2575 1101 1173; 2576 1101 1137; 2577 1102 1174; 2578 1102 1138; 2579 1103 1175
973. 2580 1103 1139; 2581 1104 1176; 2582 1104 1140; 2583 1105 1177; 2584 1105 1141
974. 2585 1106 1178; 2586 1106 1142; 2587 1107 1179; 2588 1107 1143; 2589 1108 1180
975. 2590 1108 1144; 2591 1181 176; 2592 1182 448; 2593 1181 1183; 2594 1181 1182
976. 2595 175 1184; 2596 1185 188; 2597 1186 460; 2598 1185 1187; 2599 1185 1186
977. 2600 188 1188; 2601 1189 1190; 2602 1190 1191; 2603 1191 284; 2604 1192 1193
978. 2605 1193 1194; 2606 1194 278; 2607 1195 1196; 2608 1196 1197; 2609 1197 279
979. 2610 1198 1199; 2611 1199 1200; 2612 1200 280; 2613 1201 1202; 2614 1202 1203
980. 2615 1203 281; 2616 1204 1205; 2617 1205 1206; 2618 1206 282; 2619 1207 1208
981. 2620 1208 1209; 2621 1209 283; 2622 1210 1211; 2623 1211 1212; 2624 1212 248
982. 2625 1213 1214; 2626 1214 1215; 2627 1215 285; 2628 1216 1217; 2629 1217 1218
983. 2630 1218 286; 2631 1219 1220; 2632 1220 1221; 2633 1221 287; 2634 1222 1223
984. 2635 1223 1224; 2636 1224 288; 2637 1225 1226; 2638 1226 1227; 2639 1227 289
985. 2640 1228 1229; 2641 1229 1230; 2642 1230 290; 2643 1231 1232; 2644 1232 1233
986. 2645 1233 506; 2646 1234 1235; 2647 1235 1236; 2648 1236 500; 2649 1237 1238
987. 2650 1238 1239; 2651 1239 501; 2652 1240 1241; 2653 1241 1242; 2654 1242 502
988. 2655 1243 1244; 2656 1244 1245; 2657 1245 503; 2658 1246 1247; 2659 1247 1248
989. 2660 1248 504; 2661 1249 1250; 2662 1250 1251; 2663 1251 505; 2664 1252 1253
990. 2665 1253 1254; 2666 1254 484; 2667 1255 1256; 2668 1256 1257; 2669 1257 507

991. 2670 1258 1259; 2671 1259 1260; 2672 1260 508; 2673 1261 1262; 2674 1262 1263
992. 2675 1263 509; 2676 1264 1265; 2677 1265 1266; 2678 1266 510; 2679 1267 1268
993. 2680 1268 1269; 2681 1269 511; 2682 1270 1271; 2683 1271 1272; 2684 1272 512
994. 2685 1228 1273; 2686 1228 1270; 2687 1229 1274; 2688 1229 1271; 2689 1230 1275
995. 2690 1230 1272; 2691 1225 1276; 2692 1225 1267; 2693 1226 1277; 2694 1226 1268
996. 2695 1227 1278; 2696 1227 1269; 2697 1222 1279; 2698 1222 1264; 2699 1223 1280
997. 2700 1223 1265; 2701 1224 1281; 2702 1224 1266; 2703 1219 1282; 2704 1219 1261
998. 2705 1220 1283; 2706 1220 1262; 2707 1221 1284; 2708 1221 1263; 2709 1216 1285
999. 2710 1216 1258; 2711 1217 1286; 2712 1217 1259; 2713 1218 1287; 2714 1218 1260
1000. 2715 1213 1288; 2716 1213 1255; 2717 1214 1289; 2718 1214 1256; 2719 1215 1290
1001. 2720 1215 1257; 2721 1210 1291; 2722 1210 1252; 2723 1211 1292; 2724 1211 1253
1002. 2725 1212 1293; 2726 1212 1254; 2727 1189 1294; 2728 1189 1231; 2729 1190 1295
1003. 2730 1190 1232; 2731 1191 1296; 2732 1191 1233; 2733 1207 1297; 2734 1207 1249
1004. 2735 1208 1298; 2736 1208 1250; 2737 1209 1299; 2738 1209 1251; 2739 1204 1300
1005. 2740 1204 1246; 2741 1205 1301; 2742 1205 1247; 2743 1206 1302; 2744 1206 1248
1006. 2745 1201 1303; 2746 1201 1243; 2747 1202 1304; 2748 1202 1244; 2749 1203 1305
1007. 2750 1203 1245; 2751 1198 1306; 2752 1198 1240; 2753 1199 1307; 2754 1199 1241
1008. 2755 1200 1308; 2756 1200 1242; 2757 1195 1309; 2758 1195 1237; 2759 1196 1310
1009. 2760 1196 1238; 2761 1197 1311; 2762 1197 1239; 2763 1192 1312; 2764 1192 1234
1010. 2765 1193 1313; 2766 1193 1235; 2767 1194 1314; 2768 1194 1236; 2769 1315 1317
1011. 2770 1316 1318; 2771 1317 125; 2772 1318 446; 2773 1319 1321; 2774 1320 1322
1012. 2775 1321 123; 2776 1322 444; 2777 1315 1323; 2778 1315 1316; 2779 1317 1324
1013. 2780 1317 1318; 2781 1319 1325; 2782 1319 1320; 2783 1321 1326; 2784 1321 1322
1014. 2785 1327 1329; 2786 1328 1330; 2787 1329 124; 2788 1330 445; 2789 1331 1333
1015. 2790 1332 1334; 2791 1333 122; 2792 1334 443; 2793 1327 1335; 2794 1327 1328
1016. 2795 1329 1336; 2796 1329 1330; 2797 1331 1337; 2798 1331 1332; 2799 1333 1338
1017. 2800 1333 1334; 2801 1339 462; 2802 544 1351; 2803 544 1387; 2804 543 1342
1018. 2805 540 1367; 2806 541 1353; 2807 1340 463; 2808 542 1354; 2809 1341 486
1019. 2810 1342 487; 2811 1343 489; 2812 1344 491; 2813 1345 492; 2814 1346 493
1020. 2815 1347 494; 2816 1348 496; 2817 1349 498; 2818 1350 499; 2819 1351 549
1021. 2820 1352 552; 2821 1353 553; 2822 1354 555; 2823 1355 958; 2824 1356 992
1022. 2825 1357 993; 2826 1358 994; 2827 1359 996; 2828 1360 998; 2829 1361 1001
1023. 2830 1362 1003; 2831 1363 1006; 2832 1364 1008; 2833 1365 1011; 2834 1366 1013
1024. 2835 1367 1016; 2836 1368 1018; 2837 1369 1021; 2838 1370 1023; 2839 1371 1026
1025. 2840 1372 1028; 2841 1373 1031; 2842 1374 1033; 2843 1375 1036; 2844 1376 1038
1026. 2845 1377 1040; 2846 1378 1041; 2847 1379 1042; 2848 1380 1043; 2849 1381 1044
1027. 2850 1382 1045; 2851 1383 1046; 2852 1384 1047; 2853 1385 1048; 2854 1386 1050
1028. 2855 1387 1055; 2856 1388 1056; 2857 1389 1060; 2858 1390 1059; 2859 1355 1339
1029. 2860 1345 1355; 2861 1356 1345; 2862 1357 1356; 2863 1358 1357; 2864 1344 1358
1030. 2865 1359 1344; 2866 1377 1359; 2867 1360 1377; 2868 1351 1360; 2869 1352 543
1031. 2870 1362 1352; 2871 1378 1362; 2872 1361 1378; 2873 1343 1361; 2874 1388 1343
1032. 2875 1387 1388; 2876 1366 540; 2877 1380 1366; 2878 1365 1380; 2879 1341 1365
1033. 2880 1364 1341; 2881 1379 1364; 2882 1363 1379; 2883 1342 1363; 2884 1347 541
1034. 2885 1370 1347; 2886 1382 1370; 2887 1369 1382; 2888 1346 1369; 2889 1368 1346
1035. 2890 1381 1368; 2891 1367 1381; 2892 1389 542; 2893 1390 1389; 2894 1348 1390
1036. 2895 1372 1348; 2896 1383 1372; 2897 1371 1383; 2898 1353 1371; 2899 1386 1340
1037. 2900 1350 1386; 2901 1376 1350; 2902 1384 1376; 2903 1375 1384; 2904 1349 1375
1038. 2905 1374 1349; 2906 1385 1374; 2907 1373 1385; 2908 1354 1373; 2909 389 1391
1039. 2910 394 1394; 2911 4 1397; 2912 25 1410; 2913 66 1431; 2914 1391 1392
1040. 2915 1392 1393; 2916 1393 394; 2917 1394 1395; 2918 1395 1396; 2919 1396 390
1041. 2920 1397 1398; 2921 1391 1397; 2922 1398 1399; 2923 1392 1398; 2924 1399 1400
1042. 2925 1393 1399; 2926 1400 1401; 2927 394 1400; 2928 1401 1402; 2929 1394 1401
1043. 2930 1402 1403; 2931 1395 1402; 2932 1403 5; 2933 1396 1403; 2934 1404 1405
1044. 2935 1405 1406; 2936 1406 481; 2937 1407 1408; 2938 1408 1409; 2939 1409 481
1045. 2940 1410 1411; 2941 1404 1410; 2942 1411 1412; 2943 1405 1411; 2944 1412 1413
1046. 2945 1406 1412; 2946 1413 1414; 2947 481 1413; 2948 1414 1415; 2949 1409 1414

```
1047. 2950 1415 1416; 2951 1408 1415; 2952 1416 122; 2953 1407 1416; 2954 25 1404
1048. 2955 1404 1411; 2956 1411 1406; 2957 1406 1413; 2958 1413 1409; 2959 1409 1415
1049. 2960 1415 1407; 2961 1407 122; 2962 389 1397; 2963 1397 1392; 2964 1392 1399
1050. 2965 1399 394; 2966 394 1401; 2967 1401 1395; 2968 1395 1403; 2969 1403 390
1051. 2970 115 1418; 2971 1417 441; 2972 1418 1420; 2973 1417 1418; 2974 1419 1417
1052. 2975 1420 1422; 2976 1419 1420; 2977 1421 1419; 2978 1422 1423; 2979 1421 1422
1053. 2980 1423 1425; 2981 479 1423; 2982 1424 479; 2983 1425 1427; 2984 1424 1425
1054. 2985 1426 1424; 2986 1427 1429; 2987 1426 1427; 2988 1428 1426; 2989 1429 213
1055. 2990 1428 1429; 2991 441 1418; 2992 1418 1419; 2993 1419 1422; 2994 1422 479
1056. 2995 479 1425; 2996 1425 1426; 2997 1426 1429; 2998 1429 466; 2999 1430 1432
1057. 3000 1431 1433; 3001 1430 1431; 3002 1432 1434; 3003 1433 1435; 3004 1432 1433
1058. 3005 1434 477; 3006 1435 1436; 3007 1434 1435; 3008 1436 1438; 3009 477 1436
1059. 3010 1437 1439; 3011 1438 1440; 3012 1437 1438; 3013 1439 1441; 3014 1440 1442
1060. 3015 1439 1440; 3016 1441 461; 3017 1442 189; 3018 1441 1442; 3019 418 1431
1061. 3020 1431 1432; 3021 1432 1435; 3022 1435 477; 3023 477 1438; 3024 1438 1439
1062. 3025 1439 1442; 3026 1442 461; 3027 1443 402; 3028 1444 762; 3029 1443 1444
1063. 3030 1445 409; 3031 1446 756; 3032 1445 1446; 3033 1447 416; 3034 1448 804
1064. 3035 1447 1448; 3036 1449 834; 3037 539 1449; 3038 1450 421; 3039 1451 806
1065. 3040 1450 1451; 3041 1452 422; 3042 1453 812; 3043 1452 1453; 3044 1454 818
1066. 3045 536 1454; 3046 1455 424; 3047 1456 822; 3048 1455 1456; 3049 1457 425
1067. 3050 1458 828; 3051 1457 1458; 3052 1459 426; 3053 1460 840; 3054 1459 1460
1068. 3055 1461 427; 3056 1462 846; 3057 1461 1462; 3058 1463 547; 3059 537 1463
1069. 3060 1464 429; 3061 1465 856; 3062 1464 1465; 3063 1466 430; 3064 1467 862
1070. 3065 1466 1467; 3066 1468 546; 3067 1468 536; 3068 1469 850; 3069 1463 1469
1071. 3070 1470 758; 3071 1446 1470; 3072 1471 760; 3073 1470 1471; 3074 1471 1443
1072. 3075 1472 764; 3076 1444 1472; 3077 1473 766; 3078 1472 1473; 3079 1474 403
1073. 3080 1473 1474; 3081 1448 1450; 3082 1475 808; 3083 1451 1475; 3084 1476 810
1074. 3085 1475 1476; 3086 1476 1452; 3087 1477 814; 3088 1453 1477; 3089 1478 816
1075. 3090 1477 1478; 3091 1478 1468; 3092 1479 820; 3093 1454 1479; 3094 1479 1455
1076. 3095 1480 824; 3096 1456 1480; 3097 1481 826; 3098 1480 1481; 3099 1481 1457
1077. 3100 1482 830; 3101 1458 1482; 3102 1483 832; 3103 1482 1483; 3104 1483 538
1078. 3105 1484 836; 3106 1449 1484; 3107 1485 838; 3108 1484 1485; 3109 1485 1459
1079. 3110 1486 842; 3111 1460 1486; 3112 1487 844; 3113 1486 1487; 3114 1487 1461
1080. 3115 1488 848; 3116 1462 1488; 3117 1488 537; 3118 1489 852; 3119 1469 1489
1081. 3120 1490 854; 3121 1489 1490; 3122 1490 1464; 3123 1491 858; 3124 1465 1491
1082. 3125 1492 860; 3126 1491 1492; 3127 1492 1466; 3128 1493 417; 3129 1467 1493
1083. 3130 1494 479
1084. DEFINE PMEMBER
1085. 3130 1083 PMEMBER 1
1086. START GROUP DEFINITION
1087. MEMBER
1088. _HANGERA 1 TO 4 16 19 TO 36 73 TO 79 81 TO 83 118 TO 137 174 TO 201 -
1089. 306 TO 335 338 TO 349 522 TO 524 527 TO 531 629 630 646 TO 687 720 721 728 -
1090. 729 TO 731 734 735 748 749 759 TO 806 811 TO 824 846 847 881 899 TO 903 909 -
1091. 910 TO 957 968 TO 995 1000 TO 1041 1092 TO 1094 1097 TO 1101 1181 1182 1189 -
1092. 1190 TO 1192 1210 TO 1215 1221 1223 TO 1225 1227 1228 1245 TO 1281 -
1093. 1283 TO 1285 1287 TO 1489 1491 1493 1495 1497 TO 1552 1554 1556 1558 1560 -
1094. 1561 TO 1933 2405 TO 2442 2447 TO 2600 3027 TO 3129
1095. _LACEINGA 759 TO 806 811 TO 824 846 847 881 899 1212 TO 1215 1224 1228 1269 -
1096. 1270 TO 1280 1284 1288 1373 TO 1484 1517 TO 1551 1580 TO 1609 1612 TO 1614 -
1097. 1617 TO 1619 1626 TO 1632 1635 1638 1641 TO 1645 1648 1651 1654 TO 1658 1661 -
1098. 1664 1667 TO 1671 1674 1677 1680 TO 1684 1687 1690 1693 TO 1697 1700 1703 -
1099. 1706 TO 1710 1713 1716 1719 TO 1723 1726 1729 1732 TO 1736 1739 1742 1745 -
1100. 1746 TO 1749 1752 1755 1758 TO 1762 1765 1768 1771 TO 1775 1780 TO 1785 1788 -
1101. 1789 TO 1790 1793 TO 1795 1798 1801 1804 TO 1808 1811 1814 1817 TO 1821 1824 -
1102. 1827 TO 1829 1832 1835 1838 TO 1842 1845 1848 1851 TO 1857 1860 1863 1866 -
```

```
1103. 1867 TO 1870 1873 1876 1879 TO 1883 1886 1889 TO 1891 1894 1897 1900 TO 1904 -
1104. 1907 1910 1913 TO 1917 1920 1923 TO 1933 2409 TO 2422 2427 TO 2440 2520 2522 -
1105. 2524 2526 2528 2530 2532 2534 2536 2538 2540 2542 2544 2546 2548 2550 2552 -
1106. 2554 2556 2558 2560 2562 2564 2566 2568 2570 2572 2574 2576 2578 2580 2582 -
1107. 2584 2586 2588 2590 2594 2599 3027 3028 3030 3031 3033 3034 3036 3038 3039 -
1108. 3041 3042 3044 3046 3047 3049 3050 3052 3053 3055 3056 3058 3060 3061 3063 -
1109. 3064 3066 3068 3070 3072 3075 3077 3079 3082 3084 3087 3089 3092 3095 3097 -
1110. 3100 3102 3105 3107 3110 3112 3115 3118 3120 3123 3125 3128
1111. _MAINFRAMEA 1 TO 4 16 19 TO 36 73 TO 79 81 TO 83 118 TO 137 174 TO 201 306 -
1112. 307 TO 335 338 TO 349 522 TO 524 527 TO 531 629 630 646 TO 687 720 721 728 -
1113. 729 TO 731 734 735 748 749 900 TO 903 909 TO 957 968 TO 995 1000 TO 1041 1092 -
1114. 1093 TO 1094 1097 TO 1101 1181 1182 1189 TO 1192 1210 1211 1221 1223 1225 -
1115. 1227 1245 TO 1268 1281 1283 1285 1287 1289 TO 1372 1485 TO 1489 1491 1493 -
1116. 1495 1497 TO 1516 1552 1554 1556 1558 1560 TO 1579 1610 1611 1615 1616 1620 -
1117. 1621 TO 1625 1633 1634 1636 1637 1639 1640 1646 1647 1649 1650 1652 1653 1659 -
1118. 1660 1662 1663 1665 1666 1672 1673 1675 1676 1678 1679 1685 1686 1688 1689 -
1119. 1691 1692 1698 1699 1701 1702 1704 1705 1711 1712 1714 1715 1717 1718 1724 -
1120. 1725 1727 1728 1730 1731 1737 1738 1740 1741 1743 1744 1750 1751 1753 1754 -
1121. 1756 1757 1763 1764 1766 1767 1769 1770 1776 TO 1779 1786 1787 1791 1792 -
1122. 1796 1797 1799 1800 1802 1803 1809 1810 1812 1813 1815 1816 1822 1823 1825 -
1123. 1826 1830 1831 1833 1834 1836 1837 1843 1844 1846 1847 1849 1850 1858 1859 -
1124. 1861 1862 1864 1865 1871 1872 1874 1875 1877 1878 1884 1885 1887 1888 1892 -
1125. 1893 1895 1896 1898 1899 1905 1906 1908 1909 1911 1912 1918 1919 1921 1922 -
1126. 2405 TO 2408 2423 TO 2426 2441 2442 2447 TO 2519 2521 2523 2525 2527 2529 -
1127. 2531 2533 2535 2537 2539 2541 2543 2545 2547 2549 2551 2553 2555 2557 2559 -
1128. 2561 2563 2565 2567 2569 2571 2573 2575 2577
1129. _MAINFRAMEA 2579 2581 2583 2585 2587 2589 2591 TO 2593 2595 TO 2598 2600 3029 -
1130. 3032 3035 3037 3040 3043 3045 3048 3051 3054 3057 3059 3062 3065 3067 3069 -
1131. 3071 3073 3074 3076 3078 3080 3081 3083 3085 3086 3088 3090 3091 3093 3094 -
1132. 3096 3098 3099 3101 3103 3104 3106 3108 3109 3111 3113 3114 3116 3117 3119 -
1133. 3121 3122 3124 3126 3127 3129
1134. _HANGERB 5 TO 8 216 TO 218 221 360 361 366 368 433 TO 450 508 TO 511 533 534 -
1135. 536 TO 539 541 543 545 547 549 551 553 TO 559 567 TO 602 605 TO 614 617 619 -
1136. 620 622 TO 628 688 TO 719 722 TO 727 732 733 807 TO 810 825 TO 840 -
1137. 848 TO 880 904 TO 907 996 TO 999 1042 TO 1063 1086 TO 1089 1102 TO 1166 1169 -
1138. 1171 1172 1174 TO 1180 1193 TO 1197 1216 TO 1220 1229 1231 TO 1233 -
1139. 1235 TO 1237 1239 TO 1241 1243 1244 1934 TO 1940 1942 1944 1946 1948 1950 -
1140. 1952 1954 1956 1958 1960 1962 1964 TO 2080 2082 TO 2084 2086 2087 2089 2090 -
1141. 2092 2093 2095 2096 2098 2099 2101 2102 2104 2105 2107 2108 2110 2111 2113 -
1142. 2114 2116 2117 2119 2120 2122 2123 2125 TO 2404 2601 TO 2801 2807 -
1143. 2809 TO 2858
1144. _LACEINGB 807 TO 810 825 TO 840 848 TO 880 1193 TO 1197 1232 1236 1240 1244 -
1145. 2036 TO 2080 2082 TO 2084 2086 2087 2089 2090 2092 2093 2095 2096 2098 2099 -
1146. 2101 2102 2104 2105 2107 2108 2110 2111 2113 2114 2116 2117 2119 2120 2122 -
1147. 2123 2125 TO 2144 2149 2150 2153 2156 2159 2162 2165 2168 2171 2174 2177 -
1148. 2180 2183 2186 2189 2192 2195 TO 2214 2221 TO 2227 2230 2233 2234 -
1149. 2236 TO 2238 2241 2244 2245 2247 TO 2249 2252 2255 2256 2258 TO 2260 2263 -
1150. 2266 2267 2269 TO 2271 2274 2277 2278 2280 TO 2282 2285 2288 2289 -
1151. 2291 TO 2293 2296 2299 2300 2302 TO 2304 2307 2310 2311 2313 TO 2315 2318 -
1152. 2321 2322 2324 TO 2326 2328 2330 2332 2334 2336 2338 2340 2342 2344 2349 -
1153. 2350 TO 2359 2364 TO 2369 2374 TO 2378 2381 TO 2391 2394 TO 2404 2686 2688 -
1154. 2690 2692 2694 2696 2698 2700 2702 2704 2706 2708 2710 2712 2714 2716 2718 -
1155. 2720 2722 2724 2726 2728 2730 2732 2734 2736 2738 2740 2742 2744 2746 2748 -
1156. 2750 2752 2754 2756 2758 2760 2762 2764 2766 2768 2778 2780 2782 2784 2794 -
1157. 2796 2798 2800 2801 2807 2809 TO 2858
1158. _MAINFRAMEB 5 TO 8 216 TO 218 221 360 361 366 368 433 TO 450 508 TO 511 533 -
```

```
1159. 534 536 TO 539 541 543 545 547 549 551 553 TO 559 567 TO 602 605 TO 614 617 -
1160. 619 620 622 TO 628 904 TO 907 996 TO 999 1042 TO 1063 1086 TO 1089 -
1161. 1102 TO 1166 1169 1171 1172 1174 TO 1180 1216 TO 1220 1229 1231 1233 1235 -
1162. 1237 1239 1241 1243 1934 TO 1940 1942 1944 1946 1948 1950 1952 1954 1956 -
1163. 1958 1960 1962 1964 TO 2035 2145 TO 2148 2151 2152 2154 2155 2157 2158 2160 -
1164. 2161 2163 2164 2166 2167 2169 2170 2172 2173 2175 2176 2178 2179 2181 2182 -
1165. 2184 2185 2187 2188 2190 2191 2193 2194 2215 TO 2220 2228 2229 2231 2232 -
1166. 2235 2239 2240 2242 2243 2246 2250 2251 2253 2254 2257 2261 2262 2264 2265 -
1167. 2268 2272 2273 2275 2276 2279 2283 2284 2286 2287 2290 2294 2295 2297 2298 -
1168. 2301 2305 2306 2308 2309 2312 2316 2317 2319 2320 2323 2327 2329 2331 2333 -
1169. 2335 2337 2339 2341 2343 2345 TO 2348 2360 TO 2363 2370 TO 2373 2379 2380 -
1170. 2392 2393 2601 TO 2684 2769 TO 2776 2785 TO 2792
1171. _150X4FALIED 20 22 27 28 34 35 316 334 509 587 594 597 598 611 TO 614 617 -
1172. 623 627 648 666 667 672 673 711 718 725 779 TO 781 785 786 793 794 911 917 -
1173. 918 TO 919 924 TO 926 1010 1028 1106 1135 1136 1141 TO 1144 1148 1151 1152 -
1174. 1157 1164 TO 1166 1169 1178 1179 1407 1452 1463 1489 1491 1493 1495 1552 -
1175. 1554 1556 1558 1588 1589 1610 1611 1633 1634 1636 1637 1639 1640 1646 1647 -
1176. 1649 1650 1652 1653 1660 1663 1666 1725 1728 1731 1737 1738 1740 1741 1743 -
1177. 1744 1750 1751 1753 1754 1756 1757 1776 1915 1937 TO 1940 1942 1944 1946 -
1178. 1948 1950 1952 1954 1956 1958 1960 1962 2000 TO 2005 2018 TO 2026 2154 2155 -
1179. 2157 2158 2161 2164 2179 2182 2185 2384 2389 2391 2397 2401 2416 TO 2421 -
1180. 2437 TO 2439 3033 3038 3041 3060 3063 3128
1181. END GROUP DEFINITION
1182. DEFINE MATERIAL START
1183. ISOTROPIC STEEL
1184. E 1.99947E+08
1185. POISSON 0.3
1186. DENSITY 76.8191
1187. ALPHA 6.5E-06
1188. DAMP 0.03
1189. TYPE STEEL
1190. STRENGTH RY 1.5 RT 1.2
1191. END DEFINE MATERIAL
1192. MEMBER PROPERTY APLAPOLLOTUBES
1193. 175 629 630 651 705 849 852 854 859 861 969 1181 1182 1216 TO 1219 -
1194. 1220 TABLE ST 250X250X10.0SHS
1195. 1 TO 4 8 16 19 73 TO 76 176 TO 193 216 TO 218 221 315 317 335 339 360 361 -
1196. 366 368 435 442 TO 444 508 530 531 534 539 541 545 547 549 556 TO 559 567 -
1197. 568 TO 570 577 TO 580 600 606 613 614 623 662 709 711 716 718 725 727 749 -
1198. 768 774 779 TO 781 785 786 793 794 900 901 903 907 909 910 928 TO 931 970 -
1199. 971 TO 972 975 978 TO 987 996 998 999 1007 1017 1018 1034 1037 1039 1042 1043 -
1200. 1045 1048 1055 TO 1057 1080 1081 1083 1085 1105 1107 TO 1112 1114 TO 1123 -
1201. 1131 TO 1134 1153 1157 1163 1165 TO 1168 1176 1178 1183 1185 TO 1187 1211 -
1202. 1229 1231 1235 1237 1239 1241 1243 1267 1268 1273 1276 1281 1283 1285 1287 -
1203. 1352 1361 TO 1372 1378 1379 1407 1452 1463 1464 1536 TO 1538 1547 1588 1589 -
1204. 1594 TO 1596 2012 TO 2014 2033 TO 2035 2405 TO 2408 2484 2494 2497 2501 2506 -
1205. 3130 TABLE ST 150X150X5.0SHS
1206. 2173 2194 3033 3038 3041 3060 3063 3128 TABLE ST 150X150X5.0SHS
1207. 2379 2380 2385 2388 2389 2392 2393 2401 2402 TABLE ST 150X150X5.0SHS
1208. 2145 2228 2229 2231 2232 2235 2239 2240 2242 2243 2246 2250 2251 2253 2254 -
1209. 2257 2261 2262 2264 2265 2268 2273 2276 2284 2287 2294 2295 2297 2298 2301 -
1210. 2305 2306 2308 2309 2312 2316 2317 2319 2320 2323 2327 2329 2331 2333 2335 -
1211. 2337 2339 2341 2343 2345 TO 2348 2360 TO 2363 2370 TO 2373 2604 TO 2612 2631 -
1212. 2632 TO 2642 2646 TO 2651 2673 TO 2684 2769 TO 2776 2785 2787 2789 -
1213. 2791 TABLE ST 150X150X5.0SHS
1214. 1789 1790 1794 1795 1915 1924 TO 1927 2383 2415 TO 2426 2437 TO 2440 2443 -
```

```
1215. 2444 TO 2446 TABLE ST 150X150X5.0SHS
1216. MEMBER PROPERTY INDIAN
1217. 1193 TO 1197 TABLE ST ISMB300
1218. MEMBER PROPERTY APLAPOLLOTUBES
1219. 338 653 659 681 682 708 710 717 767 773 783 784 825 1156 1214 1215 -
1220. 1453 TO 1460 1534 1535 1546 1592 1593 1609 2442 3030 -
1221. 3079 TABLE ST 220X220X8.0SHS
1222. 1274 1275 1374 1375 TABLE ST 250X250X8.0SHS
1223. MEMBER PROPERTY INDIAN
1224. 81 83 321 329 652 658 935 937 1015 1023 1247 1248 1256 1257 1289 TO 1294 1325 -
1225. 1326 TO 1330 1497 1498 1507 1508 1568 1569 1578 -
1226. 1579 TABLE ST TUBE TH 0.016 WT 0.25 DT 0.25
1227. MEMBER PROPERTY INDIAN
1228. 174 748 968 1210 TABLE ST TUBE TH 0.024 WT 0.25 DT 0.25
1229. MEMBER PROPERTY APLAPOLLOTUBES
1230. 125 127 129 131 319 320 331 437 622 654 660 661 676 680 683 687 715 730 731 -
1231. 787 792 908 945 947 949 951 997 1013 1014 1024 1025 1031 1050 1051 1053 1065 -
1232. 1070 TO 1072 1103 1171 1174 1212 1213 1251 1259 TO 1262 1304 1340 TO 1351 -
1233. 1509 TO 1512 1574 TO 1577 2441 2786 2788 2790 2792 TABLE ST 180X180X8.0SHS
1234. 449 510 511 611 612 625 627 650 770 776 836 1069 1075 TO 1077 1087 TO 1089 -
1235. 1164 1177 1179 1441 TO 1447 1597 TO 1599 1601 1606 1607 1613 1614 1618 1619 -
1236. 1784 1785 2386 2387 2390 2397 2398 2403 2913 2934 TO 2939 3000 3003 3006 -
1237. 3008 3011 3014 3017 TABLE ST 100X100X6.0SHS
1238. 6 7 330 436 438 TO 440 601 602 609 610 619 655 677 TO 679 684 TO 686 706 713 -
1239. 722 733 905 906 1030 1032 1040 1041 1049 1052 1154 1155 1189 TO 1192 1250 -
1240. 1252 1253 TABLE ST 180X180X6.0SHS
1241. 628 762 TO 764 795 TO 798 800 TO 804 806 826 TO 829 831 832 834 835 837 838 -
1242. 840 846 847 850 851 853 855 TO 858 860 862 863 878 TO 881 899 1180 1232 1236 -
1243. 1240 1244 1269 TO 1272 1277 TO 1280 1284 1288 1373 1376 1377 1380 TO 1406 -
1244. 1408 TO 1428 1481 TO 1484 1517 TO 1530 1580 TO 1587 1590 1591 1612 1617 1626 -
1245. 1627 TO 1628 1635 1638 1641 1648 1651 1654 1656 TO 1658 1661 1664 -
1246. 1667 TO 1671 1674 1677 1680 TO 1684 1687 1690 1693 TO 1697 1700 1703 1706 -
1247. 1707 TO 1710 1713 1716 1719 TO 1723 1726 1729 1732 TO 1736 1739 1742 1745 -
1248. 1746 TO 1749 1752 1755 1758 1759 1765 1768 1771 1780 1781 1788 1793 1798 1801 -
1249. 1804 1811 1814 1817 1824 1827 1832 1835 1838 TO 1842 1845 1848 1851 TO 1855 -
1250. 1860 1863 1866 TO 1870 1873 1876 1879 TO 1883 1886 1889 1894 1897 1900 1907 -
1251. 1910 1913 1920 1923 2036 TO 2080 2082 2086 2087 2089 2090 2092 2093 2095 -
1252. 2096 2098 2099 2101 2102 2104 2105 2107 2108 2110 2111 2113 2114 2116 2117 -
1253. 2119 2120 2122 2123 2125 2126 2149 2150 2153 2156 2159 2162 2165 2168 2171 -
1254. 2174 2177 2180 2183 2186 2189 2192 2195 2213 2221 TO 2227 2230 2233 2236 -
1255. 2237 TO 2238 2241 2244 2245 2247 TO 2249 2252 2255 2256 2258 TO 2260 2263 -
1256. 2266 2267 2269 TO 2271 2274 2277 2278 2280 TO 2282 2285 2288 2289 -
1257. 2291 TO 2293 2296 2299 2300 2302 TO 2304 2307 2310 2311 2313 TO 2315 2409 -
1258. 2410 2427 2428 2801 2807 2809 TO 2842 3028 3031 3034 -
1259. 3036  TABLE ST 50X50X3.6SHS
1260. 3039 3042 3044 3047 3050 3053 3056 3061 3064 3068 3070 3072 3075 3077 3082 -
1261. 3084 3087 3089 3092 3095 3097 3100 3102 3105 3107 3110 3112 3115 3118 3120 -
1262. 3123 3125 TABLE ST 50X50X3.6SHS
1263. 445 TO 448 450 766 772 778 839 1058 TO 1063 1477 TO 1480 1544 1545 1551 1629 -
1264. 1630 TO 1632 1642 TO 1645 1655 1760 TO 1762 1772 TO 1775 1806 1808 -
1265. 1818 TO 1821 1828 1891 1901 TO 1904 1914 1916 2083 2211 2234 2318 2321 2322 -
1266. 2324 TO 2326 2328 2330 2332 2334 2336 2338 2340 2342 2344 2349 TO 2354 2364 -
1267. 2365 TO 2369 2374 TO 2378 2381 2394 TO 2396 2399 2400 2843 TO 2858 2921 2923 -
1268. 2925 2927 2929 2931 2933 2941 2943 2945 2947 2949 2951 2953 TO 2969 2973 -
1269. 2976 2979 2981 2984 2987 2990 TO 2998 3001 3004 3007 3009 3012 3015 3018 -
1270. 3019 TO 3027 TABLE ST 72X72X3.2SHS
```

```
1271. 5 77 TO 79 123 314 318 433 434 533 536 554 555 571 TO 576 620 624 656 707 -
1272. 714 720 723 724 728 729 732 734 735 782 788 TO 791 809 810 902 904 -
1273. 932 TO 934 973 974 976 977 1008 1009 1016 1029 1046 1047 1086 1100 TO 1102 -
1274. 1104 1124 TO 1130 1140 1172 1184 1224 1228 1786 1787 1918 1919 1921 1922 -
1275. 2015 TO 2017 2130 TO 2136 2146 2148 2160 2172 2176 2178 2184 2355 TO 2358 -
1276. 2449 2485 2500 2601 TO 2603 2613 TO 2630 2643 TO 2645 2652 TO 2672 3046 3049 -
1277. 3052 3055 3058 3066 TABLE ST 150X150X8.0SHS
1278. 765 771 777 799 830 833 1064 1066 1068 1074 1429 TO 1440 1473 TO 1476 1543 -
1279. 1602 TO 1605 1782 1783 1805 1807 1829 1890 1917 1930 TO 1933 2084 -
1280. 2127 TO 2129 2137 TO 2141 2196 TO 2202 2204 TO 2210 2212 2214 2359 2411 2412 -
1281. 2429 2430 2909 TO 2912 2914 TO 2920 2922 2924 2926 2928 2930 2932 2940 2942 -
1282. 2944 2946 2948 2950 2952 2970 TO 2972 2974 2975 2977 2978 2980 2982 2983 -
1283. 2985 2986 2988 2989 2999 3002 3005 3010 3013 3016 TABLE ST 72X72X5.0SHS
1284. 194 TO 201 509 522 TO 524 527 TO 529 626 649 657 663 712 719 721 726 769 775 -
1285. 805 988 TO 995 1078 1079 1082 1084 1092 TO 1094 1097 TO 1099 1169 1175 1448 -
1286. 1449 TO 1451 1461 1462 1465 TO 1472 1531 TO 1533 1539 TO 1542 1548 TO 1550 -
1287. 1600 1608 1856 1857 1928 1929 2142 TO 2144 2203 2382 2384 2391 2404 2413 -
1288. 2414 2431 TO 2436 TABLE ST 120X120X6.0SHS
1289. MEMBER PROPERTY TATASTRUCTURA
1290. 646 TO 648 664 TO 675 688 TO 704 759 TO 761 807 808 811 TO 824 848 -
1291. 864 TO 877 2519 TO 2590 2593 TO 2595 2598 TO 2600 2685 TO 2768 2777 TO 2784 -
1292. 2793 TO 2800 TABLE ST 96X48X4.8RHS
1293. MEMBER PROPERTY APLAPOLLOTUBES
1294. 133 322 332 333 348 349 537 543 551 553 598 608 617 943 953 1044 1113 1152 -
1295. 1158 1188 1233 1265 1266 1337 TO 1339 1354 2147 2215 TO 2220 2272 2275 2279 -
1296. 2283 2286 2290 2464 2499 2504 TABLE ST 150X150X6.0SHS
1297. 441 1054 TABLE ST 180X180X10.0SHS
1298. 607 1159 TO 1162 TABLE ST 220X220X6.0SHS
1299. 119 121 135 137 306 TO 313 316 323 TO 328 334 538 581 TO 594 939 941 955 957 -
1300. 1000 TO 1006 1010 TO 1012 1019 TO 1022 1026 TO 1028 1067 1073 1106 -
1301. 1135 TO 1139 1141 TO 1148 1245 1246 1249 1254 1255 1258 1263 1264 -
1302. 1295 TO 1303 1316 TO 1324 1331 TO 1336 1353 1355 TO 1360 1489 1491 1493 1495 -
1303. 1503 TO 1506 1513 TO 1516 1552 1554 1556 1558 1560 TO 1563 1570 TO 1573 1934 -
1304. 1935 TO 1940 1942 1944 1946 1948 1950 1952 1954 1956 1958 1960 1962 -
1305. 1964 TO 2011 2018 TO 2032 2151 2152 2154 2155 2157 2158 2161 2163 2164 2166 -
1306. 2167 2169 2170 2175 2179 2181 2182 2185 2187 2188 2190 2191 2193 2447 2448 -
1307. 2450 TO 2463 2465 TO 2483 2486 TO 2493 2495 2496 2498 2502 2503 2505 2507 -
1308. 2508 TO 2518 2591 2592 2596 2597 TABLE ST 150X150X4.5SHS
1309. 595 TO 597 599 605 1149 TO 1151 TABLE ST 175X175X5.0SHS
1310. MEMBER PROPERTY INDIAN
1311. 2802 TO 2806 2808 2859 TO 2908 3029 3032 3035 3037 3040 3043 3045 3048 3051 -
1312. 3054 3057 3059 3062 3065 3067 3069 3071 3073 3074 3076 3078 3080 3081 3083 -
1313. 3085 3086 3088 3090 3091 3093 3094 3096 3098 3099 3101 3103 3104 3106 3108 -
1314. 3109 3111 3113 3114 3116 3117 3119 3121 3122 3124 3126 3127 -
1315. 3129 TABLE FR ISMC150 SP 0.13
1316. MEMBER PROPERTY APLAPOLLOTUBES
1317. 24 915 1305 TO 1315 1485 TO 1488 1499 TO 1502 1564 TO 1566 -
1318. 1567 TABLE ST 180X180X5.0SHS
1319. 20 TO 23 25 TO 36 82 118 120 122 124 126 128 130 132 134 136 340 TO 347 911 -
1320. 912 TO 914 916 TO 927 936 938 940 942 944 946 948 950 952 954 956 1033 1035 -
1321. 1036 1038 1221 1223 1225 1227 1610 1611 1615 1616 1620 TO 1625 1633 1634 -
1322. 1636 1637 1639 1640 1646 1647 1649 1650 1652 1653 1659 1660 1662 1663 1665 -
1323. 1666 1672 1673 1675 1676 1678 1679 1685 1686 1688 1689 1691 1692 1698 1699 -
1324. 1701 1702 1704 1705 1711 1712 1714 1715 1717 1718 1724 1725 1727 1728 1730 -
1325. 1731 1737 1738 1740 1741 1743 1744 1750 1751 1753 1754 1756 1757 1763 1764 -
1326. 1766 1767 1769 1770 1776 TO 1779 1791 1792 1796 1797 1799 1800 1802 1803 -
```

```
1327. 1809 1810 1812 1813 1815 1816 1822 1823 1825 1826 1830 1831 1833 1834 1836 -
1328. 1837 1843 1844 1846 1847 1849 1850 1858 1859 1861 1862 1864 1865 1871 1872 -
1329. 1874 1875 1877 1878 1884 1885 1887 1888 1892 1893 1895 1896 1898 1899 1905 -
1330. 1906 1908 1909 1911 1912 TABLE ST 140X140X5.0SHS
1331. CONSTANTS
1332. MATERIAL STEEL ALL
1333. SUPPORTS
1334. 1 TO 8 386 TO 393 FIXED
1335. 520 TO 528 FIXED BUT FY MX MY MZ
1336. 307 TO 378 1145 TO 1180 1183 1184 1187 1188 1273 TO 1314 1323 TO 1326 1335 -
1337. 1336 TO 1338 PINNED
1338. MEMBER RELEASE
1339. 1189 TO 1197 START MY MZ
1340. LOAD 1 LOADTYPE DEAD  TITLE DL
 **WARNING- MEMBERS    1373 &    1269 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1274 &    1374 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1275 &    1375 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1376 &    1270 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1377 &    1272 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1378 &    1273 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1379 &    1276 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1277 &    1380 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1381 &    1279 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1280 &    1382 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1271 &    1383 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1384 &    1278 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1284 &    1385 ARE BETWEEN THE SAME JOINTS.
 **WARNING- MEMBERS    1288 &    1386 ARE BETWEEN THE SAME JOINTS.
1341. SELFWEIGHT Y -1 LIST 1 TO 8 16 19 TO 36 73 TO 79 81 TO 83 118 TO 137 -
1342. 174 TO 201 216 TO 218 221 306 TO 335 338 TO 349 360 361 366 368 433 TO 450 -
1343. 508 TO 511 522 TO 524 527 TO 531 533 534 536 TO 539 541 543 545 547 549 551 -
1344. 553 TO 559 567 TO 602 605 TO 614 617 619 620 622 TO 630 646 TO 735 -
1345. 2447 TO 2482 2519 2521 2523 2525 2527 2529 2531 2533 2535 2537 2539 2541 -
1346. 2543 2545 2547 2549 2551 2553 2555 2557 2559 2561 2563 2565 2567 2569 2571 -
1347. 2573 2575 2577 2579 2581 2583 2585 2587 2589 2591 2593 2595 2596 2598 2600
1348. **DEAD LOAD OF ROOF SHEETING
1349. MEMBER LOAD
1350. 216 217 306 TO 314 322 TO 328 533 534 567 TO 580 996 997 1000 TO 1008 1016 -
1351. 1017 TO 1022 1076 1077 1102 1103 1121 TO 1134 2447 TO 2518 2591 2592 2596 -
1352. 2597 2601 TO 2684 2769 TO 2776 2785 TO 2792 2934 TO 2939 UNI GY -0.4875
1353. LOAD 2 LOADTYPE LIVE  TITLE LL
1354. **LIVE LOAD OF ROOF SHEETING
1355. MEMBER LOAD
1356. 216 217 306 TO 314 322 TO 328 533 534 567 TO 580 996 997 1000 TO 1008 1016 -
1357. 1017 TO 1022 1076 1077 1102 1103 1121 TO 1134 2447 TO 2518 2591 2592 2596 -
1358. 2597 2601 TO 2684 2769 TO 2776 2785 TO 2792 2934 TO 2939 UNI GY -1.825
1359. LOAD 3 LOADTYPE NONE  TITLE DOOR CLOSED
1360. *HANGER 84M DOOR CLOSED LOAD START
1361. JOINT LOAD
1362. 416 417 1447 1493 FY -0.3
1363. MEMBER LOAD
1364. 3124 CON GY -2.3 1.49995
1365. 3111 CON GY -2.3 1.49999
1366. 3098 CON GY -2.3 5.27101E-05
1367. 3083 CON GY -2.3 1.5
1368. JOINT LOAD
```

```
1369. 536 537 FY -25.5
1370. 1445 1474 FY -35.2
1371. 1443 FY -3.3
1372. MEMBER LOAD
1373. 3096 CON GY -3 0.500048
1374. 3083 CON GY -3 0.500005
1375. 3126 CON GY -3 0.99996
1376. 3113 CON GY -3 0.999991
1377. ****DISTRIBUTION LOAD 84M DOOR(CLOSED)
1378. 3029 3032 3071 3073 3074 3076 3078 3080 UNI GY -3.775
1379. 3037 3045 3048 3051 3054 3057 3093 3094 3096 3098 3099 3101 3103 3104 3106 -
1380. 3108 3109 3111 3113 3114 3116 3117 UNI GY -1.85
1381. 3035 3040 3043 3059 3062 3065 3067 3069 3081 3083 3085 3086 3088 3090 3091 -
1382. 3119 3121 3122 3124 3126 3127 3129 UNI GY -2.13
1383. *HANGER 84M DOOR CLOSED LOAD END
1384. *HANGER 99M DOOR CLOSED LOAD START
1385. JOINT LOAD
1386. 1339 1340 FY -0.3
1387. MEMBER LOAD
1388. 2902 CON GY -2.3 3.72071E-05
1389. 2887 CON GY -2.3 1.5
1390. 2881 CON GY -2.3 4.34083E-05
1391. 2863 CON GY -2.3 1.5
1392. JOINT LOAD
1393. 1343 1348 FY -2.3
1394. MEMBER LOAD
1395. 2882 CON GY -3 0.500033
1396. 2862 CON GY -3 0.500002
1397. 2902 CON GY -3 1.00004
1398. 1110 2894 CON GY -3 1
1399. JOINT LOAD
1400. 540 TO 544 FY -26
1401. ***DISTRIBUTED LOAD 99M DOOR (CLOSED)
1402. MEMBER LOAD
1403. 2802 TO 2806 2808 2859 TO 2908 UNI GY -2.15
1404. *HANGER 99M DOOR CLOSED LOAD END
1405. LOAD 4 LOADTYPE NONE  TITLE DOOR OPEN
1406. *HANGER 84M DOOR OPEN LOAD START
1407. JOINT LOAD
1408. 536 TO 539 1447 1493 FY -20.4
1409. MEMBER LOAD
1410. 3096 CON GY -14.7 0.500048
1411. 3083 CON GY -14.7 0.500005
1412. 3126 CON GY -14.7 0.99996
1413. 3113 CON GY -14.7 0.999991
1414. JOINT LOAD
1415. 1443 FY -3.3
1416. 1445 1474 FY -23
1417. 1445 FX 28
1418. 1474 FX -28
1419. 539 1447 FX 20.4
1420. 538 1493 FX -20.4
1421. ***DISTRIBUTED LOAD 84M DOOR(OPEN)
1422. MEMBER LOAD
1423. 3035 3040 3043 3059 3062 3065 3067 3069 3081 3083 3085 3086 3088 3090 3091 -
1424. 3119 3121 3122 3124 3126 3127 3129 UNI GY -0.07
```

```
1425. 3037 3045 3048 3051 3054 3057 3093 3094 3096 3098 3099 3101 3103 3104 3106 -
1426. 3108 3109 3111 3113 3114 3116 3117 UNI GY -0.061
1427. 3029 3032 3071 3073 3074 3076 3078 3080 UNI GY -0.091
1428. *HANGER 84M DOOR OPEN LOAD END
1429. *HANGER 99M DOOR OPEN LOAD START
1430. JOINT LOAD
1431. 1339 1340 FY -20.2
1432. 1343 1348 FY -2.3
1433. MEMBER LOAD
1434. 2902 CON GY -2.3 3.72071E-05
1435. 2887 CON GY -2.3 1.5
1436. 2881 CON GY -2.3 4.34083E-05
1437. 2863 CON GY -2.3 1.5
1438. 2882 CON GY -15.1 0.500033
1439. 2862 CON GY -15.1 0.500002
1440. 2902 CON GY -15.1 1.00004
1441. 2874 CON GY -15.1 1.372
1442. 2894 CON GY -15.1 1
1443. JOINT LOAD
1444. 540 TO 544 FY -13.2
1445. 1339 FX 20.2
1446. 1340 FX -20.2
1447. ***DISTRIBUTION LOAD (OPEN)
1448. MEMBER LOAD
1449. 2802 TO 2806 2808 2859 TO 2908 UNI GY -0.07
1450. *HANGER 99M DOOR OPEN LOAD END
1451. LOAD 5 LOADTYPE NONE  TITLE TESTING LOAD
1452. *HANGER 84M DOOR TESTING LOAD START
1453. JOINT LOAD
1454. 536 537 FY -60
1455. 538 539 FY -75
1456. *HANGER 84M DOOR TESTING LOAD END
1457. *HANGER 99M DOOR TESTING LOAD START
1458. 540 TO 544 FY -60
1459. *HANGER 99M DOOR TESTING LOAD END
1460. LOAD 6 LOADTYPE NONE  TITLE WL+XP
1461. ***84M HANGER DOOR CLADING WIND LOAD START
1462. MEMBER LOAD
1463. 1189 1190 UNI GZ 20.23
1464. 935 937 1256 1257 1325 TO 1330 UNI GZ 12.4
1465. 1191 1192 UNI GZ 22.93
1466. 901 902 973 TO 978 UNI GZ 12.81
1467. 900 909 910 928 970 TO 972 2407 2425 2426 UNI GZ 2.02
1468. 915 941 943 945 947 949 951 953 955 1011 TO 1015 1023 TO 1027 1258 TO 1263 -
1469. 1266 1267 1334 TO 1357 1487 1488 1507 TO 1516 1570 TO 1579 UNI GZ 8.09
1470. 939 957 1010 1028 1245 1264 1331 TO 1333 1358 TO 1360 1489 1491 1552 -
1471. 1554 UNI GZ 6.47
1472. 929 930 1009 1029 1100 1101 1281 1285 1361 TO 1363 1367 TO 1369 UNI GZ 4.18
1473. 903 931 979 TO 981 2408 UNI GZ 5.8
1474. ***84M HANGER DOOR CLADING WIND LOAD END
1475. ***99M HANGER DOOR CLADING WIND LOAD START
1476. 1193 TO 1197 UNI GZ 20.23
1477. 905 906 1049 TO 1054 UNI GZ 13.49
1478. 1106 1135 TO 1140 1142 TO 1147 1937 TO 1939 2000 TO 2035 2152 2161 2164 2167 -
1479. 2170 2173 2176 2179 2182 2185 2188 2191 2194 UNI GZ 8.1
1480. 1141 1148 1940 1942 1944 1958 1960 1962 2155 2158 UNI GZ 6.47
```

```
1481. 1042 1043 1171 1174 UNI GZ 5.26
1482. 907 999 1055 TO 1057 2393 UNI GZ 2.7
1483. 904 998 1046 TO 1048 2380 UNI GZ 10.8
1484. ***99M HANGER DOOR CLADING WIND LOAD END
1485. ***INTERMEDIATE WIND COLUMN LOAD START
1486. 908 1065 1070 TO 1072 UNI GZ 8.1
1487. ***INTERMEDIATE WIND COLUMN LOAD END
1488. ***84M HANGER DOOR ROOF WIND LOAD START
1489. 306 308 TO 314 1000 1002 TO 1008 2450 TO 2467 2486 TO 2503 2591 -
1490. 2592 UNI GY 2.25
1491. 307 322 TO 328 1001 1016 TO 1022 2447 TO 2449 2468 TO 2485 2504 TO 2518 2596 -
1492. 2597 UNI GY 1.44
1493. ***84M HANGER DOOR ROOF WIND LOAD END
1494. ***99M HANGER DOOR ROOF WIND LOAD START
1495. 217 534 574 TO 580 997 1103 1128 TO 1134 2622 TO 2642 2664 TO 2684 -
1496. 2785 TO 2792 UNI GY 2.24
1497. 216 533 567 TO 573 996 1102 1121 TO 1127 2601 TO 2621 2643 TO 2663 -
1498. 2769 TO 2776 UNI GY 1.44
1499. ***99M HANGER DOOR ROOF WIND LOAD END
1500. LOAD 7 LOADTYPE NONE  TITLE WL+XS
1501. MEMBER LOAD
1502. 306 308 TO 314 1000 1002 TO 1008 2450 TO 2467 2486 TO 2503 2591 -
1503. 2592 UNI GY 0.64
1504. 307 322 TO 328 1001 1016 TO 1022 2447 TO 2449 2468 TO 2485 2504 TO 2518 2596 -
1505. 2597 UNI GY -0.16
1506. 217 534 574 TO 580 997 1103 1128 TO 1134 2622 TO 2642 2664 TO 2684 -
1507. 2785 TO 2792 UNI GY 0.64
1508. 216 533 567 TO 573 996 1102 1121 TO 1127 2601 TO 2621 2643 TO 2663 -
1509. 2769 TO 2776 UNI GY -0.16
1510. ***84M HANGER DOOR ROOF WIND LOAD START
1511. ***84M HANGER DOOR ROOF WIND LOAD END
1512. ***99M HANGER DOOR ROOF WIND LOAD START
1513. ***99M HANGER DOOR ROOF WIND LOAD END
1514. LOAD 8 LOADTYPE NONE  TITLE WL-XP
1515. ***84M HANGER DOOR CLADING WIND LOAD START
1516. MEMBER LOAD
1517. 1189 1190 UNI GZ 20.23
1518. 935 937 1256 1257 1325 TO 1330 UNI GZ 12.4
1519. 1191 1192 UNI GZ 22.93
1520. 901 902 973 TO 978 UNI GZ 12.81
1521. 900 909 910 928 970 TO 972 2407 2425 2426 UNI GZ 2.02
1522. 915 941 943 945 947 949 951 953 955 1011 TO 1015 1023 TO 1027 1258 TO 1263 -
1523. 1266 1267 1334 TO 1357 1487 1488 1507 TO 1516 1570 TO 1579 UNI GZ 8.09
1524. 939 957 1010 1028 1245 1264 1331 TO 1333 1358 TO 1360 1489 1491 1552 -
1525. 1554 UNI GZ 6.47
1526. 929 930 1009 1029 1100 1101 1281 1285 1361 TO 1363 1367 TO 1369 UNI GZ 4.18
1527. 903 931 979 TO 981 2408 UNI GZ 5.8
1528. ***84M HANGER DOOR CLADING WIND LOAD END
1529. ***99M HANGER DOOR CLADING WIND LOAD START
1530. 1193 TO 1197 UNI GZ 20.23
1531. 905 906 1049 TO 1054 UNI GZ 13.49
1532. 1106 1135 TO 1140 1142 TO 1147 1937 TO 1939 2000 TO 2035 2152 2161 2164 2167 -
1533. 2170 2173 2176 2179 2182 2185 2188 2191 2194 UNI GZ 8.1
1534. 1141 1148 1940 1942 1944 1958 1960 1962 2155 2158 UNI GZ 6.47
1535. 1042 1043 1171 1174 UNI GZ 5.26
1536. 907 999 1055 TO 1057 2393 UNI GZ 2.7
```

```
1537. 904 998 1046 TO 1048 2380 UNI GZ 10.8
1538. ***99M HANGER DOOR CLADING WIND LOAD END
1539. ***INTERMEDIATE WIND COLUMN LOAD START
1540. 908 1065 1070 TO 1072 UNI GZ 8.1
1541. ***INTERMEDIATE WIND COLUMN LOAD END
1542. ***84M HANGER DOOR ROOF WIND LOAD START
1543. 306 308 TO 314 1000 1002 TO 1008 2450 TO 2467 2486 TO 2503 2591 -
1544. 2592 UNI GY 1.44
1545. 307 322 TO 328 1001 1016 TO 1022 2447 TO 2449 2468 TO 2485 2504 TO 2518 2596 -
1546. 2597 UNI GY 2.25
1547. ***84M HANGER DOOR ROOF WIND LOAD END
1548. ***99M HANGER DOOR ROOF WIND LOAD START
1549. 217 534 574 TO 580 997 1103 1128 TO 1134 2622 TO 2642 2664 TO 2684 -
1550. 2785 TO 2792 UNI GY 1.44
1551. 216 533 567 TO 573 996 1102 1121 TO 1127 2601 TO 2621 2643 TO 2663 -
1552. 2769 TO 2776 UNI GY 2.25
1553. ***99M HANGER DOOR ROOF WIND LOAD END
1554. LOAD 9 LOADTYPE NONE  TITLE WL-XS
1555. MEMBER LOAD
1556. ***84M HANGER DOOR ROOF WIND LOAD START
1557. 306 308 TO 314 1000 1002 TO 1008 2450 TO 2467 2486 TO 2503 2591 -
1558. 2592 UNI GY -0.16
1559. 307 322 TO 328 1001 1016 TO 1022 2447 TO 2449 2468 TO 2485 2504 TO 2518 2596 -
1560. 2597 UNI GY 0.64
1561. ***84M HANGER DOOR ROOF WIND LOAD END
1562. ***99M HANGER DOOR ROOF WIND LOAD START
1563. 217 534 574 TO 580 997 1103 1128 TO 1134 2622 TO 2642 2664 TO 2684 -
1564. 2785 TO 2792 UNI GY -0.16
1565. 216 533 567 TO 573 996 1102 1121 TO 1127 2601 TO 2621 2643 TO 2663 -
1566. 2769 TO 2776 UNI GY 0.64
1567. ***99M HANGER DOOR ROOF WIND LOAD END
1568. LOAD 10 LOADTYPE NONE  TITLE WL+ZP
1569. ***84M HANGER DOOR CLADING WIND LOAD START
1570. MEMBER LOAD
1571. 1189 1190 UNI GZ 14.16
1572. 935 937 1256 1257 1325 TO 1330 UNI GZ 8.5
1573. 1191 1192 UNI GZ 16.05
1574. 901 902 973 TO 978 UNI GZ 8.7
1575. 900 909 910 928 970 TO 972 2407 2425 2426 UNI GZ 1.42
1576. 915 941 943 945 947 949 951 953 955 1011 TO 1015 1023 TO 1027 1258 TO 1263 -
1577. 1266 1267 1334 TO 1357 1487 1488 1507 TO 1516 1570 TO 1579 UNI GZ 5.67
1578. 939 957 1010 1028 1245 1264 1331 TO 1333 1358 TO 1360 1489 1491 1552 -
1579. 1554 UNI GZ 4.53
1580. 929 930 1009 1029 1100 1101 1281 1285 1361 TO 1363 1367 TO 1369 UNI GZ 2.93
1581. 903 931 979 TO 981 2408 UNI GZ 6.89
1582. ***84M HANGER DOOR CLADING WIND LOAD END
1583. ***99M HANGER DOOR CLADING WIND LOAD START
1584. 1193 TO 1197 UNI GZ 14.16
1585. 905 906 1049 TO 1054 UNI GZ 9.44
1586. 1106 1135 TO 1140 1142 TO 1147 1937 TO 1939 2000 TO 2035 2152 2161 2164 2167 -
1587. 2170 2173 2176 2179 2182 2185 2188 2191 2194 UNI GZ 5.67
1588. 1141 1148 1940 1942 1944 1958 1960 1962 2155 2158 UNI GZ 4.53
1589. 1042 1043 1171 1174 UNI GZ 3.68
1590. 907 999 1055 TO 1057 2393 UNI GZ 1.89
1591. 904 998 1046 TO 1048 2380 UNI GZ 7.55
1592. ***99M HANGER DOOR CLADING WIND LOAD END
```

```
1593. ***INTERMEDIATE WIND COLUMN LOAD START
1594. 908 1065 1070 TO 1072 UNI GZ 5.67
1595. ***INTERMEDIATE WIND COLUMN LOAD END
1596. ***84M HANGER DOOR ROOF WIND LOAD START
1597. 306 TO 314 322 TO 328 1000 TO 1008 1016 TO 1022 2447 TO 2518 2591 2592 2596 -
1598. 2597 UNI GY 1.44
1599. ***84M HANGER DOOR ROOF WIND LOAD END
1600. ***99M HANGER DOOR ROOF WIND LOAD START
1601. 216 217 533 534 567 TO 580 996 997 1102 1103 1121 TO 1134 2601 TO 2684 2769 -
1602. 2770 TO 2776 2785 TO 2792 UNI GY 1.44
1603. ***99M HANGER DOOR ROOF WIND LOAD END
1604. LOAD 11 LOADTYPE NONE  TITLE WL+ZS
1605. ***84M HANGER DOOR CLADING WIND LOAD START
1606. MEMBER LOAD
1607. 1189 1190 UNI GZ -6.07
1608. 935 937 1256 1257 1325 TO 1330 UNI GZ -3.64
1609. 1191 1192 UNI GZ -6.88
1610. 901 902 973 TO 978 UNI GZ -3.84
1611. 900 909 910 928 970 TO 972 2407 2425 2426 UNI GZ -0.61
1612. 915 941 943 945 947 949 951 953 955 1011 TO 1015 1023 TO 1027 1258 TO 1263 -
1613. 1266 1267 1334 TO 1357 1487 1488 1507 TO 1516 1570 TO 1579 UNI GZ -2.43
1614. 939 957 1010 1028 1245 1264 1331 TO 1333 1358 TO 1360 1489 1491 1552 -
1615. 1554 UNI GZ -1.94
1616. 929 930 1009 1029 1100 1101 1281 1285 1361 TO 1363 1367 TO 1369 UNI GZ -1.25
1617. 903 931 979 TO 981 2408 UNI GZ -2.95
1618. ***84M HANGER DOOR CLADING WIND LOAD END
1619. ***99M HANGER DOOR CLADING WIND LOAD START
1620. 1193 TO 1197 UNI GZ -6.07
1621. 905 906 1049 TO 1054 UNI GZ -4.05
1622. 1106 1135 TO 1140 1142 TO 1147 1937 TO 1939 2000 TO 2035 2152 2161 2164 2167 -
1623. 2170 2173 2176 2179 2182 2185 2188 2191 2194 UNI GZ -2.43
1624. 1141 1148 1940 1942 1944 1958 1960 1962 2155 2158 UNI GZ -1.94
1625. 1042 1043 1171 1174 UNI GZ -1.58
1626. 907 999 1055 TO 1057 2393 UNI GZ -0.81
1627. 904 998 1046 TO 1048 2380 UNI GZ -3.24
1628. ***99M HANGER DOOR CLADING WIND LOAD END
1629. ***INTERMEDIATE WIND COLUMN LOAD START
1630. 908 1065 1070 TO 1072 UNI GZ -2.43
1631. ***INTERMEDIATE WIND COLUMN LOAD END
1632. ***84M HANGER DOOR ROOF WIND LOAD START
1633. 306 TO 314 322 TO 328 1000 TO 1008 1016 TO 1022 2447 TO 2518 2591 2592 2596 -
1634. 2597 UNI GY -0.16
1635. ***84M HANGER DOOR ROOF WIND LOAD END
1636. ***99M HANGER DOOR ROOF WIND LOAD START
1637. 216 217 533 534 567 TO 580 996 997 1102 1103 1121 TO 1134 2601 TO 2684 2769 -
1638. 2770 TO 2776 2785 TO 2792 UNI GY -0.16
1639. ***99M HANGER DOOR ROOF WIND LOAD END
1640. LOAD 12 LOADTYPE NONE  TITLE WL-ZP
1641. ***84M HANGER DOOR CLADING WIND LOAD START
1642. MEMBER LOAD
1643. 1189 1190 UNI GZ -4.05
1644. 935 937 1256 1257 1325 TO 1330 UNI GZ -2.43
1645. 1191 1192 UNI GZ -4.59
1646. 901 902 973 TO 978 UNI GZ -2.56
1647. 900 909 910 928 970 TO 972 2407 2425 2426 UNI GZ -0.4
1648. 915 941 943 945 947 949 951 953 955 1011 TO 1015 1023 TO 1027 1258 TO 1263 -
```

```
1649. 1266 1267 1334 TO 1357 1487 1488 1507 TO 1516 1570 TO 1579 UNI GZ -1.62
1650. 939 957 1010 1028 1245 1264 1331 TO 1333 1358 TO 1360 1489 1491 1552 -
1651. 1554 UNI GZ -1.29
1652. 929 930 1009 1029 1100 1101 1281 1285 1361 TO 1363 1367 TO 1369 UNI GZ -0.84
1653. 903 931 979 TO 981 2408 UNI GZ -1.97
1654. ***84M HANGER DOOR CLADING WIND LOAD END
1655. ***99M HANGER DOOR CLADING WIND LOAD START
1656. 1194 1196 UNI GZ -4.05
1657. 905 906 1049 TO 1054 UNI GZ -2.7
1658. 1106 1135 TO 1140 1142 TO 1147 1937 TO 1939 2000 TO 2035 2152 2161 2164 2167 -
1659. 2170 2173 2176 2179 2182 2185 2188 2191 2194 UNI GZ -1.62
1660. 1141 1148 1940 1942 1944 1958 1960 1962 2155 2158 UNI GZ -1.29
1661. 1042 1043 1171 1174 UNI GZ -1.05
1662. 907 999 1055 TO 1057 2393 UNI GZ -0.54
1663. 904 998 1046 TO 1048 2380 UNI GZ -2.16
1664. ***99M HANGER DOOR CLADING WIND LOAD END
1665. ***INTERMEDIATE WIND COLUMN LOAD START
1666. 908 1065 1070 TO 1072 UNI GZ -1.62
1667. ***INTERMEDIATE WIND COLUMN LOAD END
1668. ***84M HANGER DOOR ROOF WIND LOAD START
1669. 306 TO 314 322 TO 328 1000 TO 1008 1016 TO 1022 2447 TO 2518 2591 2592 2596 -
1670. 2597 UNI GY 2.08
1671. ***84M HANGER DOOR ROOF WIND LOAD END
1672. ***99M HANGER DOOR ROOF WIND LOAD START
1673. 216 217 533 534 567 TO 580 996 997 1102 1103 1121 TO 1134 2601 TO 2684 2769 -
1674. 2770 TO 2776 2785 TO 2792 UNI GY 2.08
1675. ***99M HANGER DOOR ROOF WIND LOAD END
1676. LOAD 13 LOADTYPE NONE  TITLE WL-ZS
1677. ***84M HANGER DOOR CLADING WIND LOAD START
1678. MEMBER LOAD
1679. 1189 1190 UNI GZ -24.28
1680. 935 937 1256 1257 1325 TO 1330 UNI GZ -14.57
1681. 1191 1192 UNI GZ -27.52
1682. 901 902 973 TO 978 UNI GZ -15.38
1683. 900 909 910 928 970 TO 972 2407 2425 2426 UNI GZ -2.43
1684. 915 941 943 945 947 949 951 953 955 1011 TO 1015 1023 TO 1027 1258 TO 1263 -
1685. 1266 1267 1334 TO 1357 1487 1488 1507 TO 1516 1570 TO 1579 UNI GZ -9.71
1686. 939 957 1010 1028 1245 1264 1331 TO 1333 1358 TO 1360 1489 1491 1552 -
1687. 1554 UNI GZ -7.77
1688. 929 930 1009 1029 1100 1101 1281 1285 1361 TO 1363 1367 TO 1369 UNI GZ -5.02
1689. 903 931 979 TO 981 2408 UNI GZ -11.82
1690. ***84M HANGER DOOR CLADING WIND LOAD END
1691. ***99M HANGER DOOR CLADING WIND LOAD START
1692. 1193 TO 1197 UNI GZ -24.28
1693. 538 581 TO 586 588 TO 593 1106 1135 TO 1140 1142 TO 1147 1934 TO 1939 1964 -
1694. 1965 TO 2035 2151 2152 2160 2161 2163 2164 2166 2167 2169 2170 2172 2173 2175 -
1695. 2176 2178 2179 2181 2182 2184 2185 2187 2188 2190 2191 2193 -
1696. 2194 UNI GZ -9.71
1697. 587 594 1141 1148 1940 1942 1944 1946 1948 1950 1952 1954 1956 1958 1960 1962 -
1698. 2154 2155 2157 2158 UNI GZ -7.77
1699. 360 361 619 622 1042 1043 1171 1174 UNI GZ -6.31
1700. 8 221 442 TO 444 907 999 1055 TO 1057 2392 2393 UNI GZ -3.24
1701. 5 218 433 TO 435 904 998 1046 TO 1048 2379 2380 UNI GZ -12.95
1702. ***99M HANGER DOOR CLADING WIND LOAD END
1703. ***INTERMEDIATE WIND COLUMN LOAD START
1704. 908 1065 1070 TO 1072 UNI GZ -9.71
```

```
1705. ***INTERMEDIATE WIND COLUMN LOAD END
1706. ***84M HANGER DOOR ROOF WIND LOAD START
1707. 306 TO 314 322 TO 328 1000 TO 1008 1016 TO 1022 2447 TO 2518 2591 2592 2596 -
1708. 2597 UNI GY 0.96
1709. ***84M HANGER DOOR ROOF WIND LOAD END
1710. ***99M HANGER DOOR ROOF WIND LOAD START
1711. 216 217 533 534 567 TO 580 996 997 1102 1103 1121 TO 1134 2601 TO 2684 2769 -
1712. 2770 TO 2776 2785 TO 2792 UNI GY 0.96
1713. 6 7 436 TO 441 905 906 1049 TO 1054 UNI GZ -16.19
1714. ***99M HANGER DOOR ROOF WIND LOAD END
1715. LOAD COMB 101 1.5(DL+LL+DOOR OPEN)
1716. 1 1.5 2 1.5 4 1.5
1717. LOAD COMB 102 1.5(DL+LL+DOOR CLOSED)
1718. 1 1.5 2 1.5 3 1.5
1719. LOAD COMB 103 1.5DL+1.5TESTING
1720. 1 1.5 5 1.5
1721. LOAD COMB 104 1.2DL+1.2DOOR CLOSED+1.2WLXP
1722. 1 1.2 3 1.2 6 1.2
1723. LOAD COMB 105 1.2DL+1.2DOOR CLOSED+1.2WLXS
1724. 1 1.2 3 1.2 7 1.2
1725. LOAD COMB 106 1.2DL+1.2DOOR CLOSED+1.2WL-XP
1726. 1 1.2 3 1.2 8 1.2
1727. LOAD COMB 107 1.2DL+1.2DOOR CLOSED+1.2WL-XS
1728. 1 1.2 3 1.2 9 1.2
1729. LOAD COMB 108 1.2DL+1.2DOOR CLOSED+1.2WLZP
1730. 1 1.2 3 1.2 10 1.2
1731. LOAD COMB 109 1.2DL+1.2DOOR CLOSED+1.2WLZS
1732. 1 1.2 3 1.2 11 1.2
1733. LOAD COMB 110 1.2DL+1.2DOOR CLOSED+1.2WL-ZP
1734. 1 1.2 3 1.2 12 1.2
1735. LOAD COMB 111 1.2DL+1.2DOOR CLOSED+1.2WL-ZS
1736. 1 1.2 3 1.2 13 1.2
1737. LOAD COMB 112 0.9DL+0.9DOOR CLOSED+1.5WLXP
1738. 1 0.9 3 0.9 6 1.5
1739. LOAD COMB 113 0.9DL+0.9DOOR CLOSED+1.5WLXS
1740. 1 0.9 3 0.9 7 1.5
1741. LOAD COMB 114 0.9DL+0.9DOOR CLOSED+1.5WL-XP
1742. 1 0.9 3 0.9 8 1.5
1743. LOAD COMB 115 0.9DL+0.9DOOR CLOSED+1.5WL-XS
1744. 1 0.9 3 0.9 9 1.5
1745. LOAD COMB 116 0.9DL+0.9DOOR CLOSED+1.5WLZP
1746. 1 0.9 3 0.9 10 1.5
1747. LOAD COMB 117 0.9DL+0.9DOOR CLOSED+1.5WLZS
1748. 1 0.9 3 0.9 11 1.5
1749. LOAD COMB 118 0.9DL+0.9DOOR CLOSED+1.5WL-ZP
1750. 1 0.9 3 0.9 12 1.5
1751. LOAD COMB 119 0.9DL+0.9DOOR CLOSED+1.5WL-ZS
1752. 1 0.9 3 0.9 13 1.5
1753. LOAD COMB 201 DL+DOOR OPEN
1754. 1 1.0 4 1.0
1755. LOAD COMB 202 DL+DOOR CLOSED
1756. 1 1.0 3 1.0
1757. LOAD COMB 203 DL+TESTING
1758. 1 1.0 5 1.0
1759. LOAD COMB 204 DL+DOOR CLOSED+WLXP
1760. 1 1.0 3 1.0 6 1.0
```

```
1761. LOAD COMB 205 DL+DOOR CLOSED+WLXS
1762. 1 1.0 3 1.0 7 1.0
1763. LOAD COMB 206 DL+DOOR CLOSED+WL-XP
1764. 1 1.0 3 1.0 8 1.0
1765. LOAD COMB 207 DL+DOOR CLOSED+WL-XS
1766. 1 1.0 3 1.0 9 1.0
1767. LOAD COMB 208 DL+DOOR CLOSED+WLZP
1768. 1 1.0 3 1.0 10 1.0
1769. LOAD COMB 209 DL+DOOR CLOSED+WLZS
1770. 1 1.0 3 1.0 11 1.0
1771. LOAD COMB 210 DL+DOOR CLOSED+WL-ZP
1772. 1 1.0 3 1.0 12 1.0
1773. LOAD COMB 211 DL+DOOR CLOSED+WL-ZS
1774. 1 1.0 3 1.0 13 1.0
1775. LOAD COMB 212 DL+DOOR CLOSED+WLXP
1776. 1 1.0 3 1.0 6 1.0
1777. LOAD COMB 213 DL+DOOR CLOSED+WLXS
1778. 1 1.0 3 1.0 7 1.0
1779. LOAD COMB 214 DL+DOOR CLOSED+WL-XP
1780. 1 1.0 3 1.0 8 1.0
1781. LOAD COMB 215 DL+DOOR CLOSED+WL-XS
1782. 1 1.0 3 1.0 9 1.0
1783. LOAD COMB 216 DL+DOOR CLOSED+WLZP
1784. 1 1.0 3 1.0 10 1.0
1785. LOAD COMB 217 DL+DOOR CLOSED+WLZS
1786. 1 1.0 3 1.0 11 1.0
1787. LOAD COMB 218 DL+DOOR CLOSED+WL-ZP
1788. 1 1.0 3 1.0 12 1.0
1789. LOAD COMB 219 DL+DOOR CLOSED+WL-ZS
1790. 1 1.0 3 1.0 13 1.0
1791. LOAD LIST 101 TO 119

 **WARNING: A LOAD LIST COMMAND WITHIN LOAD DATA IGNORED. **

1792. PERFORM ANALYSIS


          P R O B L E M   S T A T I S T I C S
          -----------------------------------

   NUMBER OF JOINTS       1302  NUMBER OF MEMBERS    2613
   NUMBER OF PLATES          0  NUMBER OF SOLIDS        0
   NUMBER OF SURFACES        0  NUMBER OF SUPPORTS    187

         Using 64-bit analysis engine.

         SOLVER USED IS THE IN-CORE ADVANCED MATH SOLVER

 TOTAL      PRIMARY LOAD CASES =    13, TOTAL DEGREES OF FREEDOM =    7212
 TOTAL LOAD COMBINATION  CASES =    38  SO FAR.
```

STAAD SPACE -- PAGE NO. 34

*WARNING- APPLIED SELFWEIGHT IS LESS THAN TOTAL WEIGHT OF ALL
STRUCTURAL ELEMENTS IN LOAD CASE 1 ALONG Y.
THIS COULD BE DUE TO SELFWEIGHT APPLIED TO SPECIFIC
LIST OF MEMBERS/PLATES/SOLIDS/SURFACES.
TOTAL UNFACTORED WEIGHT OF THE STRUCTURE = 1387.568 KN
TOTAL UNFACTORED WEIGHT OF THE STRUCTURE APPLIED = 419.585 KN

```
1793. PARAMETER 1
1794. CODE IS800 LSD
1795. FYLD 355000 MEMB 1 TO 8 16 19 TO 36 73 TO 79 81 TO 83 118 TO 137 174 TO 201 -
1796. 216 TO 218 221 306 TO 335 338 TO 349 360 361 366 368 433 TO 450 508 TO 511 -
1797. 522 TO 524 527 TO 531 533 534 536 TO 539 541 543 545 547 549 551 553 TO 559 -
1798. 567 TO 602 605 TO 614 617 619 620 622 TO 630 646 TO 735 748 749 759 TO 840 -
1799. 846 TO 881 899 TO 957 968 TO 1089 1092 TO 1094 1097 TO 1169 1171 1172 1174 -
1800. 1175 TO 1197 1210 TO 1221 1223 TO 1225 1227 TO 1229 1231 TO 1233 1235 TO 1237 -
1801. 1239 TO 1241 1243 TO 1281 1283 TO 1285 1287 TO 1489 1491 1493 1495 -
1802. 1497 TO 1552 1554 1556 1558 1560 TO 1940 1942 1944 1946 1948 1950 1952 1954 -
1803. 1956 1958 1960 1962 1964 TO 2080 2082 TO 2084 2086 2087 2089 2090 2092 2093 -
1804. 2095 2096 2098 2099 2101 2102 2104 2105 2107 2108 2110 2111 2113 2114 2116 -
1805. 2117 2119 2120 2122 2123 2125 TO 2442 2447 TO 2801 2807 2809 TO 2858 2934 -
1806. 2935 TO 2939 2971 2974 2977 2982 2985 2988 2999 3002 3005 3010 3013 3016 3027 -
1807. 3028 TO 3130
1808. CHECK CODE MEMB 1 TO 8 16 19 TO 36 73 TO 79 81 TO 83 118 TO 137 174 TO 201 -
1809. 216 TO 218 221 306 TO 335 338 TO 349 360 361 366 368 433 TO 450 508 TO 511 -
1810. 522 TO 524 527 TO 531 533 534 536 TO 539 541 543 545 547 549 551 553 TO 559 -
1811. 567 TO 602 605 TO 614 617 619 620 622 TO 630 646 TO 687 705 TO 735 748 749 -
1812. 759 TO 806 809 TO 840 846 847 849 TO 863 878 TO 881 899 TO 957 968 TO 1089 -
1813. 1092 TO 1094 1097 TO 1169 1171 1172 1174 TO 1197 1210 TO 1221 1223 TO 1225 -
1814. 1227 TO 1229 1231 TO 1233 1235 TO 1237 1239 TO 1241 1243 TO 1281 -
1815. 1283 TO 1285 1287 TO 1489 1491 1493 1495 1497 TO 1552 1554 1556 1558 1560 -
1816. 1561 TO 1940 1942 1944 1946 1948 1950 1952 1954 1956 1958 1960 1962 -
1817. 1964 TO 2080 2082 TO 2084 2086 2087 2089 2090 2092 2093 2095 2096 2098 2099 -
1818. 2101 2102 2104 2105 2107 2108 2110 2111 2113 2114 2116 2117 2119 2120 2122 -
1819. 2123 2125 TO 2442 2447 TO 2684 2769 TO 2776 2785 TO 2792 2801 TO 3130
STEEL DESIGN
```

```
|-------------------------------------------------------------------------------|
|  Member Number:      1                                                        |
|  Member Section:  ST   150X150X5.0SHS  (APL APOLLOTUBE SECTIONS)              |
|  Status: PASS  Ratio:   0.040  Critical Load Case:   101  Location:      0.00  |
|  Critical Condition: Sec. 9.3.2.2                                             |
|-------------------------------------------------------------------------------|
```

STAAD SPACE -- PAGE NO. 35

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	2				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.277	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	3				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.144	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	4				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.158	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	5				
Member Section:	ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.926	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 36

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	6				
Member Section:	ST	180X180X6.0SHS	(APL APOLLOTUBE SECTIONS)		
Status: PASS	Ratio:	0.860	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	7				
Member Section:	ST	180X180X6.0SHS	(APL APOLLOTUBE SECTIONS)		
Status: PASS	Ratio:	0.895	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	8				
Member Section:	ST	150X150X5.0SHS	(APL APOLLOTUBE SECTIONS)		
Status: PASS	Ratio:	0.346	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	16				
Member Section:	ST	150X150X5.0SHS	(APL APOLLOTUBE SECTIONS)		
Status: PASS	Ratio:	0.140	Critical Load Case: 114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 37

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	19				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.150	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	20				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.468	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	21				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.568	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	22				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.346	Critical Load Case:	119	Location:	1.34
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	23				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.172	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	24				
Member Section:	ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.100	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number:	25				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.473	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	26				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.429	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 39

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 27					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.361	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 28					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.122	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 29					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.340	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 30					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.622	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 40

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	31				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.104	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	32				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.337	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	33				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.333	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	34				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.255	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 41

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	35				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.091	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	36				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.387	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	73				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.130	Critical Load Case:	119	Location:	4.37
Critical Condition: Sec. 9.3.2.2					

Member Number:	74				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.790	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 42

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	75				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.764	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	76				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.139	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	77				
Member Section:	ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.296	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	78				
Member Section:	ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.840	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 43

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 79					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.562	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 81					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: FAIL	Ratio: 90.832	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 82					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.081	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 83					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: FAIL	Ratio: 121.946	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 44

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 118					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.411	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 119					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.701	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 120					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.183	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 121					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.970	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 45

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 122					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.679	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 123					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.778	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 124					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.128	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 125					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.047	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 46

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
| Member Number: 126 |
| Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.070 Critical Load Case: 111 Location: 0.00 |
| Critical Condition: Sec. 8.2.1.2 |

|---|
|* Member Number: 127 |
| Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.439 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.1.1 |

|---|
| Member Number: 128 |
| Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.111 Critical Load Case: 114 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
|* Member Number: 129 |
| Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.035 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

STAAD SPACE -- PAGE NO. 47

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
| Member Number: 130 |
| Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.348 Critical Load Case: 114 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
|* Member Number: 131 |
| Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.017 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 132 |
| Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.684 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 6.3 |

|---|
| Member Number: 133 |
| Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.909 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 134					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.212	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 135					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.938	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.1.3					

* Member Number: 136					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 2.000	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.1.1					

Member Number: 137					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.665	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 49

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 174					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.052	Critical Load Case: 112	Location:	0.38	
Critical Condition: Sec. 9.3.2.2					

Member Number: 175					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.126	Critical Load Case: 119	Location:	4.57	
Critical Condition: Sec. 6.3					

Member Number: 176					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.036	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 177					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.170	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 50

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 178					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.246	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 179					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.221	Critical Load Case:	119	Location:	4.18
Critical Condition: Sec. 9.3.2.2					

Member Number: 180					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.083	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 181					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.140	Critical Load Case:	114	Location:	4.18
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 51

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 182					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.060	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 183					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.153	Critical Load Case:	112	Location:	4.85
Critical Condition: Sec. 9.3.2.2					

Member Number: 184					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.215	Critical Load Case:	112	Location:	4.18
Critical Condition: Sec. 9.3.2.2					

Member Number: 185					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.059	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 52

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 186					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.096	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 187					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.243	Critical Load Case:	112	Location:	4.18
Critical Condition: Sec. 9.3.2.2					

Member Number: 188					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.036	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 189					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	119	Location:	2.71
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 53

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 190					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.014	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 191					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.028	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 192					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.103	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 193					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.018	Critical Load Case:	119	Location:	2.67
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 54

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 194					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.362	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 195					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.268	Critical Load Case:	114	Location:	5.54
Critical Condition: Sec. 9.3.2.2					

Member Number: 196					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.087	Critical Load Case:	112	Location:	4.41
Critical Condition: Sec. 9.3.2.2					

Member Number: 197					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.229	Critical Load Case:	119	Location:	4.96
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 55

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 198					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.090	Critical Load Case:	112	Location:	4.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 199					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.113	Critical Load Case:	119	Location:	4.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 200					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.040	Critical Load Case:	112	Location:	4.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 201					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.054	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 56

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 216					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.322	Critical Load Case:	119	Location:	0.83
Critical Condition: Sec. 6.3					

Member Number: 217					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.560	Critical Load Case:	119	Location:	0.80
Critical Condition: Sec. 6.3					

Member Number: 218					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.457	Critical Load Case:	119	Location:	3.98
Critical Condition: Sec. 8.2.1.2					

Member Number: 221					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.392	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 57

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 306					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.257	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 307					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.566	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 308					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.178	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 309					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.495	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 58

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 310					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.674	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 311					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.716	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 312					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.759	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 313					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.704	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 59

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 314					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.850	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 315					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.625	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 316					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.683	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 317					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.911	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 60

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 318					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.917	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 319					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.129	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 320					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 7.643	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

* Member Number: 321					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: FAIL	Ratio: 24.974	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 61

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 322					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.993	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 323					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.847	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 324					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.870	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 325					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.751	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 62

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 326					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.476	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 327					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.219	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 328					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.213	Critical Load Case:	119	Location:	2.67
Critical Condition: Sec. 9.3.1.3					

* Member Number: 329					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: FAIL	Ratio: 29.593	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 63

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 330 |
| Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: ******* Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.1.1

|---|
|* Member Number: 331 |
| Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.110 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

|---|
|* Member Number: 332 |
| Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.069 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

|---|
| Member Number: 333 |
| Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.847 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 64

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 334					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.637	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 335					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.551	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 338					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.355	Critical Load Case: 112	Location:	8.64	
Critical Condition: Sec. 9.3.2.2					

***WARNING: THE VALUE OF MOMENT AMPLIFICATION FACTORS KY OR KZ IS GREATER THAN 1.4
FOR MEMBER # 339 FOR LOADCASE- 112. SECOND-ORDER ELASTIC ANALYSIS MUST BE PERFORMED
AS PER SECTION 4.4.2 of IS800-2007. ALSO, ENSURE THAT THE TYPE OF COMBINATION USED IS
REPEAT LOAD OR REFERENCE LOAD INSTEAD OF THE LOAD COMBINATION SYNTAX EXCEPT FOR
RESPONSE SPECTRUM LOAD CASES.

Member Number: 339					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.769	Critical Load Case: 112	Location:	8.72	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 65

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 340					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.101	Critical Load Case:	119	Location:	8.80
Critical Condition: Sec. 9.3.2.2					

Member Number: 341					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.525	Critical Load Case:	119	Location:	8.88
Critical Condition: Sec. 9.3.2.2					

***WARNING: THE VALUE OF MOMENT AMPLIFICATION FACTORS KY OR KZ IS GREATER THAN 1.4
FOR MEMBER # 342 FOR LOADCASE- 119. SECOND-ORDER ELASTIC ANALYSIS MUST BE PERFORMED
AS PER SECTION 4.4.2 of IS800-2007. ALSO, ENSURE THAT THE TYPE OF COMBINATION USED IS
REPEAT LOAD OR REFERENCE LOAD INSTEAD OF THE LOAD COMBINATION SYNTAX EXCEPT FOR
RESPONSE SPECTRUM LOAD CASES.

Member Number: 342					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.842	Critical Load Case:	119	Location:	8.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 343					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.655	Critical Load Case:	114	Location:	9.05
Critical Condition: Sec. 9.3.2.2					

***WARNING: THE VALUE OF MOMENT AMPLIFICATION FACTORS KY OR KZ IS GREATER THAN 1.4
FOR MEMBER # 344 FOR LOADCASE- 112. SECOND-ORDER ELASTIC ANALYSIS MUST BE PERFORMED
AS PER SECTION 4.4.2 of IS800-2007. ALSO, ENSURE THAT THE TYPE OF COMBINATION USED IS
REPEAT LOAD OR REFERENCE LOAD INSTEAD OF THE LOAD COMBINATION SYNTAX EXCEPT FOR
RESPONSE SPECTRUM LOAD CASES.

STAAD SPACE -- PAGE NO. 66

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 344					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.669	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

***WARNING: THE VALUE OF MOMENT AMPLIFICATION FACTORS KY OR KZ IS GREATER THAN 1.4
FOR MEMBER # 345 FOR LOADCASE- 119. SECOND-ORDER ELASTIC ANALYSIS MUST BE PERFORMED
AS PER SECTION 4.4.2 of IS800-2007. ALSO, ENSURE THAT THE TYPE OF COMBINATION USED IS
REPEAT LOAD OR REFERENCE LOAD INSTEAD OF THE LOAD COMBINATION SYNTAX EXCEPT FOR
RESPONSE SPECTRUM LOAD CASES.

Member Number: 345					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.821	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 346					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.599	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 347					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.165	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

***WARNING: THE VALUE OF MOMENT AMPLIFICATION FACTORS KY OR KZ IS GREATER THAN 1.4
FOR MEMBER # 348 FOR LOADCASE- 114. SECOND-ORDER ELASTIC ANALYSIS MUST BE PERFORMED
AS PER SECTION 4.4.2 of IS800-2007. ALSO, ENSURE THAT THE TYPE OF COMBINATION USED IS
REPEAT LOAD OR REFERENCE LOAD INSTEAD OF THE LOAD COMBINATION SYNTAX EXCEPT FOR
RESPONSE SPECTRUM LOAD CASES.

STAAD SPACE -- PAGE NO. 67

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 348					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.784	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

***WARNING: THE VALUE OF MOMENT AMPLIFICATION FACTORS KY OR KZ IS GREATER THAN 1.4
FOR MEMBER # 349 FOR LOADCASE- 114. SECOND-ORDER ELASTIC ANALYSIS MUST BE PERFORMED
AS PER SECTION 4.4.2 of IS800-2007. ALSO, ENSURE THAT THE TYPE OF COMBINATION USED IS
REPEAT LOAD OR REFERENCE LOAD INSTEAD OF THE LOAD COMBINATION SYNTAX EXCEPT FOR
RESPONSE SPECTRUM LOAD CASES.
THERE MAY BE MORE SUCH CASES. ADDITIONAL SUCH MESSAGES ARE SUPPRESSED.

Member Number: 349					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.977	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 360					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.828	Critical Load Case:	119	Location:	4.03
Critical Condition: Sec. 9.3.2.2					

Member Number: 361					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.875	Critical Load Case:	119	Location:	4.03
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 68

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 366					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.969	Critical Load Case:	119	Location:	1.99
Critical Condition: Sec. 9.3.2.2					

Member Number: 368					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.802	Critical Load Case:	119	Location:	2.01
Critical Condition: Sec. 9.3.2.2					

Member Number: 433					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.857	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

* Member Number: 434					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.047	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 69

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 435					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.673	Critical Load Case:	119	Location:	4.18
Critical Condition: Sec. 9.3.1.1					

Member Number: 436					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.739	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 437					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.815	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 438					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.885	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 70

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 439					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.771	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 440					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.772	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 441					
Member Section: ST 180X180X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.947	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 442					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.330	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 71

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 443					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.366	Critical Load Case:	119	Location:	4.85
Critical Condition: Sec. 6.3					

Member Number: 444					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.367	Critical Load Case:	119	Location:	4.18
Critical Condition: Sec. 6.3					

Member Number: 445					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.041	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 446					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.378	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 72

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 447					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.077	Critical Load Case:	119	Location:	3.98
Critical Condition: Sec. 9.3.2.2					

Member Number: 448					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.042	Critical Load Case:	102	Location:	4.01
Critical Condition: Sec. 8.2.1.2					

Member Number: 449					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.527	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 450					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.078	Critical Load Case:	119	Location:	4.01
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 73

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 508 |
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.022 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

|---|
|* Member Number: 509 |
| Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.086 Critical Load Case: 112 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

|---|
| Member Number: 510 |
| Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.465 Critical Load Case: 102 Location: 5.30 |
Critical Condition: Sec. 9.3.2.2

|---|
| Member Number: 511 |
| Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.370 Critical Load Case: 13 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 74

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 522					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.306	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 523					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.718	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 524					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.613	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 527					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.345	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 75

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 528					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.271	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 529					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.241	Critical Load Case:	112	Location:	4.08
Critical Condition: Sec. 9.3.2.2					

Member Number: 530					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.237	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 531					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.198	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 76

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 533					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.881	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 534					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

Member Number: 536					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.957	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 537					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.615	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 77

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 538					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.418	Critical Load Case:	119	Location:	2.24
Critical Condition: Sec. 9.3.1.3					

Member Number: 539					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.663	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 541					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.525	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 543					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.613	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 78

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 545					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.222	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 547					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.137	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 549					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.383	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 551					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.695	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 79

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 553					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.571	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 554					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.602	Critical Load Case:	114	Location:	3.29
Critical Condition: Sec. 9.3.2.2					

Member Number: 555					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.650	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 556					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.264	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 80

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 557					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.600	Critical Load Case:	114	Location:	0.56
Critical Condition: Sec. 9.3.2.2					

Member Number: 558					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.361	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 559					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.753	Critical Load Case:	119	Location:	1.84
Critical Condition: Sec. 9.3.2.2					

Member Number: 567					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.127	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 81

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 568					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.389	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 569					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.682	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 570					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.900	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 571					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.719	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 82

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 572					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.806	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 573					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.861	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 574					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.852	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 575					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.815	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 83

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 576					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.728	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 577					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.880	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 578					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.718	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 579					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.480	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 84

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 580					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.172	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 581					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.261	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.1.3					

Member Number: 582					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.250	Critical Load Case:	119	Location:	2.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 583					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.263	Critical Load Case:	119	Location:	1.88
Critical Condition: Sec. 9.3.1.3					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 584					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.351	Critical Load Case:	119	Location:	1.76
Critical Condition: Sec. 9.3.1.3					

Member Number: 585					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.357	Critical Load Case:	119	Location:	1.64
Critical Condition: Sec. 9.3.1.3					

Member Number: 586					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.495	Critical Load Case:	119	Location:	1.52
Critical Condition: Sec. 9.3.1.3					

Member Number: 587					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.569	Critical Load Case:	119	Location:	1.40
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 86

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 588					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.324	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.1.3					

Member Number: 589					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.305	Critical Load Case:	119	Location:	2.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 590					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.233	Critical Load Case:	119	Location:	1.88
Critical Condition: Sec. 9.3.1.3					

Member Number: 591					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.297	Critical Load Case:	119	Location:	1.76
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 87

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 592					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.282	Critical Load Case:	119	Location:	1.64
Critical Condition: Sec. 9.3.1.3					

Member Number: 593					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.483	Critical Load Case:	119	Location:	1.52
Critical Condition: Sec. 9.3.1.3					

Member Number: 594					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.501	Critical Load Case:	119	Location:	1.40
Critical Condition: Sec. 9.3.1.3					

Member Number: 595					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.457	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 88

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 596					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.272	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 597					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 598					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.605	Critical Load Case:	112	Location:	10.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 599					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.778	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 89

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 600					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.913	Critical Load Case:	114	Location:	10.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 601					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.912	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 602					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.769	Critical Load Case:	114	Location:	10.10
Critical Condition: Sec. 9.3.2.2					

Member Number: 605					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.502	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 90

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 606					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.914	Critical Load Case:	114	Location:	10.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 607					
Member Section: ST 220X220X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.497	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 608					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.985	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 609					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.888	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 610				
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.846	Critical Load Case: 112	Location:	10.10
Critical Condition: Sec. 9.3.2.2				

* Member Number: 611				
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: FAIL	Ratio: 3.975	Critical Load Case: 112	Location:	0.00
Critical Condition: Sec. 9.3.2.2				

Member Number: 612				
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.395	Critical Load Case: 119	Location:	2.83
Critical Condition: Sec. 6.3				

* Member Number: 613				
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: FAIL	Ratio: 1.321	Critical Load Case: 114	Location:	0.00
Critical Condition: Sec. 9.3.2.2				

STAAD SPACE -- PAGE NO. 92

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 614					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.469	Critical Load Case:	114	Location:	2.84
Critical Condition: Sec. 9.3.2.2					

Member Number: 617					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.592	Critical Load Case:	119	Location:	5.60
Critical Condition: Sec. 9.3.2.2					

Member Number: 619					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.814	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 620					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.609	Critical Load Case:	119	Location:	5.63
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 622					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.813	Critical Load Case:	119	Location:	4.02
Critical Condition: Sec. 9.3.2.2					

Member Number: 623					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.627	Critical Load Case:	114	Location:	5.79
Critical Condition: Sec. 9.3.2.2					

* Member Number: 624					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.013	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 625					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.392	Critical Load Case:	8	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 94

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 626					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.576	Critical Load Case:	102	Location:	5.79
Critical Condition: Sec. 9.3.2.2					

Member Number: 627					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.395	Critical Load Case:	119	Location:	2.83
Critical Condition: Sec. 6.3					

Member Number: 628					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.109	Critical Load Case:	119	Location:	2.83
Critical Condition: Sec. 9.3.2.2					

Member Number: 629					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.121	Critical Load Case:	119	Location:	4.57
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 95

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 630					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.026	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 646					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00
Critical Condition: SLENDERNESS					

* Member Number: 647					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00
Critical Condition: SLENDERNESS					

* Member Number: 648					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

STAAD SPACE -- PAGE NO. 96

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 649					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.296	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 650					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.357	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 651					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.306	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 652					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.692	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 97

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 653					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.680	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 654					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.849	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 655					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.771	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 656					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.597	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 98

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 657					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.386	Critical Load Case: 119	Location:	5.23	
Critical Condition: Sec. 9.3.2.2					

Member Number: 658					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.700	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 659					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.698	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 660					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.823	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 99

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 661					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.642	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 662					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.844	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 663					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.492	Critical Load Case:	119	Location:	5.23
Critical Condition: Sec. 9.3.2.2					

* Member Number: 664					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

STAAD SPACE -- PAGE NO. 100

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 665						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00	
Critical Condition: SLENDERNESS						

* Member Number: 666						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 2.832	Critical Load Case:	112	Location:	0.00	
Critical Condition: Sec. 7.1.2						

* Member Number: 667						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 4.615	Critical Load Case:	112	Location:	0.00	
Critical Condition: Sec. 7.1.2						

* Member Number: 668						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 5.567	Critical Load Case:	112	Location:	0.00	
Critical Condition: Sec. 7.1.2						

STAAD SPACE -- PAGE NO. 101

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 669						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 54.697	Critical Load Case:	8	Location:	0.00	
Critical Condition: Sec. 9.3.1.1						

* Member Number: 670						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 81.066	Critical Load Case:	6	Location:	0.00	
Critical Condition: Sec. 9.3.1.1						

* Member Number: 671						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 5.314	Critical Load Case:	114	Location:	0.00	
Critical Condition: Sec. 7.1.2						

* Member Number: 672						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 4.704	Critical Load Case:	114	Location:	0.00	
Critical Condition: Sec. 7.1.2						

STAAD SPACE -- PAGE NO. 102

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 673
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)
| Status: FAIL Ratio: 2.620 Critical Load Case: 114 Location: 0.00
| Critical Condition: Sec. 7.1.2

|* Member Number: 674
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)
| Status: FAIL Ratio: 1.424 Critical Load Case: 6 Location: 0.00
| Critical Condition: SLENDERNESS

|* Member Number: 675
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)
| Status: FAIL Ratio: 1.424 Critical Load Case: 6 Location: 0.00
| Critical Condition: SLENDERNESS

| Member Number: 676
| Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.751 Critical Load Case: 112 Location: 11.71
| Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 103

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 677					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.243	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 678					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.569	Critical Load Case:	119	Location:	11.71
Critical Condition: Sec. 9.3.2.2					

Member Number: 679					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.411	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 680					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.956	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 104

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 681					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.960	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 682					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.957	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 683					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.923	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 684					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.392	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 105

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 685					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.567	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 686					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.387	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 687					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.778	Critical Load Case:	114	Location:	11.71
Critical Condition: Sec. 9.3.2.2					

Member Number: 705					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.955	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 106

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 706					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.828	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 707					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.957	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 708					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.709	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 709					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.799	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 107

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 710					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.714	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 711					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.635	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 712					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.486	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 713					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.834	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 108

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 714					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.924	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 715					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.820	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 716					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.791	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 717					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.656	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 109

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 718					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.568	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 719					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.444	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 720					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.058	Critical Load Case:	119	Location:	5.23
Critical Condition: Sec. 9.3.2.2					

Member Number: 721					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.195	Critical Load Case:	112	Location:	5.23
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 110

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 722					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.541	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 723					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.859	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 724					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.831	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 725					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.146	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 111

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 726					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.257	Critical Load Case:	119	Location:	4.88
Critical Condition: Sec. 9.3.2.2					

Member Number: 727					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.864	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 728					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.327	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 729					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.086	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 730					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.995	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 731					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.875	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 732					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.983	Critical Load Case:	119	Location:	0.52
Critical Condition: Sec. 9.3.2.2					

Member Number: 733					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.808	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 734					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.423	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 735					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.641	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 748					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.049	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 749					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.047	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 114

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 759					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.214	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 760					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.245	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 761					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.111	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 762					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 115

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 763					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.414	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 764					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.458	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 765					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.233	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 766					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.912	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 767					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.892	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 768					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.855	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 769					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.790	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 770					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.722	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 117

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 771					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.771	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 772					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.506	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 773					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.894	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 774					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.842	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 118

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 775				
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.766	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 9.3.2.2				

Member Number: 776				
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.754	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 9.3.2.2				

Member Number: 777				
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.821	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 9.3.2.2				

Member Number: 778				
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.506	Critical Load Case: 119	Location:	1.50
Critical Condition: Sec. 9.3.2.2				

STAAD SPACE -- PAGE NO. 119

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 779					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.135	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 780					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.280	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 781					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.324	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 782					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.200	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 120

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 783					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.930	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 784					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.935	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 785					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.346	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 786					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.144	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 787					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.147	Critical Load Case:	103	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 788					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.697	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 789					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.606	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 790					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.562	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 122

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 791					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.696	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 792					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.148	Critical Load Case:	103	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 793					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 794					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.388	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 123

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 795					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.087	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 796					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.304	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 797					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.134	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 798					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.160	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 124

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 799					
Member Section: ST	72X72X5.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.500	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 800					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.194	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 801					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.114	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 802					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.917	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 125

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 803					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.180	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 804					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.207	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 805					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.329	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 806					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.239	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 126

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 809					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.139	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 810					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.248	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 811					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.281	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 812					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.263	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 127

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 813					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.300	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 814					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.277	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 815					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.318	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 816					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.309	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 128

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 817					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.489	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 818					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.487	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 819					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.282	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 820					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.296	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 129

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 821					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.260	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 822					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.280	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 823					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.266	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 824					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.253	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 130

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 825					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.172	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 826					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.877	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 9.3.1.1					

* Member Number: 827					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.555	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 9.3.1.1					

Member Number: 828					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.282	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 131

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 829					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.402	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 830					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.665	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 831					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.495	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 832					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.490	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 132

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 833					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.677	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 834					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.652	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 835					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.496	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 836					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.646	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 133

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 837					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.654	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 838					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.101	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 839					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.473	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 840					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.110	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 134

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 846					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.273	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 847					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.262	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 849					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.613	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 850					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.613	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 135

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 851					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.970	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 852					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.295	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 853					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.856	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 854					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.274	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 136

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 855					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.614	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 856					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.220	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 857					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.518	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 858					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.918	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 137

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 859					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.192	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 860					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.901	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 861					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.356	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 862					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.631	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 138

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 863					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.547	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 878					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.246	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 879					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.243	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 880					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.072	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 139

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 881					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.108	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 899					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.109	Critical Load Case: 112	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 900					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.258	Critical Load Case: 114	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 901					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.887	Critical Load Case: 114	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 140

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 902					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.842	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 903					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.685	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 904					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.780	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 905					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.731	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 141

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 906					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.654	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 907					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.280	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 908					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.475	Critical Load Case:	119	Location:	3.13
Critical Condition: Sec. 8.2.1.2					

Member Number: 909					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.401	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 142

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 910					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.356	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 911					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.725	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 912					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.435	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 913					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.195	Critical Load Case:	119	Location:	1.34
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 143

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 914					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.175	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 915					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.147	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.1.3					

Member Number: 916					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.260	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 917					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.286	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 144

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 918					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.215	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 919					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.265	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 920					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.476	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 921					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.496	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 145

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 922					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.228	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 923					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.283	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 924					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.296	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 925					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.246	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 146

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 926					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.217	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 927					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.455	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 928					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.288	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 929					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.960	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 147

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 930					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.904	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 931					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.651	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 932					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.093	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 933					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.426	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 148

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 934					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.729	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

* Member Number: 935					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: FAIL	Ratio: 1.268	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 936					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.067	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

* Member Number: 937					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: FAIL	Ratio: 1.394	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 149

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 938					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.448	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 939					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.531	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 940					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.218	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 941					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.998	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 150

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 942					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.564	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 943					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.960	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 944					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.271	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 945					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.740	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 151

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 946					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.145	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 947					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.747	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 948					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.104	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 949					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.728	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 152

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 950					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.269	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 951					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.704	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 952					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.710	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 953					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.771	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 153

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 954					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.191	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 955					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.991	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 956					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.650	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 957					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.566	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 154

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 968					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.146	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 969					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.287	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 970					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.299	Critical Load Case: 119	Location:	4.18	
Critical Condition: Sec. 9.3.2.2					

Member Number: 971					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.304	Critical Load Case: 119	Location:	4.17	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 155

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 972					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.326	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 973					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.080	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 974					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.758	Critical Load Case:	119	Location:	4.17
Critical Condition: Sec. 9.3.2.2					

Member Number: 975					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.770	Critical Load Case:	114	Location:	4.18
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 156

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 976					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.681	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 977					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.937	Critical Load Case:	119	Location:	4.85
Critical Condition: Sec. 9.3.2.2					

Member Number: 978					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.744	Critical Load Case:	112	Location:	4.18
Critical Condition: Sec. 9.3.2.2					

Member Number: 979					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.606	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 157

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 980					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.975	Critical Load Case:	119	Location:	4.85
Critical Condition: Sec. 9.3.2.2					

Member Number: 981					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.620	Critical Load Case:	119	Location:	4.18
Critical Condition: Sec. 8.2.1.2					

Member Number: 982					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.050	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 983					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.050	Critical Load Case:	119	Location:	2.71
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 158

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 984					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.074	Critical Load Case:	119	Location:	2.71
Critical Condition: Sec. 8.2.1.2					

Member Number: 985					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.129	Critical Load Case:	114	Location:	2.67
Critical Condition: Sec. 8.2.1.2					

Member Number: 986					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.162	Critical Load Case:	114	Location:	2.67
Critical Condition: Sec. 9.3.2.2					

Member Number: 987					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.124	Critical Load Case:	114	Location:	2.67
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 159

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 988					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.321	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 989					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.481	Critical Load Case:	119	Location:	5.54
Critical Condition: Sec. 9.3.2.2					

Member Number: 990					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.218	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 991					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.299	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 992					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.297	Critical Load Case:	112	Location:	4.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 993					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.424	Critical Load Case:	119	Location:	4.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 994					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.335	Critical Load Case:	112	Location:	4.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 995					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.437	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 161

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 996					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.324	Critical Load Case:	119	Location:	0.83
Critical Condition: Sec. 6.3					

Member Number: 997					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.627	Critical Load Case:	119	Location:	0.80
Critical Condition: Sec. 6.3					

Member Number: 998					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.688	Critical Load Case:	119	Location:	3.98
Critical Condition: Sec. 9.3.2.2					

Member Number: 999					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.316	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 162

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1000					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.387	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1001					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.847	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1002					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.224	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1003					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.415	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 163

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1004					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.746	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1005					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.903	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1006					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.979	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1007					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.988	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 164

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 1008
| Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.020 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1009
| Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.618 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1010
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.505 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1011
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.385 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.1.3

STAAD SPACE -- PAGE NO. 165

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1012					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.818	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1013					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.568	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1014					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.614	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1015					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.681	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 166

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 1016
| Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.084 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1017
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.835 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1018
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.778 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1019
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.845 Critical Load Case: 114 Location: 0.00
| Critical Condition: Sec. 9.3.1.3

STAAD SPACE -- PAGE NO. 167

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1020					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.506	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1021					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.230	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1022					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.367	Critical Load Case:	119	Location:	2.67
Critical Condition: Sec. 9.3.1.3					

Member Number: 1023					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.680	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 168

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1024					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.589	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1025					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.552	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1026					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.789	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1027					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.421	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 169

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1028					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.524	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1029					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.561	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1030					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.726	Critical Load Case:	112	Location:	8.64
Critical Condition: Sec. 9.3.2.2					

Member Number: 1031					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.704	Critical Load Case:	112	Location:	8.72
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 170

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1032					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.398	Critical Load Case:	112	Location:	8.80
Critical Condition: Sec. 9.3.2.2					

Member Number: 1033					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.265	Critical Load Case:	114	Location:	8.88
Critical Condition: Sec. 9.3.2.2					

Member Number: 1034					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.698	Critical Load Case:	114	Location:	8.97
Critical Condition: Sec. 9.3.2.2					

Member Number: 1035					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.726	Critical Load Case:	119	Location:	9.05
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 171

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1036					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.739	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1037					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.706	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1038					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.356	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1039					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.702	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 172

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1040					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.830	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1041					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.765	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1042					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.562	Critical Load Case:	119	Location:	4.03
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1043					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.247	Critical Load Case:	119	Location:	4.03
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 173

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1044					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.567	Critical Load Case:	119	Location:	1.99
Critical Condition: Sec. 9.3.2.2					

Member Number: 1045					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.431	Critical Load Case:	119	Location:	2.01
Critical Condition: Sec. 9.3.2.2					

Member Number: 1046					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.671	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1047					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.851	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 174

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1048					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.633	Critical Load Case:	119	Location:	4.18
Critical Condition: Sec. 8.2.1.2					

Member Number: 1049					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.751	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1050					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.908	Critical Load Case:	119	Location:	4.85
Critical Condition: Sec. 9.3.2.2					

Member Number: 1051					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.823	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 175

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1052					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.931	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1053					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.979	Critical Load Case:	119	Location:	4.85
Critical Condition: Sec. 9.3.2.2					

Member Number: 1054					
Member Section: ST 180X180X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.925	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1055					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.272	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 176

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1056				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.436	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1057				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.469	Critical Load Case:	112	Location:	4.18
Critical Condition: Sec. 9.3.2.2					

Member Number:	1058				
Member Section:	ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.122	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number:	1059				
Member Section:	ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.759	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 177

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1060					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.137	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1061					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.038	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1062					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.132	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1063					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.052	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 178

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1064					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.372	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1065					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.928	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1066					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.792	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 1067					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.639	Critical Load Case:	119	Location:	5.95
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 179

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1068					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.038	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1069					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.278	Critical Load Case:	119	Location:	5.95
Critical Condition: Sec. 9.3.2.2					

Member Number: 1070					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.943	Critical Load Case:	119	Location:	4.18
Critical Condition: Sec. 8.2.1.2					

Member Number: 1071					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.738	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 180

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1072					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.758	Critical Load Case:	119	Location:	3.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1073					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.617	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1074					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.395	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1075					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.279	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 181

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1076					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.517	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1077					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.812	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 6.3					

Member Number: 1078					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.338	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1079					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.268	Critical Load Case:	114	Location:	7.67
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 182

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1080					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.725	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1081					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.599	Critical Load Case:	112	Location:	7.27
Critical Condition: Sec. 9.3.2.2					

Member Number: 1082					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.252	Critical Load Case:	119	Location:	7.27
Critical Condition: Sec. 9.3.2.2					

Member Number: 1083					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.509	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 183

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1084					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.415	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1085					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.730	Critical Load Case:	119	Location:	7.27
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1086					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.117	Critical Load Case:	119	Location:	5.77
Critical Condition: Sec. 9.3.2.2					

Member Number: 1087					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.312	Critical Load Case:	112	Location:	6.27
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 184

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1088					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.867	Critical Load Case:	119	Location:	5.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 1089					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.498	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1092					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.520	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1093					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.882	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 185

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1094					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.722	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1097					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.575	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1098					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.551	Critical Load Case:	119	Location:	4.03
Critical Condition: Sec. 9.3.2.2					

Member Number: 1099					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.518	Critical Load Case:	112	Location:	4.08
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 186

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1100					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.201	Critical Load Case:	119	Location:	1.54
Critical Condition: Sec. 9.3.2.2					

Member Number: 1101					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.164	Critical Load Case:	119	Location:	1.53
Critical Condition: Sec. 9.3.2.2					

Member Number: 1102					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.830	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1103					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.425	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 187

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1104					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.745	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1105					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.471	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1106					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.197	Critical Load Case:	119	Location:	2.24
Critical Condition: Sec. 9.3.1.3					

Member Number: 1107					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.474	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 188

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1108					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.405	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1109					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.461	Critical Load Case:	103	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1110					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.239	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1111					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.221	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 189

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1112					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.323	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1113					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.629	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1114					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.458	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1115					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.469	Critical Load Case:	103	Location:	3.29
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 190

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1116					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.517	Critical Load Case:	103	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1117					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.123	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1118					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.463	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1119					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.408	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 191

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
| Member Number: 1120 |
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.634 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 1121 |
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.203 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 8.2.1.2 |

|---|
| Member Number: 1122 |
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.479 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 1123 |
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.829 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

STAAD SPACE -- PAGE NO. 192

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1124					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.721	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1125					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.803	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1126					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.852	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1127					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.849	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1128					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.818	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1129					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.814	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1130					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.761	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1131					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.022	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 194

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1132					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.818	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1133					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.472	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1134					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.229	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1135					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.239	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 195

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1136					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.270	Critical Load Case:	119	Location:	2.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1137					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.431	Critical Load Case:	119	Location:	1.88
Critical Condition: Sec. 9.3.1.3					

Member Number: 1138					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.590	Critical Load Case:	119	Location:	1.76
Critical Condition: Sec. 9.3.2.2					

Member Number: 1139					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.745	Critical Load Case:	119	Location:	1.64
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 196

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1140					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.550	Critical Load Case:	119	Location:	1.52
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1141					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.047	Critical Load Case:	119	Location:	1.40
Critical Condition: Sec. 9.3.1.3					

Member Number: 1142					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.214	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.1.3					

Member Number: 1143					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.190	Critical Load Case:	112	Location:	2.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 197

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1144					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.308	Critical Load Case:	119	Location:	1.88
Critical Condition: Sec. 9.3.1.3					

Member Number: 1145					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.447	Critical Load Case:	119	Location:	1.76
Critical Condition: Sec. 9.3.1.3					

Member Number: 1146					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.606	Critical Load Case:	119	Location:	1.64
Critical Condition: Sec. 9.3.1.3					

Member Number: 1147					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.762	Critical Load Case:	119	Location:	1.52
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 198

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1148					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.878	Critical Load Case:	119	Location:	1.40
Critical Condition: Sec. 9.3.1.3					

Member Number: 1149					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.257	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1150					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.256	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1151					
Member Section: ST 175X175X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.099	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 199

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1152					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.466	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1153					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.915	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1154					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.772	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1155					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.976	Critical Load Case:	114	Location:	10.20
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 200

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1156					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.574	Critical Load Case:	114	Location:	10.10
Critical Condition: Sec. 9.3.2.2					

Member Number: 1157					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.547	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1158					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.902	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1159					
Member Section: ST 220X220X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.411	Critical Load Case:	114	Location:	10.39
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 201

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1160					
Member Section: ST 220X220X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.581	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1161					
Member Section: ST 220X220X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.735	Critical Load Case:	112	Location:	10.20
Critical Condition: Sec. 9.3.2.2					

Member Number: 1162					
Member Section: ST 220X220X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.918	Critical Load Case:	112	Location:	10.10
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1163					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 2.141	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 202

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1164					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.401	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

* Member Number: 1165					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.670	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1166					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.464	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1167					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.548	Critical Load Case:	112	Location:	4.94
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 203

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1168					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.576	Critical Load Case:	119	Location:	5.01
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1169					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.050	Critical Load Case:	119	Location:	5.60
Critical Condition: Sec. 9.3.2.2					

Member Number: 1171					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.905	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1172					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.596	Critical Load Case:	119	Location:	5.63
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 204

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1174					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.828	Critical Load Case:	119	Location:	4.02
Critical Condition: Sec. 9.3.2.2					

Member Number: 1175					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.475	Critical Load Case:	114	Location:	5.79
Critical Condition: Sec. 9.3.2.2					

Member Number: 1176					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.697	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1177					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.634	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 205

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1178					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.509	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1179					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.401	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1180					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.091	Critical Load Case:	119	Location:	2.83
Critical Condition: Sec. 9.3.2.2					

Member Number: 1181					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.280	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 206

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1182				
Member Section:	ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.060	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number:	1183				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.552	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1184				
Member Section:	ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.944	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1185				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.562	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 207

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1186					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.710	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1187					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.789	Critical Load Case:	112	Location:	5.05
Critical Condition: Sec. 9.3.2.2					

Member Number: 1188					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.879	Critical Load Case:	119	Location:	4.98
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1189					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 88.437	Critical Load Case:	119	Location:	8.35
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 208

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 1190
| Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 88.437 Critical Load Case: 119 Location: 8.35
| Critical Condition: Sec. 9.3.1.1

|* Member Number: 1191
| Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 108.877 Critical Load Case: 119 Location: 8.35
| Critical Condition: Sec. 9.3.1.1

|* Member Number: 1192
| Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 108.877 Critical Load Case: 119 Location: 8.35
| Critical Condition: Sec. 9.3.1.1

|* Member Number: 1193
| Member Section: ST ISMB300 (INDIAN SECTIONS)
| Status: FAIL Ratio: 33.340 Critical Load Case: 119 Location: 8.35
| Critical Condition: Sec. 9.3.1.1

STAAD SPACE -- PAGE NO. 209

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 1194						
Member Section: ST	ISMB300	(INDIAN SECTIONS)				
Status: FAIL	Ratio: 33.340	Critical Load Case:	119	Location:	8.35	
Critical Condition: Sec. 9.3.1.1						

* Member Number: 1195						
Member Section: ST	ISMB300	(INDIAN SECTIONS)				
Status: FAIL	Ratio: 33.340	Critical Load Case:	119	Location:	8.35	
Critical Condition: Sec. 9.3.1.1						

* Member Number: 1196						
Member Section: ST	ISMB300	(INDIAN SECTIONS)				
Status: FAIL	Ratio: 33.340	Critical Load Case:	119	Location:	8.35	
Critical Condition: Sec. 9.3.1.1						

* Member Number: 1197						
Member Section: ST	ISMB300	(INDIAN SECTIONS)				
Status: FAIL	Ratio: 33.340	Critical Load Case:	119	Location:	8.35	
Critical Condition: Sec. 9.3.1.1						

STAAD SPACE -- PAGE NO. 210

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1210					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.128	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1211					
Member Section: ST 150X150X5.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.089	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1212					
Member Section: ST 180X180X8.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.199	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 1213					
Member Section: ST 180X180X8.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.200	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 211

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1214					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.964	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1215					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.970	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1216					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.391	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1217					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.204	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 212

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1218					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.426	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1219					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.321	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1220					
Member Section: ST 250X250X10.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.356	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1221					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.672	Critical Load Case:	112	Location:	1.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 213

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1223					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.697	Critical Load Case:	119	Location:	1.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1224					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.469	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1225					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.576	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1227					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.420	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 214

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1228					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.405	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1229					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.458	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1231					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.346	Critical Load Case:	119	Location:	0.56
Critical Condition: Sec. 8.2.1.2					

Member Number: 1232					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.550	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 215

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1233					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.683	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1235					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.533	Critical Load Case:	103	Location:	2.71
Critical Condition: Sec. 8.2.1.2					

Member Number: 1236					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.838	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 1237					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.312	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 216

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1239					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.425	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1240					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.627	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 1241					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.101	Critical Load Case:	106	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1243					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.113	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 217

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1244					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.963	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1245					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.795	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1246					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.887	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1247					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.757	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 218

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1248					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.761	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1249					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.354	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1250					
Member Section: ST 180X180X6.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.851	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1251					
Member Section: ST 180X180X8.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.798	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 219

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1252					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.958	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1253					
Member Section: ST 180X180X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.849	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1254					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.369	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 1255					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.968	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 220

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1256					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.678	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 1257					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.682	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 1258					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.401	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1259					
Member Section: ST 180X180X8.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.636	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 221

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1260					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.696	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1261					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.703	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1262					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.636	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1263					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.370	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 222

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1264					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.846	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1265					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.816	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 8.2.1.2					

Member Number: 1266					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.819	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 8.2.1.2					

Member Number: 1267					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.857	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 223

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1268					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.835	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1269					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.242	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1270					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.080	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1271					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.463	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1272					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.527	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1273					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.496	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1274					
Member Section: ST 250X250X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.684	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1275					
Member Section: ST 250X250X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.689	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 225

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1276					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.456	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1277					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.529	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1278					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.412	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1279					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.071	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 226

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1280					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.284	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1281					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.741	Critical Load Case:	119	Location:	0.76
Critical Condition: Sec. 9.3.2.2					

Member Number: 1283					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.634	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1284					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 227

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1285					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.658	Critical Load Case:	119	Location:	0.60
Critical Condition: Sec. 9.3.2.2					

Member Number: 1287					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.601	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1288					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.177	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1289					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.650	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 228

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1290					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.651	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1291					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.329	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1292					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.651	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1293					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.651	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 229

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1294					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.330	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1295					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.420	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1296					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.331	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1297					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.665	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 230

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1298					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.382	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1299					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.303	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1300					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.265	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1301					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.541	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 231

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1302					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.569	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1303					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.877	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1304					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.510	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1305					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.820	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 232

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1306					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.888	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

* Member Number: 1307					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.040	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1308					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.044	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1309					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.733	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 233

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1310					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.997	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1311					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.000	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1312					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.675	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1313					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.800	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1314					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.804	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1315					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.880	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1316					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.486	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1317					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.498	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 235

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1318					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.830	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1319					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.405	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1320					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.341	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1321					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.294	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 236

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1322					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.406	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1323					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.312	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1324					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.699	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1325					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.751	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 237

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1326					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.334	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 1327					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.334	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 1328					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.755	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 1329					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.336	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 238

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1330					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.336	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 1331					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.172	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1332					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.240	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.1.3					

Member Number: 1333					
Member Section: ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.424	Critical Load Case: 119	Location:	1.51	
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 239

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1334					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.576	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1335					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.305	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1336					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.442	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1337					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.771	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 240

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1338					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.330	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1339					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.628	Critical Load Case:	112	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1340					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.652	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1341					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.285	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1342					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.575	Critical Load Case:	112	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1343					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.678	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1344					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.325	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1345					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.364	Critical Load Case:	112	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1346					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.656	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1347					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.305	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1348					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.366	Critical Load Case:	114	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1349					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.653	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 243

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1350					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.298	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1351					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.573	Critical Load Case:	114	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1352					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.850	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1353					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.627	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 244

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1354				
Member Section:	ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.547	Critical Load Case:	114	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number:	1355				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.553	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number:	1356				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.302	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number:	1357				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.423	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 245

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1358					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.205	Critical Load Case:	119	Location:	0.45
Critical Condition: Sec. 9.3.1.3					

Member Number: 1359					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.250	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number: 1360					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.462	Critical Load Case:	119	Location:	1.66
Critical Condition: Sec. 9.3.1.3					

Member Number: 1361					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.770	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 246

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1362					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.741	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1363					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.878	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1364					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.587	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1365					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.649	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 247

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1366					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.751	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1367					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.658	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1368					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.638	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1369					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.787	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 248

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1370					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.524	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1371					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.592	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1372					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.708	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1373					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.242	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 249

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1374					
Member Section: ST 250X250X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.684	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1375					
Member Section: ST 250X250X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.689	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1376					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.080	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1377					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.527	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 250

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1378					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.496	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1379					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.456	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1380					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.529	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1381					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.071	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 251

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1382					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.284	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1383					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.463	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1384					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.412	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1385					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 252

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1386					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.177	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1387					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.133	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1388					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.161	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1389					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 253

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1390					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.134	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1391					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.162	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1392					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1393					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.165	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 254

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1394					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.021	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1395					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.243	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1396					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.241	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1397					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.048	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 255

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1398					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.198	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1399					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.217	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1400					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.081	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1401					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.044	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 256

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1402					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.126	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1403					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.132	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1404					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.110	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1405					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.100	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 257

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1406					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.116	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1407					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.099	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1408					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.098	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1409					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.099	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 258

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1410					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.042	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1411					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.108	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1412					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.117	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1413					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.110	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 259

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1414					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.217	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1415					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.065	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1416					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.082	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1417					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.238	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 260

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1418					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.048	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1419					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.200	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1420					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.171	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1421					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.022	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 261

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1422					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.249	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1423					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.100	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1424					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.071	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1425					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.030	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 262

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1426					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.105	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1427					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.060	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1428					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.053	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1429					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.122	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 263

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1430					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.239	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1431					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.094	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1432					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.127	Critical Load Case:	114	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1433					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.290	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 264

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1434					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.281	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1435					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.055	Critical Load Case:	114	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1436					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.226	Critical Load Case:	112	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1437					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.678	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 265

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1438					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.767	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1439					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.381	Critical Load Case:	112	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1440					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.367	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1441					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.562	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 266

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1442					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.644	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1443					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.404	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1444					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.716	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1445					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.630	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 267

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1446					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.818	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1447					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.522	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1448					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.760	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1449					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.544	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 268

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1450					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.657	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1451					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.444	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1452					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.524	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1453					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.558	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 269

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1454					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.679	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1455					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.570	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1456					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.623	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1457					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.560	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 270

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1458					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.681	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1459					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.573	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1460					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.628	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1461					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.533	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 271

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1462					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.636	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1463					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.407	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1464					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.519	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1465					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.524	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 272

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1466					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.628	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1467					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.427	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1468					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.757	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1469					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.424	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 273

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1470					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.458	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1471					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.311	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1472					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.525	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1473					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.683	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 274

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1474					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.756	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1475					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.371	Critical Load Case:	114	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1476					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.350	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1477					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.334	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 275

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1478					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.315	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1479					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.050	Critical Load Case:	102	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1480					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.375	Critical Load Case:	114	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1481					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.251	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 276

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1482					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.598	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1483					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.252	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1484					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.476	Critical Load Case:	114	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1485					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.213	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 277

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 1486 |
| Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.300 Critical Load Case: 119 Location: 2.30 |
| Critical Condition: Sec. 9.3.1.3 |

| Member Number: 1487 |
| Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.246 Critical Load Case: 119 Location: 2.30 |
| Critical Condition: Sec. 9.3.1.3 |

| Member Number: 1488 |
| Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.243 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.1.3 |

| Member Number: 1489 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.523 Critical Load Case: 114 Location: 0.00 |
| Critical Condition: Sec. 9.3.1.3 |

STAAD SPACE -- PAGE NO. 278

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1491					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.442	Critical Load Case:	114	Location:	2.30
Critical Condition: Sec. 9.3.1.3					

Member Number: 1493					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.355	Critical Load Case:	114	Location:	1.62
Critical Condition: Sec. 9.3.1.3					

Member Number: 1495					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.363	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1497					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.303	Critical Load Case:	119	Location:	2.18
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 279

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1498					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.299	Critical Load Case: 119	Location:	2.30	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1499					
Member Section: ST 180X180X5.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.364	Critical Load Case: 119	Location:	2.07	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1500					
Member Section: ST 180X180X5.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.326	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1501					
Member Section: ST 180X180X5.0SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.315	Critical Load Case: 119	Location:	1.96	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 280

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1502				
Member Section:	ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.285	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1503				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.312	Critical Load Case:	114	Location:	1.85
Critical Condition: Sec. 9.3.1.3					

Member Number:	1504				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.259	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number:	1505				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.337	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 281

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1506					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.415	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1507					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.087	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 1508					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.648	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 1509					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.204	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 282

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1510					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.505	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1511					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.150	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1512					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.479	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1513					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.443	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 283

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1514					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.637	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.1.3					

Member Number: 1515					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.677	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1516					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.303	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.1.3					

Member Number: 1517					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.072	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 284

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1518					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.361	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1519					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.124	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1520					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.236	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1521					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.194	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 285

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1522					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.180	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1523					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.127	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1524					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.276	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1525					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.143	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 286

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1526					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.283	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1527					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.100	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1528					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.321	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1529					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.101	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 287

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1530					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.283	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1531					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.033	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1532					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.209	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1533					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.160	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 288

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1534					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.886	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1535					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.753	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1536					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.800	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1537					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.728	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 289

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1538					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.728	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1539					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.707	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1540					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.506	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1541					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.490	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 290

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1542					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.345	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1543					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.959	Critical Load Case:	114	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1544					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.590	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1545					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.592	Critical Load Case:	114	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 291

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1546					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.798	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1547					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.591	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1548					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.538	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1549					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.337	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 292

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1550					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.209	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1551					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.139	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1552					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.447	Critical Load Case:	112	Location:	2.30
Critical Condition: Sec. 9.3.1.3					

Member Number: 1554					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.523	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 293

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1556					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.403	Critical Load Case:	112	Location:	1.62
Critical Condition: Sec. 9.3.1.3					

Member Number: 1558					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.427	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1560					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.373	Critical Load Case:	119	Location:	1.73
Critical Condition: Sec. 9.3.1.3					

Member Number: 1561					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.365	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 294

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1562					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.326	Critical Load Case:	112	Location:	1.85
Critical Condition: Sec. 9.3.1.3					

Member Number: 1563					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1564					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.330	Critical Load Case:	119	Location:	1.96
Critical Condition: Sec. 9.3.1.3					

Member Number: 1565					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.311	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1566					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.425	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1567					
Member Section: ST 180X180X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.346	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1568					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.300	Critical Load Case:	119	Location:	2.18
Critical Condition: Sec. 9.3.2.2					

Member Number: 1569					
Member Section: ST TUB E (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.298	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 296

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1570					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.655	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1571					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.301	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.1.3					

Member Number: 1572					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.410	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1573					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.687	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 297

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1574					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.149	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1575					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.483	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1576					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.226	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1577					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.524	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 298

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1578					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.087	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 1579					
Member Section: ST TUB E	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.645	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 1580					
Member Section: ST 50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.219	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 1581					
Member Section: ST 50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.118	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 299

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1582					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.143	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1583					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.285	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1584					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.126	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1585					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.356	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 300

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1586					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.170	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1587					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.269	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1588					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.227	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1589					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.378	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 301

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1590					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.194	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1591					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.179	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1592					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.882	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1593					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.750	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 302

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1594					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.768	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1595					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.733	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1596					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.744	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1597					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.853	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1598					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.760	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1599					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.653	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1600					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.365	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1601					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.422	Critical Load Case:	112	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 304

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1602					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.400	Critical Load Case:	119	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1603					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.408	Critical Load Case:	112	Location:	2.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 1604					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.137	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1605					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.463	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 305

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1606				
Member Section:	ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.448	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1607				
Member Section:	ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.664	Critical Load Case:	112	Location:	2.47
Critical Condition: Sec. 9.3.2.2					

Member Number:	1608				
Member Section:	ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.653	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1609				
Member Section:	ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.794	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 306

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1610					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.383	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1611					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.409	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1612					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.082	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1613					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.227	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 307

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1614					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.298	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1615					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.626	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1616					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.615	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1617					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.061	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 308

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1618					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1619					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.125	Critical Load Case:	112	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1620					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.380	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1621					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.351	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 309

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1622					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.415	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1623					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.438	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1624					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.447	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1625					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.556	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 310

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1626					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.040	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1627					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.071	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1628					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.090	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1629					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.206	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 311

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1630					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.077	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1631					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.232	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1632					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.047	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1633					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.050	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 312

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1634					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.178	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1635					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.032	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1636					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.069	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1637					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.180	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 313

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1638					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.044	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1639					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.105	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1640					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.294	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1641					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.038	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 314

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1642					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.178	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1643					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.090	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1644					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.161	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1645					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.071	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 315

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1646					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.253	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1647					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1648					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.079	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1649					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.307	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 316

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1650					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1651					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.032	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1652					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.307	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1653					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.211	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1654					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.069	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1655					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.188	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1656					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.329	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1657					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.353	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 318

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1658					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.270	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1659					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.333	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1660					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.266	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1661					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 319

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1662					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.363	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1663					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.265	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1664					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.028	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1665					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.364	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 320

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1666					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.245	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1667					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.079	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1668					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.201	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1669					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.211	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 321

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1670					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.166	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1671					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.173	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1672					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.338	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1673					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.226	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 322

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1674					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.106	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1675					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.396	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1676					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.226	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1677					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.036	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 323

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1678					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.396	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1679					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.247	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1680					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.104	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1681					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.396	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 324

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1682					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.356	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1683					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.365	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1684					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.314	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1685					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.104	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 325

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1686					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.194	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1687					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.175	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1688					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.127	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1689					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 326

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1690					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.277	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1691					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.150	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1692					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.173	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1693					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.371	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1694					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.280	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1695					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.204	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1696					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.166	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1697					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.256	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 328

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1698					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.172	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1699					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.214	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1700					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.367	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1701					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.129	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 329

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1702					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.215	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1703					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.277	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1704					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.129	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1705					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 330

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1706					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1707					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.342	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1708					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.292	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1709					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.281	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 331

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1710					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.374	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1711					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.473	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1712					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.278	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1713					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.115	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 332

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1714				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.400	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1715				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.278	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1716				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.038	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1717				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.400	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 333

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1718				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.350	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1719				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.127	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1720				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.385	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number:	1721				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.447	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 334

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1722					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.434	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1723					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.477	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1724					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.429	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1725					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.310	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 335

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1726					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.086	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1727					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.400	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1728					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.310	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1729					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.034	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 336

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1730					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.400	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1731					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.339	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1732					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.090	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1733					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.172	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 337

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1734					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.140	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1735					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.209	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1736					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.187	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1737					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.360	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 338

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1738				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.221	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1739				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.066	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1740				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.321	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1741				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.221	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 339

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
| Member Number: 1742 |
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.023 Critical Load Case: 112 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 1743 |
| Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.321 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 6.3 |

|---|
| Member Number: 1744 |
| Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.260 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 6.3 |

|---|
| Member Number: 1745 |
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.086 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

STAAD SPACE -- PAGE NO. 340

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1746					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.200	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1747					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.232	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1748					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.254	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1749					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.256	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 341

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1750					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.089	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1751					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.122	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1752					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.054	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1753					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.037	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 342

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1754					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.116	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1755					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.047	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1756					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.072	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1757					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.114	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 343

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1758					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.042	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1759					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.253	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1760					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.234	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1761					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.146	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 344

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1762					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.234	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1763					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.293	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1764					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.364	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1765					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 345

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1766					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.336	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1767					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.360	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1768					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.068	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1769					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.338	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 346

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1770					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.371	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1771					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.036	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1772					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.066	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1773					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.248	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 347

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1774					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.095	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1775					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.227	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1776					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.404	Critical Load Case:	119	Location:	1.34
Critical Condition: Sec. 9.3.2.2					

Member Number: 1777					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.575	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 348

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1778					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.371	Critical Load Case:	119	Location:	1.34
Critical Condition: Sec. 9.3.2.2					

Member Number: 1779					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.203	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1780					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.080	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1781					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.049	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1782					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.316	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1783					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.546	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1784					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.233	Critical Load Case:	119	Location:	2.01
Critical Condition: Sec. 9.3.2.2					

Member Number: 1785					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 350

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1786					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.342	Critical Load Case:	119	Location:	1.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 1787					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.536	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1788					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.094	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1789					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.596	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 351

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1790					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.617	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1791					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.914	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1792					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.512	Critical Load Case:	112	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 1793					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.399	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 352

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1794					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.708	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1795					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.495	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1796					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.338	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1797					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.188	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 353

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1798					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.269	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1799					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.094	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1800					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.186	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1801					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.236	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 354

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1802				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.147	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1803				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.183	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1804				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.189	Critical Load Case:	112	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number:	1805				
Member Section:	ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.598	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 355

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1806					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.604	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1807					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.613	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1808					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.546	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1809					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.169	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 356

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1810				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.291	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1811				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.181	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number:	1812				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.375	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1813				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.300	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 357

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1814					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.124	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1815					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.412	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1816					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.552	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1817					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.172	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 358

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1818					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.577	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1819					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.499	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1820					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.642	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1821					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.499	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 359

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1822					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.327	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1823					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.539	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1824					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.140	Critical Load Case:	112	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 1825					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.345	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 360

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1826				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.261	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1827				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.213	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1828				
Member Section:	ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.775	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number:	1829				
Member Section:	ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.716	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 361

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1830					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.126	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1831					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.122	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1832					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.250	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1833					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 362

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1834				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.131	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1835				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.231	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number:	1836				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.109	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1837				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.092	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 363

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1838					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.173	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1839					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.412	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1840					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.455	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1841					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.368	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 364

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1842					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.368	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1843					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.040	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1844					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.054	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1845					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.100	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 365

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1846					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.045	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1847					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.073	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 1848					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.113	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1849					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.096	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 366

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1850				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.076	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number:	1851				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.147	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number:	1852				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.130	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number:	1853				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.183	Critical Load Case:	102	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 367

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1854					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.100	Critical Load Case:	6	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1855					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.132	Critical Load Case:	102	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1856					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.339	Critical Load Case:	119	Location:	1.87
Critical Condition: Sec. 9.3.2.2					

Member Number: 1857					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.326	Critical Load Case:	119	Location:	2.40
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 368

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1858				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.036	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number:	1859				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.075	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1860				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.141	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number:	1861				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.046	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 369

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1862				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.060	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1863				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.113	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number:	1864				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.053	Critical Load Case:	111	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number:	1865				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.131	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 370

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1866					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.105	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1867					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.169	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1868					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.128	Critical Load Case:	8	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1869					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.201	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 371

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1870				
Member Section:	ST 50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.158	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1871				
Member Section:	ST 140X140X5.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.086	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1872				
Member Section:	ST 140X140X5.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.142	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1873				
Member Section:	ST 50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.157	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 372

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1874					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.140	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1875					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.134	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1876					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.230	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 1877					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.140	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 373

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1878				
Member Section:	ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.277	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	1879				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.252	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number:	1880				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.350	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1881				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.355	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 374

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	1882				
Member Section:	ST 50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.435	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1883				
Member Section:	ST 50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.402	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	1884				
Member Section:	ST 140X140X5.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.342	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	1885				
Member Section:	ST 140X140X5.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.554	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 375

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1886					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.210	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1887					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.698	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1888					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.581	Critical Load Case:	119	Location:	1.88
Critical Condition: Sec. 9.3.2.2					

Member Number: 1889					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.141	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 376

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1890					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.723	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1891					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.788	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1892					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.384	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1893					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.296	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 377

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1894					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1895					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.155	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1896					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.285	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1897					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.129	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1898					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.180	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1899					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.192	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1900					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.198	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 1901					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.529	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 379

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1902					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.709	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1903					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.549	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1904					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.641	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1905					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.168	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 380

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1906					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.297	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1907					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.199	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 1908					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.492	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1909					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.299	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 381

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1910					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.272	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 1911					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.562	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 1912					
Member Section: ST 140X140X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.621	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1913					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 382

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1914					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.647	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1915					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.298	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1916					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.713	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 1917					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.749	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 383

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1918					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.975	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1919					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 2.000	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 1920					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.419	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1921					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.507	Critical Load Case:	119	Location:	1.34
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 384

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1922					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.316	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1923					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.078	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 1924					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.569	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1925					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.777	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 385

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1926					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.514	Critical Load Case:	119	Location:	2.01
Critical Condition: Sec. 9.3.2.2					

Member Number: 1927					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.471	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 1928					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.331	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1929					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.333	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1930					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.191	Critical Load Case:	119	Location:	3.42
Critical Condition: Sec. 9.3.2.2					

Member Number: 1931					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.365	Critical Load Case:	114	Location:	3.42
Critical Condition: Sec. 9.3.2.2					

Member Number: 1932					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.082	Critical Load Case:	119	Location:	3.42
Critical Condition: Sec. 9.3.2.2					

Member Number: 1933					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.290	Critical Load Case:	112	Location:	3.42
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 387

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1934					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.418	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1935					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.388	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1936					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.617	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1937					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.309	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 388

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1938					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.351	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1939					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.449	Critical Load Case:	119	Location:	1.45
Critical Condition: Sec. 9.3.1.3					

* Member Number: 1940					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.089	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 1942					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.078	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 389

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 1944
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.241 Critical Load Case: 119 Location: 1.74
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1946
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.512 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 1948
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.537 Critical Load Case: 119 Location: 1.74
| Critical Condition: Sec. 9.3.1.3

| Member Number: 1950
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.946 Critical Load Case: 119 Location: 1.74
| Critical Condition: Sec. 9.3.1.3

STAAD SPACE -- PAGE NO. 390

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1952					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.578	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1954					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.582	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1956					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.991	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

* Member Number: 1958					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.293	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 391

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 1960 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.262 Critical Load Case: 119 Location: 1.74 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
|* Member Number: 1962 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.451 Critical Load Case: 119 Location: 1.74 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 1964 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.643 Critical Load Case: 119 Location: 1.74 |
| Critical Condition: Sec. 9.3.1.3 |

|---|
| Member Number: 1965 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.287 Critical Load Case: 119 Location: 1.74 |
| Critical Condition: Sec. 9.3.1.3 |

STAAD SPACE -- PAGE NO. 392

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1966					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.265	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1967					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.662	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1968					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.303	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1969					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.255	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 393

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1970					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.497	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1971					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.224	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1972					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1973					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.625	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 394

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1974					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.291	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1975					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.361	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 1976					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.478	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1977					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.259	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 395

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1978					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.366	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1979					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.705	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1980					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.407	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1981					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.520	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 396

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1982					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.700	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1983					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.348	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1984					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.328	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1985					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.768	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 397

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1986					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.374	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1987					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.310	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1988					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.591	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1989					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.286	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1990					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.238	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1991					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.564	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1992					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.208	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1993					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.306	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 399

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1994					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.525	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1995					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.229	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1996					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.290	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 1997					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.692	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 400

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 1998					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.388	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 1999					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.508	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2000					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.404	Critical Load Case:	119	Location:	1.59
Critical Condition: Sec. 9.3.1.3					

Member Number: 2001					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.464	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 401

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2002					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.552	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2003					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.583	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 2004					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.565	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 2005					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.691	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 402

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2006					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.579	Critical Load Case:	119	Location:	1.30
Critical Condition: Sec. 9.3.1.3					

Member Number: 2007					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.686	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 2008					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.853	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2009					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.964	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 403

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2010					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.874	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 2011					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.921	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2012					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.770	Critical Load Case:	119	Location:	1.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2013					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.853	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 404

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2014					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.948	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2015					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.838	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 2016					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.704	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 2017					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.746	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 405

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2018					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.295	Critical Load Case:	119	Location:	1.45
Critical Condition: Sec. 9.3.1.3					

Member Number: 2019					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.341	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 2020					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.407	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2021					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.471	Critical Load Case:	119	Location:	1.59
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 406

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2022					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.439	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 2023					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.524	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2024					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.489	Critical Load Case:	119	Location:	1.45
Critical Condition: Sec. 9.3.1.3					

Member Number: 2025					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.553	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2026					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.682	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2027					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.826	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.1.3					

Member Number: 2028					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.719	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 2029					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.768	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 408

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2030					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.759	Critical Load Case:	119	Location:	1.45
Critical Condition: Sec. 9.3.1.3					

Member Number: 2031					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.824	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

Member Number: 2032					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.906	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2033					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.991	Critical Load Case:	119	Location:	1.74
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2034					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.894	Critical Load Case: 119	Location:	1.74	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2035					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.954	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2036					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.212	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.3					

Member Number: 2037					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.211	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 410

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2038					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.242	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2039					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.177	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2040					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.101	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2041					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.269	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 411

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2042					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.180	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2043					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.107	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2044					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.272	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2045					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.266	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 412

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2046					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.179	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2047					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.218	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2048					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.265	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2049					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.158	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 413

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2050					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.221	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2051					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.253	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2052					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.167	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2053					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.223	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 414

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2054					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.275	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2055					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.155	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2056					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.206	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2057					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.243	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 415

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2058					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.167	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2059					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.221	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2060					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.268	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2061					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.105	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 416

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2062					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.210	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2063					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.257	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2064					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.195	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2065					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.212	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 417

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2066					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.263	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2067					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2068					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.214	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2069					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.250	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 418

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2070					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.178	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2071					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.218	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2072					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.272	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2073					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.166	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 419

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2074					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.217	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2075					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.260	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2076					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.162	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2077					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.216	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 420

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2078					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.276	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2079					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.144	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2080					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.212	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2082					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.059	Critical Load Case:	102	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 421

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2083					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.167	Critical Load Case:	102	Location:	2.70
Critical Condition: Sec. 9.3.2.2					

Member Number: 2084					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.548	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2086					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.244	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2087					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.614	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2089					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.124	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2090					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.799	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2092					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.171	Critical Load Case:	102	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2093					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.659	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 423

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2095					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.068	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2096					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.549	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2098					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.044	Critical Load Case:	102	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2099					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.607	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 424

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2101					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.216	Critical Load Case:	112	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2102					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.296	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2104					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.414	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2105					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.435	Critical Load Case:	102	Location:	2.70
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 425

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2107					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.240	Critical Load Case:	114	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2108					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.314	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2110					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.064	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2111					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.575	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 426

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2113					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.072	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2114					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.571	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2116					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.181	Critical Load Case:	102	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2117					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.720	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 427

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2119					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.032	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2120					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.686	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2122					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.298	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2123					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.701	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 428

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2125					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.076	Critical Load Case:	114	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2126					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.436	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2127					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.765	Critical Load Case:	119	Location:	2.13
Critical Condition: Sec. 9.3.2.2					

Member Number: 2128					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.855	Critical Load Case:	119	Location:	2.22
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 429

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2129					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.861	Critical Load Case:	119	Location:	2.31
Critical Condition: Sec. 9.3.2.2					

Member Number: 2130					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.215	Critical Load Case:	119	Location:	2.41
Critical Condition: Sec. 9.3.2.2					

Member Number: 2131					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.210	Critical Load Case:	119	Location:	2.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2132					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	119	Location:	2.60
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 430

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2133					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.182	Critical Load Case:	119	Location:	2.70
Critical Condition: Sec. 9.3.2.2					

Member Number: 2134					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.196	Critical Load Case:	119	Location:	2.60
Critical Condition: Sec. 9.3.2.2					

Member Number: 2135					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.209	Critical Load Case:	119	Location:	2.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2136					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.228	Critical Load Case:	119	Location:	2.41
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 431

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2137					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.935	Critical Load Case:	119	Location:	2.31
Critical Condition: Sec. 9.3.2.2					

Member Number: 2138					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.804	Critical Load Case:	119	Location:	2.22
Critical Condition: Sec. 9.3.2.2					

Member Number: 2139					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.816	Critical Load Case:	119	Location:	2.13
Critical Condition: Sec. 9.3.2.2					

Member Number: 2140					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.566	Critical Load Case:	119	Location:	2.05
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 432

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2141					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.791	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2142					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.511	Critical Load Case:	119	Location:	4.29
Critical Condition: Sec. 9.3.2.2					

Member Number: 2143					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.369	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2144					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.381	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 433

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2145					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.966	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2146					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.825	Critical Load Case:	119	Location:	1.85
Critical Condition: Sec. 9.3.2.2					

Member Number: 2147					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.428	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2148					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.755	Critical Load Case:	119	Location:	1.85
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 434

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2149					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.086	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

* Member Number: 2150					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.450	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

* Member Number: 2151					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 2.023	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2152					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.791	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 435

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2153					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.332	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2154					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.197	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

* Member Number: 2155					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.271	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2156					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.394	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 436

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 2157
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.234 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.1.3

|* Member Number: 2158
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.467 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.1.3

| Member Number: 2159
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.370 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 8.2.1.2

|* Member Number: 2160
| Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.001 Critical Load Case: 119 Location: 1.00
| Critical Condition: Sec. 9.3.1.1

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2161					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.425	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2162					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.391	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2163					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.467	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2164					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.612	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 438

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2165					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.384	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2166					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 2.122	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2167					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.571	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2168					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.286	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 439

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 2169
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.202 Critical Load Case: 119 Location: 1.00
| Critical Condition: Sec. 9.3.1.3

| Member Number: 2170
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.989 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.1.3

| Member Number: 2171
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.370 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 8.2.1.2

| Member Number: 2172
| Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.932 Critical Load Case: 119 Location: 1.00
| Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 440

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2173					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.741	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2174					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.218	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2175					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.119	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2176					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.804	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 441

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2177					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.353	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2178					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.004	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 2179					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2180					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.394	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 442

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 2181
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.504 Critical Load Case: 119 Location: 1.00
| Critical Condition: Sec. 9.3.1.3

| Member Number: 2182
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.501 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.1.3

| Member Number: 2183
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.411 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 8.2.1.2

| Member Number: 2184
| Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.980 Critical Load Case: 119 Location: 1.00
| Critical Condition: Sec. 8.2.1.2

STAAD SPACE -- PAGE NO. 443

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2185					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.491	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2186					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2187					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.155	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2188					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.857	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 444

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2189					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.386	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2190					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.834	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2191					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.809	Critical Load Case:	119	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2192					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.295	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 445

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 2193
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.110 Critical Load Case: 119 Location: 1.00
| Critical Condition: Sec. 9.3.1.3

| Member Number: 2194
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.952 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 2195
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.353 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 8.2.1.2

| Member Number: 2196
| Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)
| Status: PASS Ratio: 0.865 Critical Load Case: 119 Location: 2.30
| Critical Condition: Sec. 9.3.2.2

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2197					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.820	Critical Load Case: 119	Location:	2.30	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2198					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.685	Critical Load Case: 119	Location:	2.30	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2199					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.774	Critical Load Case: 119	Location:	2.30	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2200					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.761	Critical Load Case: 119	Location:	2.30	
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2201					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.813	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2202					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.896	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2203					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.461	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2204					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.892	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 448

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2205					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.856	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2206					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.805	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2207					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.758	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2208					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.770	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 449

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2209					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.751	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2210					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.893	Critical Load Case:	119	Location:	2.30
Critical Condition: Sec. 9.3.2.2					

Member Number: 2211					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.248	Critical Load Case:	6	Location:	2.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2212					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.592	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 450

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2213 |
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.873 Critical Load Case: 119 Location: 2.38 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 2214 |
| Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.208 Critical Load Case: 112 Location: 2.38 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 2215 |
| Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.735 Critical Load Case: 119 Location: 1.50 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 2216 |
| Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.650 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.2.2 |

STAAD SPACE -- PAGE NO. 451

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2217					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.688	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2218					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.620	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2219					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.644	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2220					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.681	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 452

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2221					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.737	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 2222					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.478	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2223					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.404	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2224					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.273	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 453

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2225					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.133	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 2226					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.050	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2227					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.200	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2228					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.353	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 454

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2229					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.334	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2230					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.310	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2231					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.333	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2232					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.376	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 455

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2233					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.115	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2234					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.527	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2235					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.286	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2236					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.230	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 456

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2237					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.769	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2238					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.260	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2239					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.218	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2240					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.225	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 457

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2241					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.449	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2242					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.210	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2243					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.189	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2244					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.321	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 458

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2245					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.135	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2246					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.213	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2247					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.140	Critical Load Case:	6	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2248					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.134	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 459

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2249					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.298	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2250					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.523	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2251					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.411	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2252					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.503	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 460

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2253					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.522	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2254					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.399	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2255					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.257	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2256					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.312	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 461

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	2257				
Member Section:	ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.524	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number:	2258				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.191	Critical Load Case:	8	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	2259				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.106	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	2260				
Member Section:	ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.204	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 462

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2261					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.662	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2262					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.445	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2263					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2264					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.688	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 463

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2265					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.416	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2266					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.106	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2267					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.101	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 8.2.1.2					

Member Number: 2268					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.688	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 464

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2269					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.386	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2270					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.052	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2271					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.350	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2272					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.615	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 465

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2273					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.462	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2274					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.102	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2275					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.624	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2276					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.456	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 466

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2277					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.271	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2278					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.229	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2279					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.624	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2280					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.189	Critical Load Case:	8	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 467

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2281					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.221	Critical Load Case:	112	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2282					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	8	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2283					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.571	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2284					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.442	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 468

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2285					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.240	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2286					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.591	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2287					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.411	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2288					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.381	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 469

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2289					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.127	Critical Load Case:	6	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2290					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.590	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2291					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.231	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2292					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.108	Critical Load Case:	6	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 470

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2293					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.436	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2294					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.427	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2295					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.346	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2296					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.333	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 471

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2297					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.425	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2298					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.370	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2299					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.416	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2300					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.420	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2301					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.422	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2302					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.067	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2303					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.201	Critical Load Case:	8	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2304					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.144	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 473

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2305					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.080	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2306					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.048	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2307					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.200	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2308					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.116	Critical Load Case:	111	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 474

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2309					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.121	Critical Load Case:	102	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2310					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.344	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2311					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.297	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2312					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.053	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 475

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2313					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.381	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2314					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.241	Critical Load Case:	114	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2315					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.536	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2316					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.363	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2317					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.315	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2318					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.261	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 2319					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.451	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2320					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.302	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2321					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.347	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2322					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.210	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 8.2.1.2					

Member Number: 2323					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.414	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2324					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.355	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2325					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.085	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2326					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.616	Critical Load Case:	119	Location:	2.12
Critical Condition: Sec. 9.3.2.2					

Member Number: 2327					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.301	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2328					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.173	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 479

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2329					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.214	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2330					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.522	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2331					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.406	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2332					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.375	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 480

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2333					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.441	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2334					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.239	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2335					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.463	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2336					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.221	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 481

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2337					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.444	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2338					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.304	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2339					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.355	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2340					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.427	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 482

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2341					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.335	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2342					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.213	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2343					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.055	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2344					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.258	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 483

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2345					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.808	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2346					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.908	Critical Load Case:	119	Location:	1.84
Critical Condition: Sec. 9.3.2.2					

Member Number: 2347					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.554	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2348					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.505	Critical Load Case:	119	Location:	1.84
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 484

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2349					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2350					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.838	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2351					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.576	Critical Load Case:	119	Location:	2.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2352					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.276	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 485

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2353					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.066	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2354					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.302	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2355					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.366	Critical Load Case:	119	Location:	3.61
Critical Condition: Sec. 9.3.2.2					

Member Number: 2356					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.470	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 486

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2357					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.513	Critical Load Case:	119	Location:	3.10
Critical Condition: Sec. 9.3.2.2					

Member Number: 2358					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.323	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2359					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.650	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2360					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.062	Critical Load Case:	101	Location:	1.81
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 487

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2361					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.086	Critical Load Case:	111	Location:	1.81
Critical Condition: Sec. 8.2.1.2					

Member Number: 2362					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.158	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 2363					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.158	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2364					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.315	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 488

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2365					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.372	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2366					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.085	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2367					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.177	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2368					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.151	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 489

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2369					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.748	Critical Load Case:	119	Location:	1.60
Critical Condition: Sec. 9.3.2.2					

Member Number: 2370					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.272	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2371					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.324	Critical Load Case:	114	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

Member Number: 2372					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.091	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2373					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.099	Critical Load Case:	103	Location:	1.81
Critical Condition: Sec. 8.2.1.2					

Member Number: 2374					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.167	Critical Load Case:	119	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 2375					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.227	Critical Load Case:	114	Location:	2.35
Critical Condition: Sec. 9.3.2.2					

Member Number: 2376					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.087	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 491

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2377					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.371	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2378					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.462	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2379					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.650	Critical Load Case:	119	Location:	3.98
Critical Condition: Sec. 8.2.1.2					

Member Number: 2380					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.628	Critical Load Case:	119	Location:	3.98
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 492

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2381					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.328	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2382					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.195	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2383					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.723	Critical Load Case:	119	Location:	4.26
Critical Condition: Sec. 9.3.2.2					

Member Number: 2384					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.726	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 493

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2385					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.655	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2386					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.683	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2387					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.906	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2388					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.790	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 494

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2389					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.825	Critical Load Case:	119	Location:	5.07
Critical Condition: Sec. 9.3.2.2					

Member Number: 2390					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.641	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2391					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.824	Critical Load Case:	119	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

Member Number: 2392					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.391	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 495

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2393					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.374	Critical Load Case:	112	Location:	3.98
Critical Condition: Sec. 9.3.2.2					

Member Number: 2394					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.066	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2395					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.825	Critical Load Case:	119	Location:	4.26
Critical Condition: Sec. 9.3.2.2					

Member Number: 2396					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.776	Critical Load Case:	119	Location:	4.26
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 496

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	2397				
Member Section:	ST 100X100X6.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.511	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	2398				
Member Section:	ST 100X100X6.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.106	Critical Load Case:	13	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	2399				
Member Section:	ST 72X72X3.2SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.760	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	2400				
Member Section:	ST 72X72X3.2SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.694	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 497

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2401					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.784	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2402					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.823	Critical Load Case:	119	Location:	5.07
Critical Condition: Sec. 9.3.2.2					

Member Number: 2403					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.619	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2404					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.815	Critical Load Case:	119	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 498

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2405					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.125	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2406					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.123	Critical Load Case:	119	Location:	4.37
Critical Condition: Sec. 9.3.2.2					

Member Number: 2407					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.247	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2408					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.740	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 499

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2409					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.085	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2410					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.045	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2411					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.096	Critical Load Case:	102	Location:	3.40
Critical Condition: Sec. 9.3.2.2					

Member Number: 2412					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.148	Critical Load Case:	119	Location:	3.40
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 500

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2413					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.264	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2414					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.405	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2415					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.758	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2416					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.290	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 501

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2417					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.297	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2418					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.934	Critical Load Case:	119	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

Member Number: 2419					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.679	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2420					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.163	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 502

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2421					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.294	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2422					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.921	Critical Load Case:	119	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

Member Number: 2423					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.117	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2424					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.131	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 503

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2425					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.259	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2426					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.551	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2427					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.052	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2428					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.037	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 504

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2429					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.229	Critical Load Case:	112	Location:	3.40
Critical Condition: Sec. 9.3.2.2					

Member Number: 2430					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.471	Critical Load Case:	119	Location:	3.40
Critical Condition: Sec. 9.3.2.2					

Member Number: 2431					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.139	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2432					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.300	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 505

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2433					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.385	Critical Load Case:	119	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

Member Number: 2434					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.190	Critical Load Case:	112	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

Member Number: 2435					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.104	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2436					
Member Section: ST 120X120X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.095	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 506

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2437					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.623	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2438					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.152	Critical Load Case:	114	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

Member Number: 2439					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.339	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2440					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.855	Critical Load Case:	119	Location:	4.44
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 507

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2441					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.745	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2442					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.685	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2447					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.465	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2448					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.895	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 508

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	2449				
Member Section:	ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.856	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number:	2450				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.394	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number:	2451				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.393	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number:	2452				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.515	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 509

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2453					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.535	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2454					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.537	Critical Load Case:	112	Location:	0.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2455					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.757	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2456					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.549	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 510

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2457					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.559	Critical Load Case:	112	Location:	0.88
Critical Condition: Sec. 9.3.1.3					

Member Number: 2458					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.847	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2459					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.552	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2460					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.544	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 511

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2461					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.862	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2462					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.487	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2463					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.789	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2464					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.997	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 512

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2465					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.893	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2466					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.463	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2467					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.564	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2468					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.788	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 513

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2469					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.476	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2470					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.690	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2471					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.531	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2472					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.546	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 514

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2473					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.758	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2474					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.569	Critical Load Case:	114	Location:	0.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2475					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.548	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2476					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.707	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 515

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2477					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.527	Critical Load Case:	114	Location:	1.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2478					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.523	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2479					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.647	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2480					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.357	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 516

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2481					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.358	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2482					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.458	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2483					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.746	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2484					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.979	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 517

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2485 |
| Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 1.024 Critical Load Case: 119 Location: 1.50 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 2486 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.325 Critical Load Case: 112 Location: 1.50 |
| Critical Condition: Sec. 9.3.1.3 |

|---|
| Member Number: 2487 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.324 Critical Load Case: 112 Location: 0.00 |
| Critical Condition: Sec. 9.3.1.3 |

|---|
| Member Number: 2488 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.485 Critical Load Case: 112 Location: 1.50 |
| Critical Condition: Sec. 9.3.1.3 |

STAAD SPACE -- PAGE NO. 518

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2489					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.632	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2490					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.632	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2491					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.854	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2492					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.740	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 519

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2493					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.743	Critical Load Case:	112	Location:	0.38
Critical Condition: Sec. 9.3.1.3					

Member Number: 2494					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.795	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2495					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.793	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2496					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.785	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 520

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2497					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.852	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2498					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.925	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2499					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.914	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

* Member Number: 2500					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.083	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 521

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2501					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.979	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2502					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.745	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2503					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.844	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2504					
Member Section: ST 150X150X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.914	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 522

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2505					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.918	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2506					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.975	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2507					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.771	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2508					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.791	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 523

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	2509				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.984	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number:	2510				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.733	Critical Load Case:	114	Location:	1.13
Critical Condition: Sec. 9.3.1.3					

Member Number:	2511				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.729	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number:	2512				
Member Section:	ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.875	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 524

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2513					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.620	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2514					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.621	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2515					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.718	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

Member Number: 2516					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.340	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 525

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2517					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.340	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.1.3					

Member Number: 2518					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.428	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.3					

* Member Number: 2519					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2520					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.274	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 526

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2521 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2522 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.279 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

|---|
|* Member Number: 2523 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 6 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2524 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.313 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 8.2.1.2

STAAD SPACE -- PAGE NO. 527

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2525 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 6 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2526 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.265 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

|---|
|* Member Number: 2527 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2528 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.284 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

STAAD SPACE -- PAGE NO. 528

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 2529					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2530					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.334	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2531					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2532					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.208	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 529

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2533 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2534 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.246 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

|---|
|* Member Number: 2535 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 6 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2536 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.326 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

STAAD SPACE -- PAGE NO. 530

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 2537					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2538					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.120	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2539					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2540					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.199	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 531

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number:	2541				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number:	2542				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: PASS	Ratio: 0.282	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

* Member Number:	2543				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number:	2544				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: PASS	Ratio: 0.080	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 532

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2545 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2546 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.164 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

|---|
|* Member Number: 2547 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 2.744 Critical Load Case: 112 Location: 0.00 |
Critical Condition: Sec. 7.1.2

|---|
| Member Number: 2548 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.408 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 8.2.1.2

STAAD SPACE -- PAGE NO. 533

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2549 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 2.776 Critical Load Case: 112 Location: 0.00 |
Critical Condition: Sec. 7.1.2

|---|
| Member Number: 2550 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.333 Critical Load Case: 112 Location: 1.50 |
Critical Condition: Sec. 9.3.2.2

|---|
|* Member Number: 2551 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2552 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.141 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 2553					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	7	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2554					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.137	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number: 2555					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	7	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2556					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.133	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 535

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2557 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2558 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.138 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

|---|
|* Member Number: 2559 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 2.791 Critical Load Case: 114 Location: 0.00 |
Critical Condition: Sec. 7.1.2

|---|
| Member Number: 2560 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.337 Critical Load Case: 114 Location: 1.50 |
Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 536

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2561 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 2.748 Critical Load Case: 114 Location: 0.00 |
Critical Condition: Sec. 7.1.2

|---|
| Member Number: 2562 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.402 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 8.2.1.2

|---|
|* Member Number: 2563 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2564 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.161 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 537

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number:	2565				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number:	2566				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: PASS	Ratio: 0.081	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

* Member Number:	2567				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number:	2568				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: PASS	Ratio: 0.271	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 538

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2569 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2570 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.196 Critical Load Case: 119 Location: 0.00 |
Critical Condition: Sec. 9.3.2.2

|---|
|* Member Number: 2571 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 6 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2572 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.115 Critical Load Case: 114 Location: 1.50 |
Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 539

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2573 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 6 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2574 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.322 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

|---|
|* Member Number: 2575 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2576 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.239 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

STAAD SPACE -- PAGE NO. 540

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 2577					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2578					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.204	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2579					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2580					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.321	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 541

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 2581						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00	
Critical Condition: SLENDERNESS						

Member Number: 2582						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: PASS	Ratio: 0.273	Critical Load Case:	119	Location:	1.50	
Critical Condition: Sec. 8.2.1.2						

* Member Number: 2583						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00	
Critical Condition: SLENDERNESS						

Member Number: 2584						
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)						
Status: PASS	Ratio: 0.261	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2						

STAAD SPACE -- PAGE NO. 542

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number: 2585					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2586					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.305	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2587					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2588					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.277	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 543

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

* Member Number:	2589				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number:	2590				
Member Section:	ST 96X48X4.8RHS	(TATA STRUCTURA SECTIONS)			
Status: PASS	Ratio: 0.275	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number:	2591				
Member Section:	ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.181	Critical Load Case:	102	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

Member Number:	2592				
Member Section:	ST 150X150X4.5SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.217	Critical Load Case:	119	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

STAAD SPACE -- PAGE NO. 544

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 2593 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 7 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2594 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: PASS Ratio: 0.262 Critical Load Case: 119 Location: 1.50 |
Critical Condition: Sec. 8.2.1.2

|---|
|* Member Number: 2595 |
| Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS) |
| Status: FAIL Ratio: 1.424 Critical Load Case: 1 Location: 0.00 |
Critical Condition: SLENDERNESS

|---|
| Member Number: 2596 |
| Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.137 Critical Load Case: 114 Location: 1.81 |
Critical Condition: Sec. 9.3.1.3

STAAD SPACE -- PAGE NO. 545

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2597					
Member Section: ST 150X150X4.5SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.212	Critical Load Case:	114	Location:	1.81
Critical Condition: Sec. 9.3.1.3					

* Member Number: 2598					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	6	Location:	0.00
Critical Condition: SLENDERNESS					

Member Number: 2599					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: PASS	Ratio: 0.263	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

* Member Number: 2600					
Member Section: ST 96X48X4.8RHS (TATA STRUCTURA SECTIONS)					
Status: FAIL	Ratio: 1.424	Critical Load Case:	1	Location:	0.00
Critical Condition: SLENDERNESS					

STAAD SPACE -- PAGE NO. 546

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2601					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.753	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2602					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.753	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2603					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.859	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2604					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.295	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 547

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2605					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.256	Critical Load Case:	119	Location:	0.88
Critical Condition: Sec. 9.3.2.2					

Member Number: 2606					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.380	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2607					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.578	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2608					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.573	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 548

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2609					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.686	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2610					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.747	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2611					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.734	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2612					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.876	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 549

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2613					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.615	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2614					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.611	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2615					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.703	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2616					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.693	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 550

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2617					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.686	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2618					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.813	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2619					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.734	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2620					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.730	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 551

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2621					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.852	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2622					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.756	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2623					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.751	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2624					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.890	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 552

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2625					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.706	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2626					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.702	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2627					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.842	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2628					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.633	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 553

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2629					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.634	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2630					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.757	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2631					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.806	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2632					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.807	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2633					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.968	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2634					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.592	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2635					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.601	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2636					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.781	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 555

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2637					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.387	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2638					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.385	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2639					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.493	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2640					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.114	Critical Load Case:	102	Location:	1.38
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 556

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2641					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.114	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2642					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.213	Critical Load Case:	101	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2643					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.766	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2644					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.774	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 557

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2645					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.823	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2646					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.429	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2647					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.408	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2648					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.547	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 558

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2649					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.763	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2650					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.756	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2651					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.860	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2652					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.668	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 559

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2653					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.654	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2654					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.736	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2655					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.756	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2656					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.747	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2657					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.826	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2658					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.800	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2659					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.794	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2660					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.871	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 561

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2661					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.792	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2662					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.798	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2663					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.867	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2664					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.773	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 562

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2665					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.766	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2666					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.837	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2667					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.754	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2668					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.750	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 563

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2669					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.816	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2670					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.702	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2671					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.710	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2672					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.775	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 564

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2673					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.925	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2674					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.923	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

* Member Number: 2675					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: FAIL	Ratio: 1.005	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2676					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.688	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 565

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2677					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.687	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2678					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.756	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2679					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.363	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2680					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.354	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 566

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2681					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.398	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2682					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.182	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2683					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.182	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2684					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.216	Critical Load Case:	101	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 567

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2769					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.080	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2770					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.124	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2771					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.368	Critical Load Case:	119	Location:	0.67
Critical Condition: Sec. 8.2.1.2					

Member Number: 2772					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.343	Critical Load Case:	119	Location:	0.67
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 568

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2773					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.323	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

Member Number: 2774					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.322	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

Member Number: 2775					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.326	Critical Load Case:	119	Location:	1.68
Critical Condition: Sec. 6.3					

Member Number: 2776					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.320	Critical Load Case:	119	Location:	1.68
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 569

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2785					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

Member Number: 2786					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.425	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

Member Number: 2787					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	119	Location:	0.71
Critical Condition: Sec. 6.3					

Member Number: 2788					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.425	Critical Load Case:	119	Location:	0.71
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 570

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2789					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.559	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

Member Number: 2790					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.627	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 6.3					

Member Number: 2791					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.559	Critical Load Case:	119	Location:	1.68
Critical Condition: Sec. 6.3					

Member Number: 2792					
Member Section: ST 180X180X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.627	Critical Load Case:	119	Location:	1.68
Critical Condition: Sec. 6.3					

STAAD SPACE -- PAGE NO. 571

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|* Member Number: 2801
| Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)
| Status: FAIL Ratio: 1.847 Critical Load Case: 101 Location: 0.00
| Critical Condition: Sec. 9.3.1.1

| Member Number: 2802
| Member Section: FR ISMC150 (INDIAN SECTIONS)
| Status: PASS Ratio: 0.528 Critical Load Case: 119 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 2803
| Member Section: FR ISMC150 (INDIAN SECTIONS)
| Status: PASS Ratio: 0.217 Critical Load Case: 112 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

| Member Number: 2804
| Member Section: FR ISMC150 (INDIAN SECTIONS)
| Status: PASS Ratio: 0.751 Critical Load Case: 112 Location: 0.00
| Critical Condition: Sec. 9.3.2.2

STAAD SPACE -- PAGE NO. 572

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2805						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.566	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 6.2						

Member Number: 2806						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.663	Critical Load Case:	114	Location:	0.00	
Critical Condition: Sec. 9.3.2.2						

* Member Number: 2807						
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)				
Status: FAIL	Ratio: 1.542	Critical Load Case:	101	Location:	0.00	
Critical Condition: Sec. 9.3.1.1						

Member Number: 2808						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.435	Critical Load Case:	114	Location:	0.00	
Critical Condition: Sec. 9.3.2.2						

STAAD SPACE -- PAGE NO. 573

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2809					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.561	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2810					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.922	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2811					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.760	Critical Load Case:	101	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2812					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.482	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 574

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2813					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.918	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2814					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.536	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2815					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.834	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2816					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.683	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 575

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2817					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.661	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2818					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.502	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2819					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.706	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2820					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.824	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 576

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2821					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.786	Critical Load Case:	102	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2822					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.737	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2823					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.945	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 2824					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.565	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 577

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2825					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.450	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2826					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.371	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2827					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.277	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2828					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	112	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 578

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2829					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.456	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2830					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.517	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2831					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.507	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2832					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.349	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 579

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2833					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.363	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2834					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.241	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2835					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.188	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2836					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.280	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 580

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2837					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.283	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2838					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.409	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2839					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.491	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2840					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.459	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 581

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2841					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.290	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2842					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.346	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2843					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.299	Critical Load Case:	114	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 2844					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.334	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 582

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2845					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.172	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2846					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.501	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2847					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.338	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2848					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.221	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 583

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2849					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.184	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2850					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.246	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2851					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.401	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2852					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.213	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 584

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2853					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.354	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2854					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.559	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2855					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.287	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2856					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.367	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 585

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2857					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 2858					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.430	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2859					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.274	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2860					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.281	Critical Load Case:	101	Location:	1.85
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 586

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2861						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.236	Critical Load Case:	101	Location:	1.50	
Critical Condition: Sec. 9.3.2.2						

Member Number: 2862						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.349	Critical Load Case:	101	Location:	0.50	
Critical Condition: Sec. 9.3.2.2						

Member Number: 2863						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.278	Critical Load Case:	101	Location:	1.50	
Critical Condition: Sec. 9.3.2.2						

Member Number: 2864						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.222	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2						

STAAD SPACE -- PAGE NO. 587

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2865					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.219	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2866					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.200	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2867					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.157	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2868					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.188	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 588

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2869						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.566	Critical Load Case:	112	Location:	2.71	
Critical Condition: Sec. 9.3.2.2						

Member Number: 2870						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.403	Critical Load Case:	112	Location:	1.50	
Critical Condition: Sec. 9.3.2.2						

Member Number: 2871						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.229	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 6.2						

Member Number: 2872						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.212	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 6.2						

STAAD SPACE -- PAGE NO. 589

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2873						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.205	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 6.2						

Member Number: 2874						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.222	Critical Load Case:	101	Location:	1.36	
Critical Condition: Sec. 9.3.1.1						

Member Number: 2875						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.184	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 6.2						

Member Number: 2876						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.531	Critical Load Case:	119	Location:	0.00	
Critical Condition: Sec. 6.2						

STAAD SPACE -- PAGE NO. 590

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2877					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.530	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

Member Number: 2878					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.527	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

Member Number: 2879					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.525	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

Member Number: 2880					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.522	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 591

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2881					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.520	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2882					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.512	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2883					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.538	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2884					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.814	Critical Load Case:	119	Location:	3.29
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 592

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2885					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.566	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2886					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.557	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2887					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.561	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2888					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.563	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 593

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2889					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.564	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2890					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.564	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2891					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.566	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2892					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.378	Critical Load Case:	114	Location:	1.81
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 594

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2893					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.340	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

Member Number: 2894					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.353	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

Member Number: 2895					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.359	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

Member Number: 2896					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.363	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 595

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2897					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.376	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2898					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.477	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2899					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.321	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2900					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.324	Critical Load Case:	101	Location:	1.84
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 596

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2901					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.195	Critical Load Case: 101	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2902					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.266	Critical Load Case: 101	Location:	1.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2903					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.162	Critical Load Case: 101	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2904					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.102	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 597

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2905					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.092	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2906					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.067	Critical Load Case: 101	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 2907					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.067	Critical Load Case: 103	Location:	0.00	
Critical Condition: Sec. 9.3.1.1					

Member Number: 2908					
Member Section: FR ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.125	Critical Load Case: 106	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 598

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2909					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.291	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2910					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.281	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2911					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.597	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2912					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.276	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 599

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2913					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.947	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2914					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.231	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2915					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.567	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2916					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.530	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 600

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2917					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.282	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2918					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2919					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.319	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2920					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.182	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 601

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2921					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.058	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2922					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.220	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2923					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.048	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2924					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.220	Critical Load Case:	114	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 602

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2925					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.054	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2926					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.213	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2927					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.278	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2928					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.132	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 603

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2929					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.034	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2930					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.139	Critical Load Case:	112	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2931					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.012	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 2932					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.174	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 604

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2933					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.023	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2934					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.331	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2935					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.330	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.3					

Member Number: 2936					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.391	Critical Load Case:	102	Location:	1.49
Critical Condition: Sec. 8.2.1.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2937					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.838	Critical Load Case: 119	Location:	1.49	
Critical Condition: Sec. 6.3					

Member Number: 2938					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.838	Critical Load Case: 119	Location:	1.49	
Critical Condition: Sec. 6.3					

Member Number: 2939					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.868	Critical Load Case: 119	Location:	1.49	
Critical Condition: Sec. 6.3					

Member Number: 2940					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.277	Critical Load Case: 102	Location:	0.00	
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 606

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2941					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.088	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2942					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.596	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2943					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.103	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2944					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.598	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 607

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2945					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.105	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2946					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.811	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2947					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.556	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2948					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.810	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 608

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2949					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.041	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2950					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.866	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2951					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.106	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2952					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.867	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 609

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2953					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.089	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2954					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.624	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 2955					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.442	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2956					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.586	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 610

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2957					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.466	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2958					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.159	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2959					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.124	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2960					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.138	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 611

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2961					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.244	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2962					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.320	Critical Load Case:	112	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 2963					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.439	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 2964					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.308	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 612

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2965					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.483	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 2966					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.187	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2967					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.131	Critical Load Case:	114	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 2968					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.113	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 613

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2969					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.140	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2970					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.403	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2971					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.128	Critical Load Case:	114	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2972					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.229	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 614

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2973					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.109	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2974					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.078	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2975					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.232	Critical Load Case:	114	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2976					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.089	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 615

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2977					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.367	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2978					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.727	Critical Load Case:	114	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2979					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.099	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 2980					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.716	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 616

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2981					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.071	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2982					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.401	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2983					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.352	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2984					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.092	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 617

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2985					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.304	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 2986					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.351	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

Member Number: 2987					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.059	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2988					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.039	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 618

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2989					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.253	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 8.2.1.2					

Member Number: 2990					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.111	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 2991					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.586	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2992					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.677	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 619

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2993					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.536	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2994					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.680	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2995					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.595	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 2996					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.464	Critical Load Case:	112	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 620

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 2997					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.534	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 2998					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.522	Critical Load Case:	112	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 2999					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.370	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3000					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.600	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 621

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3001					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.092	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

Member Number: 3002					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.077	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3003					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.624	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3004					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.082	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3005					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.092	Critical Load Case: 119	Location:	1.49	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3006					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.419	Critical Load Case: 102	Location:	1.49	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3007					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.101	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3008					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.418	Critical Load Case: 102	Location:	1.49	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 623

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3009					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.067	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3010					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.863	Critical Load Case:	119	Location:	1.49
Critical Condition: Sec. 9.3.2.2					

Member Number: 3011					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.786	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3012					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.134	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 624

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3013					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.308	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3014					
Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.739	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3015					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.116	Critical Load Case: 119	Location:	1.50	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3016					
Member Section: ST 72X72X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.398	Critical Load Case: 119	Location:	1.49	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 625

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
|* Member Number: 3017 |
| Member Section: ST 100X100X6.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: FAIL Ratio: 2.000 Critical Load Case: 119 Location: 0.00 |
| Critical Condition: Sec. 9.3.1.1 |

|---|
| Member Number: 3018 |
| Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.134 Critical Load Case: 119 Location: 1.50 |
| Critical Condition: Sec. 8.2.1.2 |

|---|
| Member Number: 3019 |
| Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.578 Critical Load Case: 114 Location: 2.11 |
| Critical Condition: Sec. 9.3.2.2 |

|---|
| Member Number: 3020 |
| Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.593 Critical Load Case: 119 Location: 2.11 |
| Critical Condition: Sec. 9.3.2.2 |

STAAD SPACE -- PAGE NO. 626

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3021					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.554	Critical Load Case:	114	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 3022					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.564	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 3023					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.892	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 3024					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.552	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 6.2					

STAAD SPACE -- PAGE NO. 627

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3025					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.886	Critical Load Case:	119	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 3026					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.553	Critical Load Case:	112	Location:	2.11
Critical Condition: Sec. 9.3.2.2					

Member Number: 3027					
Member Section: ST 72X72X3.2SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.677	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 3028					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.360	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 628

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3029					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.175	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3030					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.896	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3031					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.174	Critical Load Case: 102	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3032					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.159	Critical Load Case: 102	Location:	0.00	
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 629

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number:	3033				
Member Section:	ST	150X150X5.0SHS	(APL APOLLOTUBE SECTIONS)		
Status: PASS	Ratio:	0.218	Critical Load Case: 119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number:	3034				
Member Section:	ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)		
Status: PASS	Ratio:	0.186	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number:	3035				
Member Section:	FR	ISMC150	(INDIAN SECTIONS)		
Status: PASS	Ratio:	0.272	Critical Load Case: 119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number:	3036				
Member Section:	ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)		
Status: PASS	Ratio:	0.137	Critical Load Case: 119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 630

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3037					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.093	Critical Load Case: 112	Location:	0.00	
Critical Condition: Sec. 9.3.1.1					

Member Number: 3038					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.328	Critical Load Case: 119	Location:	0.75	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3039					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.269	Critical Load Case: 101	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3040					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.164	Critical Load Case: 111	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 631

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3041					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 3042					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.193	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 3043					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.123	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3044					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 632

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3045					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.297	Critical Load Case: 103	Location:	0.00	
Critical Condition: Sec. 9.3.1.1					

Member Number: 3046					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.854	Critical Load Case: 119	Location:	0.75	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3047					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.275	Critical Load Case: 119	Location:	0.75	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3048					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.181	Critical Load Case: 101	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 633

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3049					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.690	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3050					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.202	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3051					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.124	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3052					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.682	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 634

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3053					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.127	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 3054					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.114	Critical Load Case:	104	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3055					
Member Section: ST 150X150X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.855	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3056					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.186	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 635

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3057					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.202	Critical Load Case:	104	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3058					
Member Section: ST	150X150X8.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.507	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3059					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.322	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3060					
Member Section: ST	150X150X5.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.206	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 636

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3061					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.292	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3062					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.177	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3063					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.372	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3064					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.182	Critical Load Case:	114	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 637

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3065					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.268	Critical Load Case: 119	Location:	1.81	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3066					
Member Section: ST	150X150X8.0SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.575	Critical Load Case: 119	Location:	0.75	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3067					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.322	Critical Load Case: 112	Location:	1.12	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3068					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.178	Critical Load Case: 114	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 638

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3069						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.238	Critical Load Case:	106	Location:	0.00	
Critical Condition: Sec. 9.3.2.2						

Member Number: 3070						
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.276	Critical Load Case:	102	Location:	0.00	
Critical Condition: Sec. 8.2.1.2						

Member Number: 3071						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.122	Critical Load Case:	112	Location:	1.00	
Critical Condition: Sec. 9.3.2.2						

Member Number: 3072						
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.362	Critical Load Case:	102	Location:	0.00	
Critical Condition: Sec. 8.2.1.2						

STAAD SPACE -- PAGE NO. 639

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3073					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.118	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3074					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.174	Critical Load Case:	112	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3075					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.276	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 3076					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.117	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 640

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3077					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.176	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 3078					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.120	Critical Load Case:	112	Location:	0.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3079					
Member Section: ST 220X220X8.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.906	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3080					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.158	Critical Load Case:	102	Location:	1.50
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 641

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3081					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.238	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3082					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.236	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 3083					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.200	Critical Load Case:	101	Location:	0.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3084					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.230	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 642

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3085					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.099	Critical Load Case:	102	Location:	0.00
Critical Condition: Sec. 9.3.1.1					

Member Number: 3086					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.164	Critical Load Case:	111	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3087					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.135	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3088					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.068	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 643

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3089					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.169	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3090					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.114	Critical Load Case:	103	Location:	1.50
Critical Condition: Sec. 9.3.1.1					

Member Number: 3091					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.190	Critical Load Case:	111	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3092					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.187	Critical Load Case:	112	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 644

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3093						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.153	Critical Load Case:	112	Location:	0.00	
Critical Condition: Sec. 9.3.2.2						

Member Number: 3094						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.203	Critical Load Case:	106	Location:	1.50	
Critical Condition: Sec. 9.3.2.2						

Member Number: 3095						
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)				
Status: PASS	Ratio: 0.230	Critical Load Case:	101	Location:	0.00	
Critical Condition: Sec. 8.2.1.2						

Member Number: 3096						
Member Section: FR	ISMC150	(INDIAN SECTIONS)				
Status: PASS	Ratio: 0.180	Critical Load Case:	101	Location:	0.50	
Critical Condition: Sec. 9.3.2.2						

STAAD SPACE -- PAGE NO. 645

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3097					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.128	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 9.3.2.2					

Member Number: 3098					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.088	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3099					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.118	Critical Load Case:	106	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3100					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.149	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 646

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3101					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.046	Critical Load Case:	111	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3102					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.133	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3103					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.071	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.1.1					

Member Number: 3104					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.108	Critical Load Case:	114	Location:	1.50
Critical Condition: Sec. 9.3.1.1					

STAAD SPACE -- PAGE NO. 647

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3105					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.150	Critical Load Case:	111	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3106					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.061	Critical Load Case:	111	Location:	0.37
Critical Condition: Sec. 9.3.1.1					

Member Number: 3107					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.196	Critical Load Case:	119	Location:	0.75
Critical Condition: Sec. 8.2.1.2					

Member Number: 3108					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.044	Critical Load Case:	111	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 648

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3109					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.127	Critical Load Case: 102	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3110					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.230	Critical Load Case: 101	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3111					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.089	Critical Load Case: 101	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3112					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.271	Critical Load Case: 119	Location:	0.75	
Critical Condition: Sec. 8.2.1.2					

STAAD SPACE -- PAGE NO. 649

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3113					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.180	Critical Load Case: 101	Location:	1.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3114					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.182	Critical Load Case: 101	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3115					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.179	Critical Load Case: 119	Location:	0.00	
Critical Condition: Sec. 8.2.1.2					

Member Number: 3116					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.157	Critical Load Case: 114	Location:	1.50	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 650

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3117					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.298	Critical Load Case: 103	Location:	1.88	
Critical Condition: Sec. 9.3.1.1					

Member Number: 3118					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.144	Critical Load Case: 114	Location:	0.00	
Critical Condition: Sec. 9.3.2.2					

Member Number: 3119					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.115	Critical Load Case: 103	Location:	0.00	
Critical Condition: Sec. 9.3.1.1					

Member Number: 3120					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.201	Critical Load Case: 119	Location:	0.75	
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 651

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3121					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.065	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3122					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.121	Critical Load Case:	111	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3123					
Member Section: ST	50X50X3.6SHS	(APL APOLLOTUBE SECTIONS)			
Status: PASS	Ratio: 0.239	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 3124					
Member Section: FR	ISMC150	(INDIAN SECTIONS)			
Status: PASS	Ratio: 0.128	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 652

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

Member Number: 3125					
Member Section: ST 50X50X3.6SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.267	Critical Load Case:	101	Location:	0.00
Critical Condition: Sec. 8.2.1.2					

Member Number: 3126					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.199	Critical Load Case:	101	Location:	1.00
Critical Condition: Sec. 9.3.2.2					

Member Number: 3127					
Member Section: FR ISMC150 (INDIAN SECTIONS)					
Status: PASS	Ratio: 0.214	Critical Load Case:	119	Location:	1.50
Critical Condition: Sec. 9.3.2.2					

Member Number: 3128					
Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS)					
Status: PASS	Ratio: 0.249	Critical Load Case:	119	Location:	0.00
Critical Condition: Sec. 9.3.2.2					

STAAD SPACE -- PAGE NO. 653

STAAD.PRO CODE CHECKING - IS-800-2007-LSD (V2.1)
****

|---|
| Member Number: 3129 |
| Member Section: FR ISMC150 (INDIAN SECTIONS) |
| Status: PASS Ratio: 0.295 Critical Load Case: 119 Location: 1.81 |
Critical Condition: Sec. 9.3.2.2

|---|
| Member Number: 3130 |
| Member Section: ST 150X150X5.0SHS (APL APOLLOTUBE SECTIONS) |
| Status: PASS Ratio: 0.501 Critical Load Case: 119 Location: 3.84 |
Critical Condition: Sec. 9.3.2.2

1820. STEEL MEMBER TAKE OFF LIST 1 TO 4 16 19 TO 36 73 TO 79 81 TO 83 118 TO 137 -

STAAD SPACE -- PAGE NO. 654

STEEL TAKE OFF

STEEL TAKE-OFF

PROFILE	LENGTH(METE)	WEIGHT(KN)

1821. 174 TO 201 306 TO 335 338 TO 349 522 TO 524 527 TO 531 629 630 649 TO 663 -
1822. 676 TO 687 720 721 728 TO 731 734 735 748 749 762 TO 765 779 TO 806 846 847 -
1823. 881 899 TO 903 909 TO 957 968 TO 995 1000 TO 1041 1092 TO 1094 1097 TO 1101 -
1824. 1181 1182 1210 TO 1215 1221 1223 1225 1227 1245 TO 1268 1281 1283 TO 1285 -
1825. 1287 TO 1372 1385 1386 1423 TO 1432 1481 TO 1489 1491 1493 1495 1497 TO 1516 -
1826. 1552 1554 1556 1558 1560 TO 1579 1610 TO 1616 1620 TO 1625 1633 1634 1636 -
1827. 1637 1639 1640 1646 1647 1649 1650 1652 1653 1659 1660 1662 1663 1665 1666 -
1828. 1672 1673 1675 1676 1678 1679 1685 1686 1688 1689 1691 1692 1698 1699 1701 -
1829. 1702 1704 1705 1711 1712 1714 1715 1717 1718 1724 1725 1727 1728 1730 1731 -
1830. 1737 1738 1740 1741 1743 1744 1750 1751 1753 1754 1756 1757 1763 1764 1766 -
1831. 1767 1769 1770 1776 TO 1779 1781 1784 TO 1792 1796 1797 1799 1800 1802 1803 -
1832. 1809 1810 1812 1813 1815 1816 1822 1823 1825 1826 1830 1831 1833 1834 1836 -
1833. 1837 1843 1844 1846 1847 1849 1850 1858 1859 1861 1862 1864 1865 1871 1872 -
1834. 1874 1875 1877 1878 1884 1885 1887 1888 1892 1893 1895 1896 1898 1899 1905 -
1835. 1906 1908 1909 1911 1912 1918 1919 1921 TO 1923 1926 1927 1930 TO 1933 2405 -
1836. 2406 TO 2442 2447 TO 2518 3029 3032 3033 3035 3037 3038 3040 3041 3043 3045 -
1837. 3046 3048 3049 3051

ST	150X150X5.0SHS	390.22	85.012
ST	140X140X5.0SHS	403.80	81.767
ST	180X180X5.0SHS	50.96	13.452
ST	150X150X8.0SHS	102.63	34.525
ST	TUB E	72.57	83.485
ST	150X150X4.5SHS	284.45	56.091
ST	180X180X8.0SHS	176.28	72.299
ST	150X150X6.0SHS	43.64	11.274
ST	TUB E	18.32	30.529
ST	250X250X10.0SHS	32.68	23.451
ST	120X120X6.0SHS	199.26	40.457
ST	180X180X6.0SHS	117.05	36.714
ST	220X220X8.0SHS	57.21	29.090
ST	100X100X6.0SHS	13.29	2.208
ST	50X50X3.6SHS	61.91	3.020
ST	72X72X5.0SHS	39.69	3.890
FR	ISMC150	14.19	4.644
	TOTAL =		611.907

MEMBER	PROFILE	LENGTH (METE)	WEIGHT (KN)
1	ST 150X150X5.0SHS	4.18	0.910
2	ST 150X150X5.0SHS	4.18	0.910
3	ST 150X150X5.0SHS	4.18	0.910
4	ST 150X150X5.0SHS	4.18	0.910
16	ST 150X150X5.0SHS	3.05	0.664
19	ST 150X150X5.0SHS	3.05	0.664
20	ST 140X140X5.0SHS	1.35	0.274

STAAD SPACE -- PAGE NO. 655

21	ST	140X140X5.0SHS	1.81	0.367
22	ST	140X140X5.0SHS	1.34	0.271
23	ST	140X140X5.0SHS	1.50	0.304
24	ST	180X180X5.0SHS	2.30	0.606
25	ST	140X140X5.0SHS	1.50	0.304
26	ST	140X140X5.0SHS	1.50	0.304
27	ST	140X140X5.0SHS	1.50	0.304
28	ST	140X140X5.0SHS	1.50	0.304
29	ST	140X140X5.0SHS	1.50	0.304
30	ST	140X140X5.0SHS	1.81	0.367
31	ST	140X140X5.0SHS	1.50	0.304
32	ST	140X140X5.0SHS	1.50	0.304
33	ST	140X140X5.0SHS	1.50	0.304
34	ST	140X140X5.0SHS	1.50	0.304
35	ST	140X140X5.0SHS	1.50	0.304
36	ST	140X140X5.0SHS	1.50	0.304
73	ST	150X150X5.0SHS	4.37	0.953
74	ST	150X150X5.0SHS	1.50	0.327
75	ST	150X150X5.0SHS	1.50	0.327
76	ST	150X150X5.0SHS	4.37	0.953
77	ST	150X150X8.0SHS	1.35	0.455
78	ST	150X150X8.0SHS	1.81	0.610
79	ST	150X150X8.0SHS	1.34	0.450
81	ST	TUB E	1.81	2.085
82	ST	140X140X5.0SHS	1.50	0.304
83	ST	TUB E	1.81	2.085
118	ST	140X140X5.0SHS	1.50	0.304
119	ST	150X150X4.5SHS	1.81	0.357
120	ST	140X140X5.0SHS	1.50	0.304
121	ST	150X150X4.5SHS	1.81	0.357
122	ST	140X140X5.0SHS	1.88	0.380
123	ST	150X150X8.0SHS	1.81	0.610
124	ST	140X140X5.0SHS	1.50	0.304
125	ST	180X180X8.0SHS	1.81	0.743
126	ST	140X140X5.0SHS	1.50	0.304
127	ST	180X180X8.0SHS	1.81	0.743
128	ST	140X140X5.0SHS	1.50	0.304
129	ST	180X180X8.0SHS	1.81	0.743
130	ST	140X140X5.0SHS	1.50	0.304
131	ST	180X180X8.0SHS	1.81	0.743
132	ST	140X140X5.0SHS	1.12	0.228
133	ST	150X150X6.0SHS	1.81	0.468
134	ST	140X140X5.0SHS	1.50	0.304
135	ST	150X150X4.5SHS	1.81	0.357
136	ST	140X140X5.0SHS	1.81	0.367
137	ST	150X150X4.5SHS	1.81	0.357
174	ST	TUB E	4.58	7.632
175	ST	250X250X10.0SHS	4.57	3.283
176	ST	150X150X5.0SHS	4.18	0.910
177	ST	150X150X5.0SHS	4.17	0.910
178	ST	150X150X5.0SHS	4.18	0.910
179	ST	150X150X5.0SHS	4.18	0.910
180	ST	150X150X5.0SHS	4.17	0.910
181	ST	150X150X5.0SHS	4.18	0.910
182	ST	150X150X5.0SHS	3.50	0.763
183	ST	150X150X5.0SHS	4.85	1.056

184	ST	150X150X5.0SHS	4.18	0.910
185	ST	150X150X5.0SHS	3.50	0.763
186	ST	150X150X5.0SHS	4.85	1.056
187	ST	150X150X5.0SHS	4.18	0.910
188	ST	150X150X5.0SHS	2.71	0.589
189	ST	150X150X5.0SHS	2.71	0.589
190	ST	150X150X5.0SHS	2.71	0.589
191	ST	150X150X5.0SHS	2.67	0.583
192	ST	150X150X5.0SHS	2.67	0.583
193	ST	150X150X5.0SHS	2.67	0.583
194	ST	120X120X6.0SHS	4.96	1.007
195	ST	120X120X6.0SHS	5.54	1.124
196	ST	120X120X6.0SHS	4.41	0.895
197	ST	120X120X6.0SHS	4.96	1.007
198	ST	120X120X6.0SHS	4.97	1.010
199	ST	120X120X6.0SHS	4.97	1.010
200	ST	120X120X6.0SHS	4.97	1.010
201	ST	120X120X6.0SHS	4.97	1.010
306	ST	150X150X4.5SHS	2.71	0.534
307	ST	150X150X4.5SHS	1.50	0.296
308	ST	150X150X4.5SHS	1.81	0.358
309	ST	150X150X4.5SHS	1.50	0.296
310	ST	150X150X4.5SHS	1.50	0.296
311	ST	150X150X4.5SHS	1.50	0.296
312	ST	150X150X4.5SHS	1.50	0.296
313	ST	150X150X4.5SHS	1.50	0.296
314	ST	150X150X8.0SHS	1.50	0.505
315	ST	150X150X5.0SHS	3.08	0.671
316	ST	150X150X4.5SHS	2.30	0.453
317	ST	150X150X5.0SHS	2.30	0.500
318	ST	150X150X8.0SHS	2.30	0.773
319	ST	180X180X8.0SHS	2.30	0.942
320	ST	180X180X8.0SHS	2.30	0.942
321	ST	TUB E	2.30	2.642
322	ST	150X150X6.0SHS	1.50	0.388
323	ST	150X150X4.5SHS	1.50	0.296
324	ST	150X150X4.5SHS	1.50	0.296
325	ST	150X150X4.5SHS	1.50	0.296
326	ST	150X150X4.5SHS	1.50	0.296
327	ST	150X150X4.5SHS	1.81	0.358
328	ST	150X150X4.5SHS	2.67	0.527
329	ST	TUB E	2.30	2.642
330	ST	180X180X6.0SHS	2.30	0.720
331	ST	180X180X8.0SHS	2.30	0.942
332	ST	150X150X6.0SHS	2.30	0.593
333	ST	150X150X6.0SHS	2.30	0.593
334	ST	150X150X4.5SHS	2.30	0.453
335	ST	150X150X5.0SHS	3.08	0.671
338	ST	220X220X8.0SHS	8.64	4.392
339	ST	150X150X5.0SHS	8.72	1.899
340	ST	140X140X5.0SHS	8.80	1.782
341	ST	140X140X5.0SHS	8.88	1.799
342	ST	140X140X5.0SHS	8.97	1.816
343	ST	140X140X5.0SHS	9.05	1.833
344	ST	140X140X5.0SHS	9.05	1.833
345	ST	140X140X5.0SHS	8.97	1.816

346	ST	140X140X5.0SHS	8.88	1.799
347	ST	140X140X5.0SHS	8.80	1.782
348	ST	150X150X6.0SHS	8.72	2.252
349	ST	150X150X6.0SHS	8.64	2.231
522	ST	120X120X6.0SHS	4.10	0.832
523	ST	120X120X6.0SHS	7.14	1.449
524	ST	120X120X6.0SHS	7.14	1.449
527	ST	120X120X6.0SHS	4.06	0.823
528	ST	120X120X6.0SHS	4.03	0.819
529	ST	120X120X6.0SHS	4.08	0.828
530	ST	150X150X5.0SHS	3.07	0.669
531	ST	150X150X5.0SHS	3.07	0.669
629	ST	250X250X10.0SHS	4.57	3.283
630	ST	250X250X10.0SHS	4.57	3.283
649	ST	120X120X6.0SHS	5.23	1.062
650	ST	100X100X6.0SHS	5.23	0.869
651	ST	250X250X10.0SHS	5.23	3.753
652	ST	TUB E	5.23	6.016
653	ST	220X220X8.0SHS	5.23	2.659
654	ST	180X180X8.0SHS	5.23	2.145
655	ST	180X180X6.0SHS	5.23	1.640
656	ST	150X150X8.0SHS	5.23	1.759
657	ST	120X120X6.0SHS	5.23	1.062
658	ST	TUB E	5.23	6.016
659	ST	220X220X8.0SHS	5.23	2.659
660	ST	180X180X8.0SHS	5.23	2.145
661	ST	180X180X8.0SHS	5.23	2.145
662	ST	150X150X5.0SHS	5.23	1.139
663	ST	120X120X6.0SHS	5.23	1.062
676	ST	180X180X8.0SHS	11.71	4.801
677	ST	180X180X6.0SHS	11.71	3.671
678	ST	180X180X6.0SHS	11.71	3.671
679	ST	180X180X6.0SHS	11.71	3.671
680	ST	180X180X8.0SHS	11.71	4.801
681	ST	220X220X8.0SHS	11.71	5.952
682	ST	220X220X8.0SHS	11.71	5.952
683	ST	180X180X8.0SHS	11.71	4.801
684	ST	180X180X6.0SHS	11.71	3.671
685	ST	180X180X6.0SHS	11.71	3.671
686	ST	180X180X6.0SHS	11.71	3.671
687	ST	180X180X8.0SHS	11.71	4.801
720	ST	150X150X8.0SHS	5.23	1.759
721	ST	120X120X6.0SHS	5.23	1.062
728	ST	150X150X8.0SHS	5.06	1.702
729	ST	150X150X8.0SHS	5.06	1.702
730	ST	180X180X8.0SHS	5.74	2.353
731	ST	180X180X8.0SHS	5.72	2.347
734	ST	150X150X8.0SHS	5.89	1.980
735	ST	150X150X8.0SHS	5.87	1.976
748	ST	TUB E	4.58	7.632
749	ST	150X150X5.0SHS	4.58	0.998
762	ST	50X50X3.6SHS	1.50	0.073
763	ST	50X50X3.6SHS	1.50	0.073
764	ST	50X50X3.6SHS	1.50	0.073
765	ST	72X72X5.0SHS	1.50	0.147
779	ST	150X150X5.0SHS	1.50	0.327

780	ST	150X150X5.0SHS	0.75	0.163
781	ST	150X150X5.0SHS	0.75	0.163
782	ST	150X150X8.0SHS	1.50	0.505
783	ST	220X220X8.0SHS	0.75	0.381
784	ST	220X220X8.0SHS	0.75	0.381
785	ST	150X150X5.0SHS	0.75	0.163
786	ST	150X150X5.0SHS	0.75	0.163
787	ST	180X180X8.0SHS	0.75	0.308
788	ST	150X150X8.0SHS	0.75	0.252
789	ST	150X150X8.0SHS	0.75	0.252
790	ST	150X150X8.0SHS	0.75	0.252
791	ST	150X150X8.0SHS	0.75	0.252
792	ST	180X180X8.0SHS	0.75	0.308
793	ST	150X150X5.0SHS	0.75	0.163
794	ST	150X150X5.0SHS	0.75	0.163
795	ST	50X50X3.6SHS	1.50	0.073
796	ST	50X50X3.6SHS	1.50	0.073
797	ST	50X50X3.6SHS	1.50	0.073
798	ST	50X50X3.6SHS	1.50	0.073
799	ST	72X72X5.0SHS	1.50	0.147
800	ST	50X50X3.6SHS	1.50	0.073
801	ST	50X50X3.6SHS	1.50	0.073
802	ST	50X50X3.6SHS	1.50	0.073
803	ST	50X50X3.6SHS	1.50	0.073
804	ST	50X50X3.6SHS	1.50	0.073
805	ST	120X120X6.0SHS	1.50	0.305
806	ST	50X50X3.6SHS	1.50	0.073
846	ST	50X50X3.6SHS	1.50	0.073
847	ST	50X50X3.6SHS	1.50	0.073
881	ST	50X50X3.6SHS	1.50	0.073
899	ST	50X50X3.6SHS	1.50	0.073
900	ST	150X150X5.0SHS	4.18	0.910
901	ST	150X150X5.0SHS	4.18	0.910
902	ST	150X150X8.0SHS	4.18	1.404
903	ST	150X150X5.0SHS	4.18	0.910
909	ST	150X150X5.0SHS	3.05	0.664
910	ST	150X150X5.0SHS	3.05	0.664
911	ST	140X140X5.0SHS	1.35	0.274
912	ST	140X140X5.0SHS	1.81	0.367
913	ST	140X140X5.0SHS	1.34	0.271
914	ST	140X140X5.0SHS	1.50	0.304
915	ST	180X180X5.0SHS	2.30	0.606
916	ST	140X140X5.0SHS	1.50	0.304
917	ST	140X140X5.0SHS	1.50	0.304
918	ST	140X140X5.0SHS	1.50	0.304
919	ST	140X140X5.0SHS	1.50	0.304
920	ST	140X140X5.0SHS	1.50	0.304
921	ST	140X140X5.0SHS	1.81	0.367
922	ST	140X140X5.0SHS	1.50	0.304
923	ST	140X140X5.0SHS	1.50	0.304
924	ST	140X140X5.0SHS	1.50	0.304
925	ST	140X140X5.0SHS	1.50	0.304
926	ST	140X140X5.0SHS	1.50	0.304
927	ST	140X140X5.0SHS	1.50	0.304
928	ST	150X150X5.0SHS	4.37	0.953
929	ST	150X150X5.0SHS	1.50	0.327

STAAD SPACE -- PAGE NO. 659

930	ST	150X150X5.0SHS	1.50	0.327
931	ST	150X150X5.0SHS	4.37	0.953
932	ST	150X150X8.0SHS	1.35	0.455
933	ST	150X150X8.0SHS	1.81	0.610
934	ST	150X150X8.0SHS	1.34	0.450
935	ST	TUB E	1.81	2.085
936	ST	140X140X5.0SHS	1.50	0.304
937	ST	TUB E	1.81	2.085
938	ST	140X140X5.0SHS	1.50	0.304
939	ST	150X150X4.5SHS	1.81	0.357
940	ST	140X140X5.0SHS	1.50	0.304
941	ST	150X150X4.5SHS	1.81	0.357
942	ST	140X140X5.0SHS	1.88	0.380
943	ST	150X150X6.0SHS	1.81	0.468
944	ST	140X140X5.0SHS	1.50	0.304
945	ST	180X180X8.0SHS	1.81	0.743
946	ST	140X140X5.0SHS	1.50	0.304
947	ST	180X180X8.0SHS	1.81	0.743
948	ST	140X140X5.0SHS	1.50	0.304
949	ST	180X180X8.0SHS	1.81	0.743
950	ST	140X140X5.0SHS	1.50	0.304
951	ST	180X180X8.0SHS	1.81	0.743
952	ST	140X140X5.0SHS	1.12	0.228
953	ST	150X150X6.0SHS	1.81	0.468
954	ST	140X140X5.0SHS	1.50	0.304
955	ST	150X150X4.5SHS	1.81	0.357
956	ST	140X140X5.0SHS	1.81	0.367
957	ST	150X150X4.5SHS	1.81	0.357
968	ST	TUB E	4.58	7.632
969	ST	250X250X10.0SHS	4.57	3.283
970	ST	150X150X5.0SHS	4.18	0.910
971	ST	150X150X5.0SHS	4.17	0.910
972	ST	150X150X5.0SHS	4.18	0.910
973	ST	150X150X8.0SHS	4.18	1.404
974	ST	150X150X8.0SHS	4.17	1.404
975	ST	150X150X5.0SHS	4.18	0.910
976	ST	150X150X8.0SHS	3.50	1.178
977	ST	150X150X8.0SHS	4.85	1.631
978	ST	150X150X5.0SHS	4.18	0.910
979	ST	150X150X5.0SHS	3.50	0.763
980	ST	150X150X5.0SHS	4.85	1.056
981	ST	150X150X5.0SHS	4.18	0.910
982	ST	150X150X5.0SHS	2.71	0.589
983	ST	150X150X5.0SHS	2.71	0.589
984	ST	150X150X5.0SHS	2.71	0.589
985	ST	150X150X5.0SHS	2.67	0.583
986	ST	150X150X5.0SHS	2.67	0.583
987	ST	150X150X5.0SHS	2.67	0.583
988	ST	120X120X6.0SHS	4.96	1.007
989	ST	120X120X6.0SHS	5.54	1.124
990	ST	120X120X6.0SHS	4.41	0.895
991	ST	120X120X6.0SHS	4.96	1.007
992	ST	120X120X6.0SHS	4.97	1.010
993	ST	120X120X6.0SHS	4.97	1.010
994	ST	120X120X6.0SHS	4.97	1.010
995	ST	120X120X6.0SHS	4.97	1.010

1000	ST	150X150X4.5SHS	2.71	0.534
1001	ST	150X150X4.5SHS	1.50	0.296
1002	ST	150X150X4.5SHS	1.81	0.358
1003	ST	150X150X4.5SHS	1.50	0.296
1004	ST	150X150X4.5SHS	1.50	0.296
1005	ST	150X150X4.5SHS	1.50	0.296
1006	ST	150X150X4.5SHS	1.50	0.296
1007	ST	150X150X5.0SHS	1.50	0.327
1008	ST	150X150X8.0SHS	1.50	0.505
1009	ST	150X150X8.0SHS	3.08	1.035
1010	ST	150X150X4.5SHS	2.30	0.453
1011	ST	150X150X4.5SHS	2.30	0.453
1012	ST	150X150X4.5SHS	2.30	0.453
1013	ST	180X180X8.0SHS	2.30	0.942
1014	ST	180X180X8.0SHS	2.30	0.942
1015	ST	TUB E	2.30	2.642
1016	ST	150X150X8.0SHS	1.50	0.505
1017	ST	150X150X5.0SHS	1.50	0.327
1018	ST	150X150X5.0SHS	1.50	0.327
1019	ST	150X150X4.5SHS	1.50	0.296
1020	ST	150X150X4.5SHS	1.50	0.296
1021	ST	150X150X4.5SHS	1.81	0.358
1022	ST	150X150X4.5SHS	2.67	0.527
1023	ST	TUB E	2.30	2.642
1024	ST	180X180X8.0SHS	2.30	0.942
1025	ST	180X180X8.0SHS	2.30	0.942
1026	ST	150X150X4.5SHS	2.30	0.453
1027	ST	150X150X4.5SHS	2.30	0.453
1028	ST	150X150X4.5SHS	2.30	0.453
1029	ST	150X150X8.0SHS	3.08	1.035
1030	ST	180X180X6.0SHS	8.64	2.709
1031	ST	180X180X8.0SHS	8.72	3.576
1032	ST	180X180X6.0SHS	8.80	2.760
1033	ST	140X140X5.0SHS	8.88	1.799
1034	ST	150X150X5.0SHS	8.97	1.954
1035	ST	140X140X5.0SHS	9.05	1.833
1036	ST	140X140X5.0SHS	9.05	1.833
1037	ST	150X150X5.0SHS	8.97	1.954
1038	ST	140X140X5.0SHS	8.88	1.799
1039	ST	150X150X5.0SHS	8.80	1.917
1040	ST	180X180X6.0SHS	8.72	2.735
1041	ST	180X180X6.0SHS	8.64	2.709
1092	ST	120X120X6.0SHS	4.10	0.832
1093	ST	120X120X6.0SHS	7.14	1.449
1094	ST	120X120X6.0SHS	7.14	1.449
1097	ST	120X120X6.0SHS	4.06	0.823
1098	ST	120X120X6.0SHS	4.03	0.819
1099	ST	120X120X6.0SHS	4.08	0.828
1100	ST	150X150X8.0SHS	3.07	1.033
1101	ST	150X150X8.0SHS	3.07	1.032
1181	ST	250X250X10.0SHS	4.57	3.283
1182	ST	250X250X10.0SHS	4.57	3.283
1210	ST	TUB E	4.58	7.632
1211	ST	150X150X5.0SHS	4.58	0.998
1212	ST	180X180X8.0SHS	0.75	0.308
1213	ST	180X180X8.0SHS	0.75	0.308

1214	ST	220X220X8.0SHS	0.75	0.381
1215	ST	220X220X8.0SHS	0.75	0.381
1221	ST	140X140X5.0SHS	1.12	0.228
1223	ST	140X140X5.0SHS	1.12	0.228
1225	ST	140X140X5.0SHS	1.50	0.304
1227	ST	140X140X5.0SHS	1.50	0.304
1245	ST	150X150X4.5SHS	1.50	0.296
1246	ST	150X150X4.5SHS	1.50	0.296
1247	ST	TUB E	1.50	1.726
1248	ST	TUB E	1.50	1.726
1249	ST	150X150X4.5SHS	1.50	0.296
1250	ST	180X180X6.0SHS	1.50	0.470
1251	ST	180X180X8.0SHS	1.50	0.615
1252	ST	180X180X6.0SHS	1.50	0.470
1253	ST	180X180X6.0SHS	1.50	0.470
1254	ST	150X150X4.5SHS	1.50	0.296
1255	ST	150X150X4.5SHS	1.50	0.296
1256	ST	TUB E	1.50	1.726
1257	ST	TUB E	1.50	1.726
1258	ST	150X150X4.5SHS	1.50	0.296
1259	ST	180X180X8.0SHS	1.50	0.615
1260	ST	180X180X8.0SHS	1.50	0.615
1261	ST	180X180X8.0SHS	1.50	0.615
1262	ST	180X180X8.0SHS	1.50	0.615
1263	ST	150X150X4.5SHS	1.50	0.296
1264	ST	150X150X4.5SHS	1.50	0.296
1265	ST	150X150X6.0SHS	1.50	0.388
1266	ST	150X150X6.0SHS	1.50	0.388
1267	ST	150X150X5.0SHS	1.50	0.327
1268	ST	150X150X5.0SHS	1.50	0.327
1281	ST	150X150X5.0SHS	1.81	0.395
1283	ST	150X150X5.0SHS	1.81	0.395
1284	ST	50X50X3.6SHS	1.50	0.073
1285	ST	150X150X5.0SHS	1.81	0.395
1287	ST	150X150X5.0SHS	1.81	0.395
1288	ST	50X50X3.6SHS	1.50	0.073
1289	ST	TUB E	1.81	2.085
1290	ST	TUB E	1.81	2.085
1291	ST	TUB E	1.81	2.085
1292	ST	TUB E	1.81	2.085
1293	ST	TUB E	1.81	2.085
1294	ST	TUB E	1.81	2.085
1295	ST	150X150X4.5SHS	1.81	0.357
1296	ST	150X150X4.5SHS	1.81	0.357
1297	ST	150X150X4.5SHS	1.81	0.357
1298	ST	150X150X4.5SHS	1.81	0.357
1299	ST	150X150X4.5SHS	1.81	0.357
1300	ST	150X150X4.5SHS	1.81	0.357
1301	ST	150X150X4.5SHS	1.81	0.357
1302	ST	150X150X4.5SHS	1.81	0.357
1303	ST	150X150X4.5SHS	1.81	0.357
1304	ST	180X180X8.0SHS	1.81	0.743
1305	ST	180X180X5.0SHS	1.81	0.478
1306	ST	180X180X5.0SHS	1.81	0.478
1307	ST	180X180X5.0SHS	1.81	0.478
1308	ST	180X180X5.0SHS	1.81	0.478

1309	ST	180X180X5.0SHS	1.81	0.478
1310	ST	180X180X5.0SHS	1.81	0.478
1311	ST	180X180X5.0SHS	1.81	0.478
1312	ST	180X180X5.0SHS	1.81	0.478
1313	ST	180X180X5.0SHS	1.81	0.478
1314	ST	180X180X5.0SHS	1.81	0.478
1315	ST	180X180X5.0SHS	1.81	0.478
1316	ST	150X150X4.5SHS	1.81	0.357
1317	ST	150X150X4.5SHS	1.81	0.357
1318	ST	150X150X4.5SHS	1.81	0.357
1319	ST	150X150X4.5SHS	1.81	0.357
1320	ST	150X150X4.5SHS	1.81	0.357
1321	ST	150X150X4.5SHS	1.81	0.357
1322	ST	150X150X4.5SHS	1.81	0.357
1323	ST	150X150X4.5SHS	1.81	0.357
1324	ST	150X150X4.5SHS	1.81	0.357
1325	ST	TUB E	1.81	2.085
1326	ST	TUB E	1.81	2.085
1327	ST	TUB E	1.81	2.085
1328	ST	TUB E	1.81	2.085
1329	ST	TUB E	1.81	2.085
1330	ST	TUB E	1.81	2.085
1331	ST	150X150X4.5SHS	1.81	0.357
1332	ST	150X150X4.5SHS	1.81	0.357
1333	ST	150X150X4.5SHS	1.81	0.357
1334	ST	150X150X4.5SHS	1.81	0.357
1335	ST	150X150X4.5SHS	1.81	0.357
1336	ST	150X150X4.5SHS	1.81	0.357
1337	ST	150X150X6.0SHS	1.81	0.468
1338	ST	150X150X6.0SHS	1.81	0.468
1339	ST	150X150X6.0SHS	1.81	0.468
1340	ST	180X180X8.0SHS	1.81	0.743
1341	ST	180X180X8.0SHS	1.81	0.743
1342	ST	180X180X8.0SHS	1.81	0.743
1343	ST	180X180X8.0SHS	1.81	0.743
1344	ST	180X180X8.0SHS	1.81	0.743
1345	ST	180X180X8.0SHS	1.81	0.743
1346	ST	180X180X8.0SHS	1.81	0.743
1347	ST	180X180X8.0SHS	1.81	0.743
1348	ST	180X180X8.0SHS	1.81	0.743
1349	ST	180X180X8.0SHS	1.81	0.743
1350	ST	180X180X8.0SHS	1.81	0.743
1351	ST	180X180X8.0SHS	1.81	0.743
1352	ST	150X150X5.0SHS	1.81	0.395
1353	ST	150X150X4.5SHS	1.81	0.357
1354	ST	150X150X6.0SHS	1.81	0.468
1355	ST	150X150X4.5SHS	1.81	0.357
1356	ST	150X150X4.5SHS	1.81	0.357
1357	ST	150X150X4.5SHS	1.81	0.357
1358	ST	150X150X4.5SHS	1.81	0.357
1359	ST	150X150X4.5SHS	1.81	0.357
1360	ST	150X150X4.5SHS	1.81	0.357
1361	ST	150X150X5.0SHS	1.81	0.395
1362	ST	150X150X5.0SHS	1.81	0.395
1363	ST	150X150X5.0SHS	1.81	0.395
1364	ST	150X150X5.0SHS	1.81	0.395

1365	ST	150X150X5.0SHS	1.81	0.395
1366	ST	150X150X5.0SHS	1.81	0.395
1367	ST	150X150X5.0SHS	1.81	0.395
1368	ST	150X150X5.0SHS	1.81	0.395
1369	ST	150X150X5.0SHS	1.81	0.395
1370	ST	150X150X5.0SHS	1.81	0.395
1371	ST	150X150X5.0SHS	1.81	0.395
1372	ST	150X150X5.0SHS	1.81	0.395
1385	ST	50X50X3.6SHS	1.50	0.073
1386	ST	50X50X3.6SHS	1.50	0.073
1423	ST	50X50X3.6SHS	1.50	0.073
1424	ST	50X50X3.6SHS	1.50	0.073
1425	ST	50X50X3.6SHS	1.50	0.073
1426	ST	50X50X3.6SHS	1.50	0.073
1427	ST	50X50X3.6SHS	1.50	0.073
1428	ST	50X50X3.6SHS	1.50	0.073
1429	ST	72X72X5.0SHS	2.35	0.231
1430	ST	72X72X5.0SHS	2.35	0.231
1431	ST	72X72X5.0SHS	2.35	0.231
1432	ST	72X72X5.0SHS	2.35	0.231
1481	ST	50X50X3.6SHS	2.35	0.115
1482	ST	50X50X3.6SHS	2.35	0.115
1483	ST	50X50X3.6SHS	2.35	0.115
1484	ST	50X50X3.6SHS	2.35	0.115
1485	ST	180X180X5.0SHS	2.30	0.606
1486	ST	180X180X5.0SHS	2.30	0.606
1487	ST	180X180X5.0SHS	2.30	0.606
1488	ST	180X180X5.0SHS	2.30	0.606
1489	ST	150X150X4.5SHS	1.62	0.319
1491	ST	150X150X4.5SHS	2.30	0.453
1493	ST	150X150X4.5SHS	1.62	0.319
1495	ST	150X150X4.5SHS	2.30	0.453
1497	ST	TUB E	2.18	2.512
1498	ST	TUB E	2.30	2.642
1499	ST	180X180X5.0SHS	2.07	0.547
1500	ST	180X180X5.0SHS	2.30	0.606
1501	ST	180X180X5.0SHS	1.96	0.517
1502	ST	180X180X5.0SHS	2.30	0.606
1503	ST	150X150X4.5SHS	1.85	0.364
1504	ST	150X150X4.5SHS	2.30	0.453
1505	ST	150X150X4.5SHS	1.73	0.342
1506	ST	150X150X4.5SHS	2.30	0.453
1507	ST	TUB E	2.18	2.512
1508	ST	TUB E	2.30	2.642
1509	ST	180X180X8.0SHS	2.07	0.849
1510	ST	180X180X8.0SHS	2.30	0.942
1511	ST	180X180X8.0SHS	1.96	0.803
1512	ST	180X180X8.0SHS	2.30	0.942
1513	ST	150X150X4.5SHS	1.85	0.364
1514	ST	150X150X4.5SHS	2.30	0.453
1515	ST	150X150X4.5SHS	1.73	0.342
1516	ST	150X150X4.5SHS	2.30	0.453
1552	ST	150X150X4.5SHS	2.30	0.453
1554	ST	150X150X4.5SHS	1.62	0.319
1556	ST	150X150X4.5SHS	1.62	0.319
1558	ST	150X150X4.5SHS	2.30	0.453

1560	ST	150X150X4.5SHS	1.73	0.342
1561	ST	150X150X4.5SHS	2.30	0.453
1562	ST	150X150X4.5SHS	1.85	0.364
1563	ST	150X150X4.5SHS	2.30	0.453
1564	ST	180X180X5.0SHS	1.96	0.517
1565	ST	180X180X5.0SHS	2.30	0.606
1566	ST	180X180X5.0SHS	2.07	0.547
1567	ST	180X180X5.0SHS	2.30	0.606
1568	ST	TUB E	2.18	2.512
1569	ST	TUB E	2.30	2.642
1570	ST	150X150X4.5SHS	1.73	0.342
1571	ST	150X150X4.5SHS	2.30	0.453
1572	ST	150X150X4.5SHS	1.85	0.364
1573	ST	150X150X4.5SHS	2.30	0.453
1574	ST	180X180X8.0SHS	1.96	0.803
1575	ST	180X180X8.0SHS	2.30	0.942
1576	ST	180X180X8.0SHS	2.07	0.849
1577	ST	180X180X8.0SHS	2.30	0.942
1578	ST	TUB E	2.18	2.512
1579	ST	TUB E	2.30	2.642
1610	ST	140X140X5.0SHS	1.35	0.274
1611	ST	140X140X5.0SHS	1.35	0.274
1612	ST	50X50X3.6SHS	1.50	0.073
1613	ST	100X100X6.0SHS	2.02	0.336
1614	ST	100X100X6.0SHS	2.02	0.336
1615	ST	140X140X5.0SHS	1.81	0.367
1616	ST	140X140X5.0SHS	1.81	0.367
1620	ST	140X140X5.0SHS	1.50	0.304
1621	ST	140X140X5.0SHS	1.50	0.304
1622	ST	140X140X5.0SHS	1.50	0.304
1623	ST	140X140X5.0SHS	1.50	0.304
1624	ST	140X140X5.0SHS	1.50	0.304
1625	ST	140X140X5.0SHS	1.50	0.304
1633	ST	140X140X5.0SHS	1.50	0.304
1634	ST	140X140X5.0SHS	1.50	0.304
1636	ST	140X140X5.0SHS	1.50	0.304
1637	ST	140X140X5.0SHS	1.50	0.304
1639	ST	140X140X5.0SHS	1.50	0.304
1640	ST	140X140X5.0SHS	1.50	0.304
1646	ST	140X140X5.0SHS	1.50	0.304
1647	ST	140X140X5.0SHS	1.50	0.304
1649	ST	140X140X5.0SHS	1.50	0.304
1650	ST	140X140X5.0SHS	1.50	0.304
1652	ST	140X140X5.0SHS	1.50	0.304
1653	ST	140X140X5.0SHS	1.50	0.304
1659	ST	140X140X5.0SHS	1.50	0.304
1660	ST	140X140X5.0SHS	1.50	0.304
1662	ST	140X140X5.0SHS	1.50	0.304
1663	ST	140X140X5.0SHS	1.50	0.304
1665	ST	140X140X5.0SHS	1.50	0.304
1666	ST	140X140X5.0SHS	1.50	0.304
1672	ST	140X140X5.0SHS	1.50	0.304
1673	ST	140X140X5.0SHS	1.50	0.304
1675	ST	140X140X5.0SHS	1.50	0.304
1676	ST	140X140X5.0SHS	1.50	0.304
1678	ST	140X140X5.0SHS	1.50	0.304

1679	ST	140X140X5.0SHS	1.50	0.304
1685	ST	140X140X5.0SHS	1.50	0.304
1686	ST	140X140X5.0SHS	1.50	0.304
1688	ST	140X140X5.0SHS	1.50	0.304
1689	ST	140X140X5.0SHS	1.50	0.304
1691	ST	140X140X5.0SHS	1.50	0.304
1692	ST	140X140X5.0SHS	1.50	0.304
1698	ST	140X140X5.0SHS	1.50	0.304
1699	ST	140X140X5.0SHS	1.50	0.304
1701	ST	140X140X5.0SHS	1.50	0.304
1702	ST	140X140X5.0SHS	1.50	0.304
1704	ST	140X140X5.0SHS	1.50	0.304
1705	ST	140X140X5.0SHS	1.50	0.304
1711	ST	140X140X5.0SHS	1.50	0.304
1712	ST	140X140X5.0SHS	1.50	0.304
1714	ST	140X140X5.0SHS	1.50	0.304
1715	ST	140X140X5.0SHS	1.50	0.304
1717	ST	140X140X5.0SHS	1.50	0.304
1718	ST	140X140X5.0SHS	1.50	0.304
1724	ST	140X140X5.0SHS	1.50	0.304
1725	ST	140X140X5.0SHS	1.50	0.304
1727	ST	140X140X5.0SHS	1.50	0.304
1728	ST	140X140X5.0SHS	1.50	0.304
1730	ST	140X140X5.0SHS	1.50	0.304
1731	ST	140X140X5.0SHS	1.50	0.304
1737	ST	140X140X5.0SHS	1.50	0.304
1738	ST	140X140X5.0SHS	1.50	0.304
1740	ST	140X140X5.0SHS	1.50	0.304
1741	ST	140X140X5.0SHS	1.50	0.304
1743	ST	140X140X5.0SHS	1.50	0.304
1744	ST	140X140X5.0SHS	1.50	0.304
1750	ST	140X140X5.0SHS	1.50	0.304
1751	ST	140X140X5.0SHS	1.50	0.304
1753	ST	140X140X5.0SHS	1.50	0.304
1754	ST	140X140X5.0SHS	1.50	0.304
1756	ST	140X140X5.0SHS	1.50	0.304
1757	ST	140X140X5.0SHS	1.50	0.304
1763	ST	140X140X5.0SHS	1.50	0.304
1764	ST	140X140X5.0SHS	1.50	0.304
1766	ST	140X140X5.0SHS	1.50	0.304
1767	ST	140X140X5.0SHS	1.50	0.304
1769	ST	140X140X5.0SHS	1.50	0.304
1770	ST	140X140X5.0SHS	1.50	0.304
1776	ST	140X140X5.0SHS	1.34	0.271
1777	ST	140X140X5.0SHS	1.81	0.367
1778	ST	140X140X5.0SHS	1.34	0.271
1779	ST	140X140X5.0SHS	1.81	0.367
1781	ST	50X50X3.6SHS	1.50	0.073
1784	ST	100X100X6.0SHS	2.01	0.334
1785	ST	100X100X6.0SHS	2.01	0.334
1786	ST	150X150X8.0SHS	1.35	0.455
1787	ST	150X150X8.0SHS	1.35	0.455
1788	ST	50X50X3.6SHS	1.50	0.073
1789	ST	150X150X5.0SHS	2.02	0.440
1790	ST	150X150X5.0SHS	2.02	0.440
1791	ST	140X140X5.0SHS	1.81	0.367

1792	ST	140X140X5.0SHS	1.81	0.367
1796	ST	140X140X5.0SHS	1.50	0.304
1797	ST	140X140X5.0SHS	1.50	0.304
1799	ST	140X140X5.0SHS	1.50	0.304
1800	ST	140X140X5.0SHS	1.50	0.304
1802	ST	140X140X5.0SHS	1.50	0.304
1803	ST	140X140X5.0SHS	1.50	0.304
1809	ST	140X140X5.0SHS	1.50	0.304
1810	ST	140X140X5.0SHS	1.50	0.304
1812	ST	140X140X5.0SHS	1.50	0.304
1813	ST	140X140X5.0SHS	1.50	0.304
1815	ST	140X140X5.0SHS	1.50	0.304
1816	ST	140X140X5.0SHS	1.50	0.304
1822	ST	140X140X5.0SHS	1.50	0.304
1823	ST	140X140X5.0SHS	1.50	0.304
1825	ST	140X140X5.0SHS	1.50	0.304
1826	ST	140X140X5.0SHS	1.50	0.304
1830	ST	140X140X5.0SHS	1.50	0.304
1831	ST	140X140X5.0SHS	1.50	0.304
1833	ST	140X140X5.0SHS	1.50	0.304
1834	ST	140X140X5.0SHS	1.50	0.304
1836	ST	140X140X5.0SHS	1.50	0.304
1837	ST	140X140X5.0SHS	1.50	0.304
1843	ST	140X140X5.0SHS	1.50	0.304
1844	ST	140X140X5.0SHS	1.50	0.304
1846	ST	140X140X5.0SHS	1.50	0.304
1847	ST	140X140X5.0SHS	1.50	0.304
1849	ST	140X140X5.0SHS	1.50	0.304
1850	ST	140X140X5.0SHS	1.50	0.304
1858	ST	140X140X5.0SHS	1.50	0.304
1859	ST	140X140X5.0SHS	1.50	0.304
1861	ST	140X140X5.0SHS	1.50	0.304
1862	ST	140X140X5.0SHS	1.50	0.304
1864	ST	140X140X5.0SHS	1.50	0.304
1865	ST	140X140X5.0SHS	1.50	0.304
1871	ST	140X140X5.0SHS	1.50	0.304
1872	ST	140X140X5.0SHS	1.50	0.304
1874	ST	140X140X5.0SHS	1.50	0.304
1875	ST	140X140X5.0SHS	1.50	0.304
1877	ST	140X140X5.0SHS	1.50	0.304
1878	ST	140X140X5.0SHS	1.50	0.304
1884	ST	140X140X5.0SHS	1.50	0.304
1885	ST	140X140X5.0SHS	1.50	0.304
1887	ST	140X140X5.0SHS	1.88	0.380
1888	ST	140X140X5.0SHS	1.88	0.380
1892	ST	140X140X5.0SHS	1.50	0.304
1893	ST	140X140X5.0SHS	1.50	0.304
1895	ST	140X140X5.0SHS	1.50	0.304
1896	ST	140X140X5.0SHS	1.50	0.304
1898	ST	140X140X5.0SHS	1.50	0.304
1899	ST	140X140X5.0SHS	1.50	0.304
1905	ST	140X140X5.0SHS	1.50	0.304
1906	ST	140X140X5.0SHS	1.50	0.304
1908	ST	140X140X5.0SHS	1.50	0.304
1909	ST	140X140X5.0SHS	1.50	0.304
1911	ST	140X140X5.0SHS	1.50	0.304

1912	ST	140X140X5.0SHS	1.50	0.304
1918	ST	150X150X8.0SHS	1.81	0.610
1919	ST	150X150X8.0SHS	1.81	0.610
1921	ST	150X150X8.0SHS	1.34	0.450
1922	ST	150X150X8.0SHS	1.34	0.450
1923	ST	50X50X3.6SHS	1.50	0.073
1926	ST	150X150X5.0SHS	2.01	0.438
1927	ST	150X150X5.0SHS	2.01	0.438
1930	ST	72X72X5.0SHS	3.42	0.335
1931	ST	72X72X5.0SHS	3.42	0.336
1932	ST	72X72X5.0SHS	3.42	0.335
1933	ST	72X72X5.0SHS	3.42	0.336
2405	ST	150X150X5.0SHS	3.05	0.664
2406	ST	150X150X5.0SHS	4.37	0.953
2407	ST	150X150X5.0SHS	3.05	0.664
2408	ST	150X150X5.0SHS	4.37	0.953
2409	ST	50X50X3.6SHS	1.50	0.073
2410	ST	50X50X3.6SHS	1.50	0.073
2411	ST	72X72X5.0SHS	3.40	0.333
2412	ST	72X72X5.0SHS	3.40	0.333
2413	ST	120X120X6.0SHS	4.62	0.939
2414	ST	120X120X6.0SHS	4.62	0.939
2415	ST	150X150X5.0SHS	4.44	0.966
2416	ST	150X150X5.0SHS	5.07	1.106
2417	ST	150X150X5.0SHS	3.81	0.830
2418	ST	150X150X5.0SHS	4.44	0.966
2419	ST	150X150X5.0SHS	4.44	0.966
2420	ST	150X150X5.0SHS	5.07	1.106
2421	ST	150X150X5.0SHS	3.81	0.830
2422	ST	150X150X5.0SHS	4.44	0.966
2423	ST	150X150X5.0SHS	3.05	0.664
2424	ST	150X150X5.0SHS	4.37	0.953
2425	ST	150X150X5.0SHS	3.05	0.664
2426	ST	150X150X5.0SHS	4.37	0.953
2427	ST	50X50X3.6SHS	1.50	0.073
2428	ST	50X50X3.6SHS	1.50	0.073
2429	ST	72X72X5.0SHS	3.40	0.333
2430	ST	72X72X5.0SHS	3.40	0.333
2431	ST	120X120X6.0SHS	4.62	0.939
2432	ST	120X120X6.0SHS	4.62	0.939
2433	ST	120X120X6.0SHS	4.44	0.901
2434	ST	120X120X6.0SHS	4.44	0.901
2435	ST	120X120X6.0SHS	4.44	0.901
2436	ST	120X120X6.0SHS	4.44	0.901
2437	ST	150X150X5.0SHS	4.44	0.966
2438	ST	150X150X5.0SHS	4.44	0.966
2439	ST	150X150X5.0SHS	4.44	0.966
2440	ST	150X150X5.0SHS	4.44	0.966
2441	ST	180X180X8.0SHS	11.71	4.801
2442	ST	220X220X8.0SHS	11.71	5.952
2447	ST	150X150X4.5SHS	1.50	0.296
2448	ST	150X150X4.5SHS	1.50	0.296
2449	ST	150X150X8.0SHS	1.50	0.505
2450	ST	150X150X4.5SHS	1.50	0.296
2451	ST	150X150X4.5SHS	1.50	0.296
2452	ST	150X150X4.5SHS	1.50	0.296

2453	ST	150X150X4.5SHS	1.50	0.296
2454	ST	150X150X4.5SHS	1.50	0.296
2455	ST	150X150X4.5SHS	1.50	0.296
2456	ST	150X150X4.5SHS	1.50	0.296
2457	ST	150X150X4.5SHS	1.50	0.296
2458	ST	150X150X4.5SHS	1.50	0.296
2459	ST	150X150X4.5SHS	1.50	0.296
2460	ST	150X150X4.5SHS	1.50	0.296
2461	ST	150X150X4.5SHS	1.50	0.296
2462	ST	150X150X4.5SHS	1.50	0.296
2463	ST	150X150X4.5SHS	1.50	0.296
2464	ST	150X150X6.0SHS	1.50	0.388
2465	ST	150X150X4.5SHS	1.50	0.296
2466	ST	150X150X4.5SHS	1.50	0.296
2467	ST	150X150X4.5SHS	1.50	0.296
2468	ST	150X150X4.5SHS	1.50	0.296
2469	ST	150X150X4.5SHS	1.50	0.296
2470	ST	150X150X4.5SHS	1.50	0.296
2471	ST	150X150X4.5SHS	1.50	0.296
2472	ST	150X150X4.5SHS	1.50	0.296
2473	ST	150X150X4.5SHS	1.50	0.296
2474	ST	150X150X4.5SHS	1.50	0.296
2475	ST	150X150X4.5SHS	1.50	0.296
2476	ST	150X150X4.5SHS	1.50	0.296
2477	ST	150X150X4.5SHS	1.50	0.296
2478	ST	150X150X4.5SHS	1.50	0.296
2479	ST	150X150X4.5SHS	1.50	0.296
2480	ST	150X150X4.5SHS	1.50	0.296
2481	ST	150X150X4.5SHS	1.50	0.296
2482	ST	150X150X4.5SHS	1.50	0.296
2483	ST	150X150X4.5SHS	1.50	0.296
2484	ST	150X150X5.0SHS	1.50	0.327
2485	ST	150X150X8.0SHS	1.50	0.505
2486	ST	150X150X4.5SHS	1.50	0.296
2487	ST	150X150X4.5SHS	1.50	0.296
2488	ST	150X150X4.5SHS	1.50	0.296
2489	ST	150X150X4.5SHS	1.50	0.296
2490	ST	150X150X4.5SHS	1.50	0.296
2491	ST	150X150X4.5SHS	1.50	0.296
2492	ST	150X150X4.5SHS	1.50	0.296
2493	ST	150X150X4.5SHS	1.50	0.296
2494	ST	150X150X5.0SHS	1.50	0.327
2495	ST	150X150X4.5SHS	1.50	0.296
2496	ST	150X150X4.5SHS	1.50	0.296
2497	ST	150X150X5.0SHS	1.50	0.327
2498	ST	150X150X4.5SHS	1.50	0.296
2499	ST	150X150X6.0SHS	1.50	0.388
2500	ST	150X150X8.0SHS	1.50	0.505
2501	ST	150X150X5.0SHS	1.50	0.327
2502	ST	150X150X4.5SHS	1.50	0.296
2503	ST	150X150X4.5SHS	1.50	0.296
2504	ST	150X150X6.0SHS	1.50	0.388
2505	ST	150X150X4.5SHS	1.50	0.296
2506	ST	150X150X5.0SHS	1.50	0.327
2507	ST	150X150X4.5SHS	1.50	0.296
2508	ST	150X150X4.5SHS	1.50	0.296

2509	ST	150X150X4.5SHS	1.50	0.296
2510	ST	150X150X4.5SHS	1.50	0.296
2511	ST	150X150X4.5SHS	1.50	0.296
2512	ST	150X150X4.5SHS	1.50	0.296
2513	ST	150X150X4.5SHS	1.50	0.296
2514	ST	150X150X4.5SHS	1.50	0.296
2515	ST	150X150X4.5SHS	1.50	0.296
2516	ST	150X150X4.5SHS	1.50	0.296
2517	ST	150X150X4.5SHS	1.50	0.296
2518	ST	150X150X4.5SHS	1.50	0.296
3029	FR	ISMC150	1.50	0.491
3032	FR	ISMC150	1.50	0.491
3033	ST	150X150X5.0SHS	0.75	0.163
3035	FR	ISMC150	1.81	0.593
3037	FR	ISMC150	1.50	0.491
3038	ST	150X150X5.0SHS	0.75	0.163
3040	FR	ISMC150	1.50	0.491
3041	ST	150X150X5.0SHS	0.75	0.163
3043	FR	ISMC150	1.50	0.491
3045	FR	ISMC150	1.88	0.614
3046	ST	150X150X8.0SHS	0.75	0.252
3048	FR	ISMC150	1.50	0.491
3049	ST	150X150X8.0SHS	0.75	0.252
3051	FR	ISMC150	1.50	0.491
			---	---
		TOTAL =		611.907

********** END OF DATA FROM INTERNAL STORAGE **********

1838. STEEL MEMBER TAKE OFF LIST 3052 3054 3055 3057 3059 3060 3062 3063 3065 3067 -

STAAD SPACE -- PAGE NO. 670

STEEL TAKE OFF

STEEL TAKE-OFF

PROFILE	LENGTH(METE)	WEIGHT(KN)
1839. 3069 3071 3073 3074 3076 3078 3080 3081 3083 3085 3086 3088 3090 3091 3093 -		
1840. 3094 3096 3098 3099 3101 3103 3104 3106 3108 3109 3111 3113 3114 3116 3117 -		
1841. 3119 3121 3122 3124 3126 TO 3129		
ST 150X150X8.0SHS	1.50	0.505
FR ISMC150	65.06	21.292
ST 150X150X5.0SHS	2.25	0.490
	TOTAL =	22.287

MEMBER	PROFILE	LENGTH (METE)	WEIGHT (KN)
3052	ST 150X150X8.0SHS	0.75	0.252
3054	FR ISMC150	1.50	0.491
3055	ST 150X150X8.0SHS	0.75	0.252
3057	FR ISMC150	1.50	0.491
3059	FR ISMC150	1.12	0.368
3060	ST 150X150X5.0SHS	0.75	0.163
3062	FR ISMC150	1.50	0.491
3063	ST 150X150X5.0SHS	0.75	0.163
3065	FR ISMC150	1.81	0.593
3067	FR ISMC150	1.12	0.368
3069	FR ISMC150	1.50	0.491
3071	FR ISMC150	1.50	0.491
3073	FR ISMC150	1.50	0.491
3074	FR ISMC150	1.50	0.491
3076	FR ISMC150	1.50	0.491
3078	FR ISMC150	1.50	0.491
3080	FR ISMC150	1.50	0.491
3081	FR ISMC150	1.81	0.593
3083	FR ISMC150	1.50	0.491
3085	FR ISMC150	1.50	0.491
3086	FR ISMC150	1.50	0.491
3088	FR ISMC150	1.50	0.491
3090	FR ISMC150	1.50	0.491
3091	FR ISMC150	1.50	0.491
3093	FR ISMC150	1.50	0.491
3094	FR ISMC150	1.50	0.491
3096	FR ISMC150	1.50	0.491
3098	FR ISMC150	1.50	0.491
3099	FR ISMC150	1.50	0.491
3101	FR ISMC150	1.50	0.491
3103	FR ISMC150	1.50	0.491
3104	FR ISMC150	1.50	0.491
3106	FR ISMC150	1.50	0.491
3108	FR ISMC150	1.50	0.491
3109	FR ISMC150	1.50	0.491

3111	FR	ISMC150	1.50	0.491
3113	FR	ISMC150	1.50	0.491
3114	FR	ISMC150	1.50	0.491
3116	FR	ISMC150	1.50	0.491
3117	FR	ISMC150	1.88	0.614
3119	FR	ISMC150	1.50	0.491
3121	FR	ISMC150	1.50	0.491
3122	FR	ISMC150	1.50	0.491
3124	FR	ISMC150	1.50	0.491
3126	FR	ISMC150	1.50	0.491
3127	FR	ISMC150	1.50	0.491
3128	ST	150X150X5.0SHS	0.75	0.163
3129	FR	ISMC150	1.81	0.593
			TOTAL =	22.287

********** END OF DATA FROM INTERNAL STORAGE **********

1842. STEEL MEMBER TAKE OFF LIST 5 TO 8 216 TO 218 221 360 361 366 368 433 TO 450 -

STAAD SPACE -- PAGE NO. 672

STEEL TAKE OFF

STEEL TAKE-OFF

PROFILE	LENGTH(METE)	WEIGHT(KN)
1843. 508 TO 511 533 534 536 TO 539 541 543 545 547 549 551 553 TO 559 567 TO 602 -		
1844. 605 TO 614 617 619 620 622 TO 628 688 TO 719 722 TO 727 732 733 807 TO 810 -		
1845. 825 TO 840 848 TO 880 904 TO 907 996 TO 999 1042 TO 1063 1086 TO 1089 1102 -		
1846. 1103 TO 1166 1169 1171 1172 1174 TO 1180 1216 TO 1220 1229 1231 TO 1233 1235 -		
1847. 1236 TO 1237 1239 TO 1241 1243 1244 1934 TO 1940 1942 1944 1946 1948 1950 -		
1848. 1952 1954 1956 1958 1960 1962 1964 TO 2080 2082 TO 2084 2086 2087 2089 2090 -		
1849. 2092 2093 2095 2096 2098 2099 2101 2102 2104 2105 2107 2108 2110 2111 2113 -		
1850. 2114 2116 2117 2119 2120 2122 2123 2125 TO 2404 2601 TO 2801 2807 -		
1851. 2809 TO 2858		
ST 150X150X8.0SHS	227.32	76.469
ST 180X180X6.0SHS	127.46	39.977
ST 150X150X5.0SHS	519.90	113.266
ST 180X180X8.0SHS	44.19	18.123
ST 180X180X10.0SHS	8.35	4.196
ST 72X72X3.2SHS	131.97	8.658
ST 100X100X6.0SHS	90.13	14.976
ST 120X120X6.0SHS	72.51	14.721
ST 150X150X6.0SHS	81.36	21.018
ST 150X150X4.5SHS	229.87	45.329
ST 175X175X5.0SHS	84.94	21.766
ST 220X220X6.0SHS	51.38	19.905
ST 50X50X3.6SHS	318.05	15.514
ST 96X48X4.8RHS	427.13	40.391
ST 250X250X10.0SHS	13.21	9.482
ST 220X220X8.0SHS	28.74	14.612
ST 72X72X5.0SHS	63.37	6.212
	----------	----------
	TOTAL =	484.614

MEMBER	PROFILE	LENGTH (METE)	WEIGHT (KN)
5	ST 150X150X8.0SHS	4.18	1.404
6	ST 180X180X6.0SHS	4.18	1.310
7	ST 180X180X6.0SHS	4.18	1.310
8	ST 150X150X5.0SHS	4.18	0.910
216	ST 150X150X5.0SHS	0.83	0.181
217	ST 150X150X5.0SHS	0.80	0.174
218	ST 150X150X5.0SHS	3.99	0.868
221	ST 150X150X5.0SHS	3.99	0.868
360	ST 150X150X5.0SHS	4.03	0.877
361	ST 150X150X5.0SHS	4.03	0.877
366	ST 150X150X5.0SHS	1.99	0.434
368	ST 150X150X5.0SHS	2.01	0.437
433	ST 150X150X8.0SHS	3.50	1.178
434	ST 150X150X8.0SHS	4.85	1.631
435	ST 150X150X5.0SHS	4.18	0.910

436	ST	180X180X6.0SHS	3.50	1.098
437	ST	180X180X8.0SHS	4.85	1.988
438	ST	180X180X6.0SHS	4.18	1.309
439	ST	180X180X6.0SHS	3.50	1.098
440	ST	180X180X6.0SHS	4.85	1.521
441	ST	180X180X10.0SHS	4.18	2.098
442	ST	150X150X5.0SHS	3.50	0.763
443	ST	150X150X5.0SHS	4.85	1.056
444	ST	150X150X5.0SHS	4.18	0.910
445	ST	72X72X3.2SHS	3.98	0.261
446	ST	72X72X3.2SHS	3.98	0.261
447	ST	72X72X3.2SHS	3.98	0.261
448	ST	72X72X3.2SHS	4.01	0.263
449	ST	100X100X6.0SHS	4.01	0.666
450	ST	72X72X3.2SHS	4.01	0.263
508	ST	150X150X5.0SHS	5.77	1.257
509	ST	120X120X6.0SHS	6.27	1.273
510	ST	100X100X6.0SHS	5.30	0.881
511	ST	100X100X6.0SHS	5.77	0.958
533	ST	150X150X8.0SHS	1.50	0.505
534	ST	150X150X5.0SHS	1.50	0.327
536	ST	150X150X8.0SHS	1.85	0.623
537	ST	150X150X6.0SHS	1.50	0.388
538	ST	150X150X4.5SHS	2.24	0.442
539	ST	150X150X5.0SHS	1.50	0.327
541	ST	150X150X5.0SHS	1.50	0.327
543	ST	150X150X6.0SHS	3.29	0.849
545	ST	150X150X5.0SHS	1.50	0.327
547	ST	150X150X5.0SHS	1.81	0.395
549	ST	150X150X5.0SHS	1.50	0.327
551	ST	150X150X6.0SHS	1.50	0.388
553	ST	150X150X6.0SHS	1.50	0.388
554	ST	150X150X8.0SHS	3.29	1.106
555	ST	150X150X8.0SHS	2.71	0.913
556	ST	150X150X5.0SHS	1.81	0.395
557	ST	150X150X5.0SHS	0.56	0.121
558	ST	150X150X5.0SHS	1.50	0.327
559	ST	150X150X5.0SHS	1.84	0.400
567	ST	150X150X5.0SHS	1.50	0.327
568	ST	150X150X5.0SHS	1.50	0.327
569	ST	150X150X5.0SHS	1.50	0.327
570	ST	150X150X5.0SHS	1.50	0.327
571	ST	150X150X8.0SHS	1.50	0.505
572	ST	150X150X8.0SHS	1.50	0.505
573	ST	150X150X8.0SHS	1.50	0.505
574	ST	150X150X8.0SHS	1.50	0.505
575	ST	150X150X8.0SHS	1.50	0.505
576	ST	150X150X8.0SHS	1.50	0.505
577	ST	150X150X5.0SHS	1.50	0.327
578	ST	150X150X5.0SHS	1.50	0.327
579	ST	150X150X5.0SHS	1.50	0.327
580	ST	150X150X5.0SHS	1.50	0.327
581	ST	150X150X4.5SHS	2.12	0.418
582	ST	150X150X4.5SHS	2.00	0.395
583	ST	150X150X4.5SHS	1.88	0.371
584	ST	150X150X4.5SHS	1.76	0.347

585	ST	150X150X4.5SHS	1.64	0.323
586	ST	150X150X4.5SHS	1.52	0.299
587	ST	150X150X4.5SHS	1.40	0.276
588	ST	150X150X4.5SHS	2.12	0.418
589	ST	150X150X4.5SHS	2.00	0.395
590	ST	150X150X4.5SHS	1.88	0.371
591	ST	150X150X4.5SHS	1.76	0.347
592	ST	150X150X4.5SHS	1.64	0.323
593	ST	150X150X4.5SHS	1.52	0.299
594	ST	150X150X4.5SHS	1.40	0.276
595	ST	175X175X5.0SHS	10.69	2.740
596	ST	175X175X5.0SHS	10.69	2.740
597	ST	175X175X5.0SHS	10.59	2.714
598	ST	150X150X6.0SHS	10.49	2.711
599	ST	175X175X5.0SHS	10.39	2.664
600	ST	150X150X5.0SHS	10.30	2.243
601	ST	180X180X6.0SHS	10.20	3.198
602	ST	180X180X6.0SHS	10.10	3.168
605	ST	175X175X5.0SHS	10.59	2.714
606	ST	150X150X5.0SHS	10.49	2.286
607	ST	220X220X6.0SHS	10.39	4.027
608	ST	150X150X6.0SHS	10.30	2.660
609	ST	180X180X6.0SHS	10.20	3.199
610	ST	180X180X6.0SHS	10.10	3.168
611	ST	100X100X6.0SHS	8.86	1.473
612	ST	100X100X6.0SHS	2.83	0.470
613	ST	150X150X5.0SHS	8.85	1.928
614	ST	150X150X5.0SHS	5.68	1.238
617	ST	150X150X6.0SHS	5.60	1.448
619	ST	180X180X6.0SHS	4.02	1.262
620	ST	150X150X8.0SHS	5.63	1.893
622	ST	180X180X8.0SHS	4.02	1.650
623	ST	150X150X5.0SHS	5.79	1.261
624	ST	150X150X8.0SHS	6.29	2.117
625	ST	100X100X6.0SHS	5.32	0.885
626	ST	120X120X6.0SHS	5.79	1.175
627	ST	100X100X6.0SHS	2.83	0.470
628	ST	50X50X3.6SHS	2.83	0.138
688	ST	96X48X4.8RHS	4.88	0.461
689	ST	96X48X4.8RHS	4.88	0.461
690	ST	96X48X4.8RHS	4.88	0.461
691	ST	96X48X4.8RHS	4.88	0.461
692	ST	96X48X4.8RHS	4.88	0.461
693	ST	96X48X4.8RHS	4.88	0.461
694	ST	96X48X4.8RHS	4.88	0.461
695	ST	96X48X4.8RHS	4.88	0.461
696	ST	96X48X4.8RHS	4.88	0.461
697	ST	96X48X4.8RHS	4.88	0.461
698	ST	96X48X4.8RHS	4.88	0.461
699	ST	96X48X4.8RHS	4.88	0.461
700	ST	96X48X4.8RHS	4.88	0.461
701	ST	96X48X4.8RHS	4.88	0.461
702	ST	96X48X4.8RHS	4.88	0.461
703	ST	96X48X4.8RHS	4.88	0.461
704	ST	96X48X4.8RHS	4.88	0.461
705	ST	250X250X10.0SHS	5.71	4.099

706	ST	180X180X6.0SHS	5.71	1.792
707	ST	150X150X8.0SHS	5.71	1.922
708	ST	220X220X8.0SHS	5.71	2.904
709	ST	150X150X5.0SHS	5.71	1.244
710	ST	220X220X8.0SHS	5.71	2.904
711	ST	150X150X5.0SHS	5.71	1.244
712	ST	120X120X6.0SHS	5.71	1.160
713	ST	180X180X6.0SHS	5.71	1.792
714	ST	150X150X8.0SHS	5.71	1.922
715	ST	180X180X8.0SHS	5.71	2.343
716	ST	150X150X5.0SHS	5.71	1.244
717	ST	220X220X8.0SHS	5.71	2.904
718	ST	150X150X5.0SHS	5.71	1.244
719	ST	120X120X6.0SHS	5.71	1.160
722	ST	180X180X6.0SHS	4.88	1.529
723	ST	150X150X8.0SHS	5.71	1.922
724	ST	150X150X8.0SHS	5.71	1.922
725	ST	150X150X5.0SHS	4.88	1.062
726	ST	120X120X6.0SHS	4.88	0.990
727	ST	150X150X5.0SHS	4.88	1.062
732	ST	150X150X8.0SHS	6.29	2.117
733	ST	180X180X6.0SHS	6.31	1.980
807	ST	96X48X4.8RHS	1.50	0.142
808	ST	96X48X4.8RHS	1.50	0.142
809	ST	150X150X8.0SHS	1.50	0.505
810	ST	150X150X8.0SHS	1.50	0.505
825	ST	220X220X8.0SHS	1.50	0.763
826	ST	50X50X3.6SHS	0.75	0.037
827	ST	50X50X3.6SHS	0.75	0.037
828	ST	50X50X3.6SHS	1.50	0.073
829	ST	50X50X3.6SHS	1.50	0.073
830	ST	72X72X5.0SHS	1.50	0.147
831	ST	50X50X3.6SHS	1.50	0.073
832	ST	50X50X3.6SHS	1.50	0.073
833	ST	72X72X5.0SHS	1.50	0.147
834	ST	50X50X3.6SHS	1.50	0.073
835	ST	50X50X3.6SHS	1.50	0.073
836	ST	100X100X6.0SHS	1.50	0.249
837	ST	50X50X3.6SHS	1.50	0.073
838	ST	50X50X3.6SHS	1.50	0.073
839	ST	72X72X3.2SHS	1.50	0.098
840	ST	50X50X3.6SHS	1.50	0.073
848	ST	96X48X4.8RHS	1.50	0.142
849	ST	250X250X10.0SHS	0.75	0.538
850	ST	50X50X3.6SHS	0.75	0.037
851	ST	50X50X3.6SHS	0.75	0.037
852	ST	250X250X10.0SHS	0.75	0.538
853	ST	50X50X3.6SHS	0.75	0.037
854	ST	250X250X10.0SHS	0.75	0.538
855	ST	50X50X3.6SHS	0.75	0.037
856	ST	50X50X3.6SHS	0.75	0.037
857	ST	50X50X3.6SHS	0.75	0.037
858	ST	50X50X3.6SHS	0.75	0.037
859	ST	250X250X10.0SHS	0.75	0.538
860	ST	50X50X3.6SHS	0.75	0.037
861	ST	250X250X10.0SHS	0.75	0.538

862	ST	50X50X3.6SHS	0.75	0.037
863	ST	50X50X3.6SHS	0.75	0.037
864	ST	96X48X4.8RHS	1.50	0.142
865	ST	96X48X4.8RHS	1.50	0.142
866	ST	96X48X4.8RHS	1.50	0.142
867	ST	96X48X4.8RHS	1.50	0.142
868	ST	96X48X4.8RHS	1.50	0.142
869	ST	96X48X4.8RHS	1.50	0.142
870	ST	96X48X4.8RHS	1.50	0.142
871	ST	96X48X4.8RHS	1.50	0.142
872	ST	96X48X4.8RHS	1.50	0.142
873	ST	96X48X4.8RHS	1.50	0.142
874	ST	96X48X4.8RHS	1.50	0.142
875	ST	96X48X4.8RHS	1.50	0.142
876	ST	96X48X4.8RHS	1.50	0.142
877	ST	96X48X4.8RHS	1.50	0.142
878	ST	50X50X3.6SHS	1.50	0.073
879	ST	50X50X3.6SHS	1.50	0.073
880	ST	50X50X3.6SHS	1.50	0.073
904	ST	150X150X8.0SHS	4.18	1.404
905	ST	180X180X6.0SHS	4.18	1.310
906	ST	180X180X6.0SHS	4.18	1.310
907	ST	150X150X5.0SHS	4.18	0.910
996	ST	150X150X5.0SHS	0.83	0.181
997	ST	180X180X8.0SHS	0.80	0.328
998	ST	150X150X5.0SHS	3.99	0.868
999	ST	150X150X5.0SHS	3.99	0.868
1042	ST	150X150X5.0SHS	4.03	0.877
1043	ST	150X150X5.0SHS	4.03	0.877
1044	ST	150X150X6.0SHS	1.99	0.514
1045	ST	150X150X5.0SHS	2.01	0.437
1046	ST	150X150X8.0SHS	3.50	1.178
1047	ST	150X150X8.0SHS	4.85	1.631
1048	ST	150X150X5.0SHS	4.18	0.910
1049	ST	180X180X6.0SHS	3.50	1.098
1050	ST	180X180X8.0SHS	4.85	1.988
1051	ST	180X180X8.0SHS	4.18	1.712
1052	ST	180X180X6.0SHS	3.50	1.098
1053	ST	180X180X8.0SHS	4.85	1.988
1054	ST	180X180X10.0SHS	4.18	2.098
1055	ST	150X150X5.0SHS	3.50	0.763
1056	ST	150X150X5.0SHS	4.85	1.056
1057	ST	150X150X5.0SHS	4.18	0.910
1058	ST	72X72X3.2SHS	3.98	0.261
1059	ST	72X72X3.2SHS	3.98	0.261
1060	ST	72X72X3.2SHS	3.98	0.261
1061	ST	72X72X3.2SHS	4.01	0.263
1062	ST	72X72X3.2SHS	4.01	0.263
1063	ST	72X72X3.2SHS	4.01	0.263
1086	ST	150X150X8.0SHS	5.77	1.940
1087	ST	100X100X6.0SHS	6.27	1.042
1088	ST	100X100X6.0SHS	5.30	0.881
1089	ST	100X100X6.0SHS	5.77	0.958
1102	ST	150X150X8.0SHS	1.50	0.505
1103	ST	180X180X8.0SHS	1.50	0.615
1104	ST	150X150X8.0SHS	1.85	0.623

1105	ST	150X150X5.0SHS	1.50	0.327
1106	ST	150X150X4.5SHS	2.24	0.442
1107	ST	150X150X5.0SHS	1.50	0.327
1108	ST	150X150X5.0SHS	1.50	0.327
1109	ST	150X150X5.0SHS	3.29	0.716
1110	ST	150X150X5.0SHS	1.50	0.327
1111	ST	150X150X5.0SHS	1.81	0.395
1112	ST	150X150X5.0SHS	1.50	0.327
1113	ST	150X150X6.0SHS	1.50	0.388
1114	ST	150X150X5.0SHS	1.50	0.327
1115	ST	150X150X5.0SHS	3.29	0.716
1116	ST	150X150X5.0SHS	2.71	0.591
1117	ST	150X150X5.0SHS	1.81	0.395
1118	ST	150X150X5.0SHS	0.56	0.121
1119	ST	150X150X5.0SHS	1.50	0.327
1120	ST	150X150X5.0SHS	1.84	0.400
1121	ST	150X150X5.0SHS	1.50	0.327
1122	ST	150X150X5.0SHS	1.50	0.327
1123	ST	150X150X5.0SHS	1.50	0.327
1124	ST	150X150X8.0SHS	1.50	0.505
1125	ST	150X150X8.0SHS	1.50	0.505
1126	ST	150X150X8.0SHS	1.50	0.505
1127	ST	150X150X8.0SHS	1.50	0.505
1128	ST	150X150X8.0SHS	1.50	0.505
1129	ST	150X150X8.0SHS	1.50	0.505
1130	ST	150X150X8.0SHS	1.50	0.505
1131	ST	150X150X5.0SHS	1.50	0.327
1132	ST	150X150X5.0SHS	1.50	0.327
1133	ST	150X150X5.0SHS	1.50	0.327
1134	ST	150X150X5.0SHS	1.50	0.327
1135	ST	150X150X4.5SHS	2.12	0.418
1136	ST	150X150X4.5SHS	2.00	0.395
1137	ST	150X150X4.5SHS	1.88	0.371
1138	ST	150X150X4.5SHS	1.76	0.347
1139	ST	150X150X4.5SHS	1.64	0.323
1140	ST	150X150X8.0SHS	1.52	0.511
1141	ST	150X150X4.5SHS	1.40	0.276
1142	ST	150X150X4.5SHS	2.12	0.418
1143	ST	150X150X4.5SHS	2.00	0.395
1144	ST	150X150X4.5SHS	1.88	0.371
1145	ST	150X150X4.5SHS	1.76	0.347
1146	ST	150X150X4.5SHS	1.64	0.323
1147	ST	150X150X4.5SHS	1.52	0.299
1148	ST	150X150X4.5SHS	1.40	0.276
1149	ST	175X175X5.0SHS	10.69	2.740
1150	ST	175X175X5.0SHS	10.69	2.740
1151	ST	175X175X5.0SHS	10.59	2.714
1152	ST	150X150X6.0SHS	10.49	2.711
1153	ST	150X150X5.0SHS	10.39	2.264
1154	ST	180X180X6.0SHS	10.30	3.229
1155	ST	180X180X6.0SHS	10.20	3.198
1156	ST	220X220X8.0SHS	10.10	5.136
1157	ST	150X150X5.0SHS	10.59	2.308
1158	ST	150X150X6.0SHS	10.49	2.711
1159	ST	220X220X6.0SHS	10.39	4.027
1160	ST	220X220X6.0SHS	10.30	3.989

1161	ST	220X220X6.0SHS	10.20	3.951
1162	ST	220X220X6.0SHS	10.10	3.913
1163	ST	150X150X5.0SHS	8.86	1.931
1164	ST	100X100X6.0SHS	2.83	0.470
1165	ST	150X150X5.0SHS	8.85	1.928
1166	ST	150X150X5.0SHS	5.68	1.238
1169	ST	120X120X6.0SHS	5.60	1.138
1171	ST	180X180X8.0SHS	4.02	1.650
1172	ST	150X150X8.0SHS	5.63	1.893
1174	ST	180X180X8.0SHS	4.02	1.650
1175	ST	120X120X6.0SHS	5.79	1.175
1176	ST	150X150X5.0SHS	6.29	1.371
1177	ST	100X100X6.0SHS	5.32	0.885
1178	ST	150X150X5.0SHS	5.79	1.261
1179	ST	100X100X6.0SHS	2.83	0.470
1180	ST	50X50X3.6SHS	2.83	0.138
1216	ST	250X250X10.0SHS	0.75	0.538
1217	ST	250X250X10.0SHS	0.75	0.538
1218	ST	250X250X10.0SHS	0.75	0.538
1219	ST	250X250X10.0SHS	0.75	0.538
1220	ST	250X250X10.0SHS	0.75	0.538
1229	ST	150X150X5.0SHS	0.56	0.122
1231	ST	150X150X5.0SHS	0.56	0.122
1232	ST	50X50X3.6SHS	0.75	0.037
1233	ST	150X150X6.0SHS	2.71	0.701
1235	ST	150X150X5.0SHS	2.71	0.591
1236	ST	50X50X3.6SHS	0.75	0.037
1237	ST	150X150X5.0SHS	1.50	0.327
1239	ST	150X150X5.0SHS	1.50	0.327
1240	ST	50X50X3.6SHS	0.75	0.037
1241	ST	150X150X5.0SHS	1.50	0.327
1243	ST	150X150X5.0SHS	1.50	0.327
1244	ST	50X50X3.6SHS	0.75	0.037
1934	ST	150X150X4.5SHS	2.24	0.442
1935	ST	150X150X4.5SHS	1.74	0.344
1936	ST	150X150X4.5SHS	1.74	0.343
1937	ST	150X150X4.5SHS	2.24	0.442
1938	ST	150X150X4.5SHS	1.74	0.344
1939	ST	150X150X4.5SHS	1.74	0.343
1940	ST	150X150X4.5SHS	2.24	0.442
1942	ST	150X150X4.5SHS	1.74	0.344
1944	ST	150X150X4.5SHS	1.74	0.343
1946	ST	150X150X4.5SHS	2.24	0.442
1948	ST	150X150X4.5SHS	1.74	0.344
1950	ST	150X150X4.5SHS	1.74	0.343
1952	ST	150X150X4.5SHS	2.24	0.442
1954	ST	150X150X4.5SHS	1.74	0.344
1956	ST	150X150X4.5SHS	1.74	0.343
1958	ST	150X150X4.5SHS	2.24	0.442
1960	ST	150X150X4.5SHS	1.74	0.344
1962	ST	150X150X4.5SHS	1.74	0.343
1964	ST	150X150X4.5SHS	1.74	0.343
1965	ST	150X150X4.5SHS	1.74	0.344
1966	ST	150X150X4.5SHS	2.24	0.442
1967	ST	150X150X4.5SHS	1.74	0.343
1968	ST	150X150X4.5SHS	1.74	0.344

1969	ST	150X150X4.5SHS	2.24	0.442
1970	ST	150X150X4.5SHS	1.74	0.343
1971	ST	150X150X4.5SHS	1.74	0.344
1972	ST	150X150X4.5SHS	2.24	0.442
1973	ST	150X150X4.5SHS	1.74	0.343
1974	ST	150X150X4.5SHS	1.74	0.344
1975	ST	150X150X4.5SHS	2.24	0.442
1976	ST	150X150X4.5SHS	1.74	0.343
1977	ST	150X150X4.5SHS	1.74	0.344
1978	ST	150X150X4.5SHS	2.24	0.442
1979	ST	150X150X4.5SHS	1.74	0.343
1980	ST	150X150X4.5SHS	1.74	0.344
1981	ST	150X150X4.5SHS	2.24	0.442
1982	ST	150X150X4.5SHS	1.74	0.343
1983	ST	150X150X4.5SHS	1.74	0.344
1984	ST	150X150X4.5SHS	2.24	0.442
1985	ST	150X150X4.5SHS	1.74	0.343
1986	ST	150X150X4.5SHS	1.74	0.344
1987	ST	150X150X4.5SHS	2.24	0.442
1988	ST	150X150X4.5SHS	1.74	0.343
1989	ST	150X150X4.5SHS	1.74	0.344
1990	ST	150X150X4.5SHS	2.24	0.442
1991	ST	150X150X4.5SHS	1.74	0.343
1992	ST	150X150X4.5SHS	1.74	0.344
1993	ST	150X150X4.5SHS	2.24	0.442
1994	ST	150X150X4.5SHS	1.74	0.343
1995	ST	150X150X4.5SHS	1.74	0.344
1996	ST	150X150X4.5SHS	2.24	0.442
1997	ST	150X150X4.5SHS	1.74	0.343
1998	ST	150X150X4.5SHS	1.74	0.344
1999	ST	150X150X4.5SHS	2.24	0.442
2000	ST	150X150X4.5SHS	1.74	0.343
2001	ST	150X150X4.5SHS	1.74	0.344
2002	ST	150X150X4.5SHS	2.24	0.442
2003	ST	150X150X4.5SHS	1.74	0.343
2004	ST	150X150X4.5SHS	1.74	0.344
2005	ST	150X150X4.5SHS	2.24	0.442
2006	ST	150X150X4.5SHS	1.74	0.343
2007	ST	150X150X4.5SHS	1.74	0.344
2008	ST	150X150X4.5SHS	2.24	0.442
2009	ST	150X150X4.5SHS	1.74	0.343
2010	ST	150X150X4.5SHS	1.74	0.344
2011	ST	150X150X4.5SHS	2.24	0.442
2012	ST	150X150X5.0SHS	1.74	0.379
2013	ST	150X150X5.0SHS	1.74	0.380
2014	ST	150X150X5.0SHS	2.24	0.489
2015	ST	150X150X8.0SHS	1.74	0.585
2016	ST	150X150X8.0SHS	1.74	0.586
2017	ST	150X150X8.0SHS	2.24	0.754
2018	ST	150X150X4.5SHS	1.74	0.343
2019	ST	150X150X4.5SHS	1.74	0.344
2020	ST	150X150X4.5SHS	2.24	0.442
2021	ST	150X150X4.5SHS	1.74	0.343
2022	ST	150X150X4.5SHS	1.74	0.344
2023	ST	150X150X4.5SHS	2.24	0.442
2024	ST	150X150X4.5SHS	1.74	0.343

2025	ST	150X150X4.5SHS	1.74	0.344
2026	ST	150X150X4.5SHS	2.24	0.442
2027	ST	150X150X4.5SHS	1.74	0.343
2028	ST	150X150X4.5SHS	1.74	0.344
2029	ST	150X150X4.5SHS	2.24	0.442
2030	ST	150X150X4.5SHS	1.74	0.343
2031	ST	150X150X4.5SHS	1.74	0.344
2032	ST	150X150X4.5SHS	2.24	0.442
2033	ST	150X150X5.0SHS	1.74	0.379
2034	ST	150X150X5.0SHS	1.74	0.380
2035	ST	150X150X5.0SHS	2.24	0.489
2036	ST	50X50X3.6SHS	1.50	0.073
2037	ST	50X50X3.6SHS	1.50	0.073
2038	ST	50X50X3.6SHS	1.50	0.073
2039	ST	50X50X3.6SHS	1.50	0.073
2040	ST	50X50X3.6SHS	1.50	0.073
2041	ST	50X50X3.6SHS	1.50	0.073
2042	ST	50X50X3.6SHS	1.50	0.073
2043	ST	50X50X3.6SHS	1.50	0.073
2044	ST	50X50X3.6SHS	1.50	0.073
2045	ST	50X50X3.6SHS	1.50	0.073
2046	ST	50X50X3.6SHS	1.50	0.073
2047	ST	50X50X3.6SHS	1.50	0.073
2048	ST	50X50X3.6SHS	1.50	0.073
2049	ST	50X50X3.6SHS	1.50	0.073
2050	ST	50X50X3.6SHS	1.50	0.073
2051	ST	50X50X3.6SHS	1.50	0.073
2052	ST	50X50X3.6SHS	1.50	0.073
2053	ST	50X50X3.6SHS	1.50	0.073
2054	ST	50X50X3.6SHS	1.50	0.073
2055	ST	50X50X3.6SHS	1.50	0.073
2056	ST	50X50X3.6SHS	1.50	0.073
2057	ST	50X50X3.6SHS	1.50	0.073
2058	ST	50X50X3.6SHS	1.50	0.073
2059	ST	50X50X3.6SHS	1.50	0.073
2060	ST	50X50X3.6SHS	1.50	0.073
2061	ST	50X50X3.6SHS	1.50	0.073
2062	ST	50X50X3.6SHS	1.50	0.073
2063	ST	50X50X3.6SHS	1.50	0.073
2064	ST	50X50X3.6SHS	1.50	0.073
2065	ST	50X50X3.6SHS	1.50	0.073
2066	ST	50X50X3.6SHS	1.50	0.073
2067	ST	50X50X3.6SHS	1.50	0.073
2068	ST	50X50X3.6SHS	1.50	0.073
2069	ST	50X50X3.6SHS	1.50	0.073
2070	ST	50X50X3.6SHS	1.50	0.073
2071	ST	50X50X3.6SHS	1.50	0.073
2072	ST	50X50X3.6SHS	1.50	0.073
2073	ST	50X50X3.6SHS	1.50	0.073
2074	ST	50X50X3.6SHS	1.50	0.073
2075	ST	50X50X3.6SHS	1.50	0.073
2076	ST	50X50X3.6SHS	1.50	0.073
2077	ST	50X50X3.6SHS	1.50	0.073
2078	ST	50X50X3.6SHS	1.50	0.073
2079	ST	50X50X3.6SHS	1.50	0.073
2080	ST	50X50X3.6SHS	1.50	0.073

2082	ST	50X50X3.6SHS	2.30	0.112
2083	ST	72X72X3.2SHS	2.70	0.177
2084	ST	72X72X5.0SHS	2.05	0.201
2086	ST	50X50X3.6SHS	2.30	0.112
2087	ST	50X50X3.6SHS	2.70	0.132
2089	ST	50X50X3.6SHS	2.30	0.112
2090	ST	50X50X3.6SHS	2.70	0.132
2092	ST	50X50X3.6SHS	2.30	0.112
2093	ST	50X50X3.6SHS	2.70	0.132
2095	ST	50X50X3.6SHS	2.30	0.112
2096	ST	50X50X3.6SHS	2.70	0.132
2098	ST	50X50X3.6SHS	2.30	0.112
2099	ST	50X50X3.6SHS	2.70	0.132
2101	ST	50X50X3.6SHS	2.30	0.112
2102	ST	50X50X3.6SHS	2.70	0.132
2104	ST	50X50X3.6SHS	2.30	0.112
2105	ST	50X50X3.6SHS	2.70	0.132
2107	ST	50X50X3.6SHS	2.30	0.112
2108	ST	50X50X3.6SHS	2.70	0.132
2110	ST	50X50X3.6SHS	2.30	0.112
2111	ST	50X50X3.6SHS	2.70	0.132
2113	ST	50X50X3.6SHS	2.30	0.112
2114	ST	50X50X3.6SHS	2.70	0.132
2116	ST	50X50X3.6SHS	2.30	0.112
2117	ST	50X50X3.6SHS	2.70	0.132
2119	ST	50X50X3.6SHS	2.30	0.112
2120	ST	50X50X3.6SHS	2.70	0.132
2122	ST	50X50X3.6SHS	2.30	0.112
2123	ST	50X50X3.6SHS	2.70	0.132
2125	ST	50X50X3.6SHS	2.30	0.112
2126	ST	50X50X3.6SHS	2.70	0.132
2127	ST	72X72X5.0SHS	2.13	0.209
2128	ST	72X72X5.0SHS	2.22	0.218
2129	ST	72X72X5.0SHS	2.31	0.227
2130	ST	150X150X8.0SHS	2.41	0.809
2131	ST	150X150X8.0SHS	2.50	0.841
2132	ST	150X150X8.0SHS	2.60	0.874
2133	ST	150X150X8.0SHS	2.70	0.908
2134	ST	150X150X8.0SHS	2.60	0.874
2135	ST	150X150X8.0SHS	2.50	0.841
2136	ST	150X150X8.0SHS	2.41	0.809
2137	ST	72X72X5.0SHS	2.31	0.227
2138	ST	72X72X5.0SHS	2.22	0.218
2139	ST	72X72X5.0SHS	2.13	0.209
2140	ST	72X72X5.0SHS	2.05	0.201
2141	ST	72X72X5.0SHS	4.30	0.421
2142	ST	120X120X6.0SHS	4.29	0.872
2143	ST	120X120X6.0SHS	4.30	0.873
2144	ST	120X120X6.0SHS	4.29	0.872
2145	ST	150X150X5.0SHS	1.99	0.434
2146	ST	150X150X8.0SHS	1.85	0.623
2147	ST	150X150X6.0SHS	1.99	0.514
2148	ST	150X150X8.0SHS	1.85	0.623
2149	ST	50X50X3.6SHS	1.50	0.073
2150	ST	50X50X3.6SHS	0.75	0.037
2151	ST	150X150X4.5SHS	1.00	0.198

2152	ST	150X150X4.5SHS	1.00	0.198
2153	ST	50X50X3.6SHS	1.50	0.073
2154	ST	150X150X4.5SHS	1.00	0.198
2155	ST	150X150X4.5SHS	1.00	0.198
2156	ST	50X50X3.6SHS	1.50	0.073
2157	ST	150X150X4.5SHS	1.00	0.198
2158	ST	150X150X4.5SHS	1.00	0.198
2159	ST	50X50X3.6SHS	1.50	0.073
2160	ST	150X150X8.0SHS	1.00	0.337
2161	ST	150X150X4.5SHS	1.00	0.198
2162	ST	50X50X3.6SHS	1.50	0.073
2163	ST	150X150X4.5SHS	1.00	0.198
2164	ST	150X150X4.5SHS	1.00	0.198
2165	ST	50X50X3.6SHS	1.50	0.073
2166	ST	150X150X4.5SHS	1.00	0.198
2167	ST	150X150X4.5SHS	1.00	0.198
2168	ST	50X50X3.6SHS	1.50	0.073
2169	ST	150X150X4.5SHS	1.00	0.198
2170	ST	150X150X4.5SHS	1.00	0.198
2171	ST	50X50X3.6SHS	1.50	0.073
2172	ST	150X150X8.0SHS	1.00	0.337
2173	ST	150X150X5.0SHS	1.00	0.218
2174	ST	50X50X3.6SHS	1.50	0.073
2175	ST	150X150X4.5SHS	1.00	0.198
2176	ST	150X150X8.0SHS	1.00	0.337
2177	ST	50X50X3.6SHS	1.50	0.073
2178	ST	150X150X8.0SHS	1.00	0.337
2179	ST	150X150X4.5SHS	1.00	0.198
2180	ST	50X50X3.6SHS	1.50	0.073
2181	ST	150X150X4.5SHS	1.00	0.198
2182	ST	150X150X4.5SHS	1.00	0.198
2183	ST	50X50X3.6SHS	1.50	0.073
2184	ST	150X150X8.0SHS	1.00	0.337
2185	ST	150X150X4.5SHS	1.00	0.198
2186	ST	50X50X3.6SHS	1.50	0.073
2187	ST	150X150X4.5SHS	1.00	0.198
2188	ST	150X150X4.5SHS	1.00	0.198
2189	ST	50X50X3.6SHS	1.50	0.073
2190	ST	150X150X4.5SHS	1.00	0.198
2191	ST	150X150X4.5SHS	1.00	0.198
2192	ST	50X50X3.6SHS	1.50	0.073
2193	ST	150X150X4.5SHS	1.00	0.198
2194	ST	150X150X5.0SHS	1.00	0.218
2195	ST	50X50X3.6SHS	1.50	0.073
2196	ST	72X72X5.0SHS	2.30	0.225
2197	ST	72X72X5.0SHS	2.30	0.225
2198	ST	72X72X5.0SHS	2.30	0.225
2199	ST	72X72X5.0SHS	2.30	0.225
2200	ST	72X72X5.0SHS	2.30	0.225
2201	ST	72X72X5.0SHS	2.30	0.225
2202	ST	72X72X5.0SHS	2.30	0.225
2203	ST	120X120X6.0SHS	2.30	0.466
2204	ST	72X72X5.0SHS	2.30	0.225
2205	ST	72X72X5.0SHS	2.30	0.225
2206	ST	72X72X5.0SHS	2.30	0.225
2207	ST	72X72X5.0SHS	2.30	0.225

2208	ST	72X72X5.0SHS	2.30	0.225
2209	ST	72X72X5.0SHS	2.30	0.225
2210	ST	72X72X5.0SHS	2.30	0.225
2211	ST	72X72X3.2SHS	2.49	0.163
2212	ST	72X72X5.0SHS	2.49	0.244
2213	ST	50X50X3.6SHS	2.38	0.116
2214	ST	72X72X5.0SHS	2.38	0.234
2215	ST	150X150X6.0SHS	1.50	0.388
2216	ST	150X150X6.0SHS	1.50	0.388
2217	ST	150X150X6.0SHS	1.50	0.388
2218	ST	150X150X6.0SHS	1.50	0.388
2219	ST	150X150X6.0SHS	1.50	0.388
2220	ST	150X150X6.0SHS	1.50	0.388
2221	ST	50X50X3.6SHS	0.75	0.037
2222	ST	50X50X3.6SHS	0.75	0.037
2223	ST	50X50X3.6SHS	0.75	0.037
2224	ST	50X50X3.6SHS	2.12	0.103
2225	ST	50X50X3.6SHS	2.12	0.103
2226	ST	50X50X3.6SHS	2.12	0.103
2227	ST	50X50X3.6SHS	2.12	0.103
2228	ST	150X150X5.0SHS	1.50	0.327
2229	ST	150X150X5.0SHS	1.50	0.327
2230	ST	50X50X3.6SHS	0.75	0.037
2231	ST	150X150X5.0SHS	1.50	0.327
2232	ST	150X150X5.0SHS	1.50	0.327
2233	ST	50X50X3.6SHS	0.75	0.037
2234	ST	72X72X3.2SHS	2.12	0.139
2235	ST	150X150X5.0SHS	1.50	0.327
2236	ST	50X50X3.6SHS	2.12	0.103
2237	ST	50X50X3.6SHS	2.12	0.103
2238	ST	50X50X3.6SHS	2.12	0.103
2239	ST	150X150X5.0SHS	1.50	0.327
2240	ST	150X150X5.0SHS	1.50	0.327
2241	ST	50X50X3.6SHS	0.75	0.037
2242	ST	150X150X5.0SHS	1.50	0.327
2243	ST	150X150X5.0SHS	1.50	0.327
2244	ST	50X50X3.6SHS	0.75	0.037
2245	ST	50X50X3.6SHS	2.12	0.103
2246	ST	150X150X5.0SHS	1.50	0.327
2247	ST	50X50X3.6SHS	2.12	0.103
2248	ST	50X50X3.6SHS	2.12	0.103
2249	ST	50X50X3.6SHS	2.12	0.103
2250	ST	150X150X5.0SHS	1.50	0.327
2251	ST	150X150X5.0SHS	1.50	0.327
2252	ST	50X50X3.6SHS	0.75	0.037
2253	ST	150X150X5.0SHS	1.50	0.327
2254	ST	150X150X5.0SHS	1.50	0.327
2255	ST	50X50X3.6SHS	0.75	0.037
2256	ST	50X50X3.6SHS	2.12	0.103
2257	ST	150X150X5.0SHS	1.50	0.327
2258	ST	50X50X3.6SHS	2.12	0.103
2259	ST	50X50X3.6SHS	2.12	0.103
2260	ST	50X50X3.6SHS	2.12	0.103
2261	ST	150X150X5.0SHS	1.50	0.327
2262	ST	150X150X5.0SHS	1.50	0.327
2263	ST	50X50X3.6SHS	0.75	0.037

2264	ST	150X150X5.0SHS	1.50	0.327
2265	ST	150X150X5.0SHS	1.50	0.327
2266	ST	50X50X3.6SHS	0.75	0.037
2267	ST	50X50X3.6SHS	2.12	0.103
2268	ST	150X150X5.0SHS	1.50	0.327
2269	ST	50X50X3.6SHS	2.12	0.103
2270	ST	50X50X3.6SHS	2.12	0.103
2271	ST	50X50X3.6SHS	2.12	0.103
2272	ST	150X150X6.0SHS	1.50	0.388
2273	ST	150X150X5.0SHS	1.50	0.327
2274	ST	50X50X3.6SHS	0.75	0.037
2275	ST	150X150X6.0SHS	1.50	0.388
2276	ST	150X150X5.0SHS	1.50	0.327
2277	ST	50X50X3.6SHS	0.75	0.037
2278	ST	50X50X3.6SHS	2.12	0.103
2279	ST	150X150X6.0SHS	1.50	0.388
2280	ST	50X50X3.6SHS	2.12	0.103
2281	ST	50X50X3.6SHS	2.12	0.103
2282	ST	50X50X3.6SHS	2.12	0.103
2283	ST	150X150X6.0SHS	1.50	0.388
2284	ST	150X150X5.0SHS	1.50	0.327
2285	ST	50X50X3.6SHS	0.75	0.037
2286	ST	150X150X6.0SHS	1.50	0.388
2287	ST	150X150X5.0SHS	1.50	0.327
2288	ST	50X50X3.6SHS	0.75	0.037
2289	ST	50X50X3.6SHS	2.12	0.103
2290	ST	150X150X6.0SHS	1.50	0.388
2291	ST	50X50X3.6SHS	2.12	0.103
2292	ST	50X50X3.6SHS	2.12	0.103
2293	ST	50X50X3.6SHS	2.12	0.103
2294	ST	150X150X5.0SHS	1.50	0.327
2295	ST	150X150X5.0SHS	1.50	0.327
2296	ST	50X50X3.6SHS	0.75	0.037
2297	ST	150X150X5.0SHS	1.50	0.327
2298	ST	150X150X5.0SHS	1.50	0.327
2299	ST	50X50X3.6SHS	0.75	0.037
2300	ST	50X50X3.6SHS	2.12	0.103
2301	ST	150X150X5.0SHS	1.50	0.327
2302	ST	50X50X3.6SHS	2.12	0.103
2303	ST	50X50X3.6SHS	2.12	0.103
2304	ST	50X50X3.6SHS	2.12	0.103
2305	ST	150X150X5.0SHS	1.50	0.327
2306	ST	150X150X5.0SHS	1.50	0.327
2307	ST	50X50X3.6SHS	0.75	0.037
2308	ST	150X150X5.0SHS	1.50	0.327
2309	ST	150X150X5.0SHS	1.50	0.327
2310	ST	50X50X3.6SHS	0.75	0.037
2311	ST	50X50X3.6SHS	2.12	0.103
2312	ST	150X150X5.0SHS	1.50	0.327
2313	ST	50X50X3.6SHS	2.12	0.103
2314	ST	50X50X3.6SHS	2.12	0.103
2315	ST	50X50X3.6SHS	2.12	0.103
2316	ST	150X150X5.0SHS	1.50	0.327
2317	ST	150X150X5.0SHS	1.50	0.327
2318	ST	72X72X3.2SHS	0.75	0.049
2319	ST	150X150X5.0SHS	1.50	0.327

2320	ST	150X150X5.0SHS	1.50	0.327
2321	ST	72X72X3.2SHS	0.75	0.049
2322	ST	72X72X3.2SHS	2.12	0.139
2323	ST	150X150X5.0SHS	1.50	0.327
2324	ST	72X72X3.2SHS	2.12	0.139
2325	ST	72X72X3.2SHS	2.12	0.139
2326	ST	72X72X3.2SHS	2.12	0.139
2327	ST	150X150X5.0SHS	1.50	0.327
2328	ST	72X72X3.2SHS	0.75	0.049
2329	ST	150X150X5.0SHS	1.50	0.327
2330	ST	72X72X3.2SHS	0.75	0.049
2331	ST	150X150X5.0SHS	1.50	0.327
2332	ST	72X72X3.2SHS	0.75	0.049
2333	ST	150X150X5.0SHS	1.50	0.327
2334	ST	72X72X3.2SHS	0.75	0.049
2335	ST	150X150X5.0SHS	1.50	0.327
2336	ST	72X72X3.2SHS	0.75	0.049
2337	ST	150X150X5.0SHS	1.50	0.327
2338	ST	72X72X3.2SHS	0.75	0.049
2339	ST	150X150X5.0SHS	1.50	0.327
2340	ST	72X72X3.2SHS	0.75	0.049
2341	ST	150X150X5.0SHS	1.50	0.327
2342	ST	72X72X3.2SHS	0.75	0.049
2343	ST	150X150X5.0SHS	1.50	0.327
2344	ST	72X72X3.2SHS	0.75	0.049
2345	ST	150X150X5.0SHS	2.01	0.437
2346	ST	150X150X5.0SHS	1.84	0.400
2347	ST	150X150X5.0SHS	2.01	0.437
2348	ST	150X150X5.0SHS	1.84	0.400
2349	ST	72X72X3.2SHS	2.37	0.156
2350	ST	72X72X3.2SHS	2.37	0.156
2351	ST	72X72X3.2SHS	2.50	0.164
2352	ST	72X72X3.2SHS	2.50	0.164
2353	ST	72X72X3.2SHS	1.50	0.098
2354	ST	72X72X3.2SHS	0.75	0.049
2355	ST	150X150X8.0SHS	3.61	1.215
2356	ST	150X150X8.0SHS	3.10	1.043
2357	ST	150X150X8.0SHS	3.10	1.043
2358	ST	150X150X8.0SHS	3.61	1.215
2359	ST	72X72X5.0SHS	1.60	0.157
2360	ST	150X150X5.0SHS	1.81	0.395
2361	ST	150X150X5.0SHS	1.81	0.395
2362	ST	150X150X5.0SHS	1.81	0.395
2363	ST	150X150X5.0SHS	1.81	0.395
2364	ST	72X72X3.2SHS	0.75	0.049
2365	ST	72X72X3.2SHS	0.75	0.049
2366	ST	72X72X3.2SHS	2.35	0.154
2367	ST	72X72X3.2SHS	2.35	0.154
2368	ST	72X72X3.2SHS	2.35	0.154
2369	ST	72X72X3.2SHS	1.60	0.105
2370	ST	150X150X5.0SHS	1.81	0.395
2371	ST	150X150X5.0SHS	1.81	0.395
2372	ST	150X150X5.0SHS	1.81	0.395
2373	ST	150X150X5.0SHS	1.81	0.395
2374	ST	72X72X3.2SHS	2.35	0.154
2375	ST	72X72X3.2SHS	2.35	0.154

2376	ST	72X72X3.2SHS	2.35	0.154
2377	ST	72X72X3.2SHS	0.75	0.049
2378	ST	72X72X3.2SHS	0.75	0.049
2379	ST	150X150X5.0SHS	3.98	0.868
2380	ST	150X150X5.0SHS	3.98	0.868
2381	ST	72X72X3.2SHS	1.50	0.098
2382	ST	120X120X6.0SHS	4.26	0.865
2383	ST	150X150X5.0SHS	4.26	0.928
2384	ST	120X120X6.0SHS	4.44	0.901
2385	ST	150X150X5.0SHS	5.07	1.106
2386	ST	100X100X6.0SHS	3.81	0.633
2387	ST	100X100X6.0SHS	4.44	0.737
2388	ST	150X150X5.0SHS	4.44	0.966
2389	ST	150X150X5.0SHS	5.07	1.106
2390	ST	100X100X6.0SHS	3.81	0.633
2391	ST	120X120X6.0SHS	4.44	0.901
2392	ST	150X150X5.0SHS	3.98	0.868
2393	ST	150X150X5.0SHS	3.98	0.868
2394	ST	72X72X3.2SHS	1.50	0.098
2395	ST	72X72X3.2SHS	4.26	0.279
2396	ST	72X72X3.2SHS	4.26	0.279
2397	ST	100X100X6.0SHS	4.44	0.737
2398	ST	100X100X6.0SHS	5.07	0.843
2399	ST	72X72X3.2SHS	3.81	0.250
2400	ST	72X72X3.2SHS	4.44	0.291
2401	ST	150X150X5.0SHS	4.44	0.966
2402	ST	150X150X5.0SHS	5.07	1.106
2403	ST	100X100X6.0SHS	3.81	0.633
2404	ST	120X120X6.0SHS	4.44	0.901
2601	ST	150X150X8.0SHS	1.50	0.505
2602	ST	150X150X8.0SHS	1.50	0.505
2603	ST	150X150X8.0SHS	1.50	0.505
2604	ST	150X150X5.0SHS	1.50	0.327
2605	ST	150X150X5.0SHS	1.50	0.327
2606	ST	150X150X5.0SHS	1.50	0.327
2607	ST	150X150X5.0SHS	1.50	0.327
2608	ST	150X150X5.0SHS	1.50	0.327
2609	ST	150X150X5.0SHS	1.50	0.327
2610	ST	150X150X5.0SHS	1.50	0.327
2611	ST	150X150X5.0SHS	1.50	0.327
2612	ST	150X150X5.0SHS	1.50	0.327
2613	ST	150X150X8.0SHS	1.50	0.505
2614	ST	150X150X8.0SHS	1.50	0.505
2615	ST	150X150X8.0SHS	1.50	0.505
2616	ST	150X150X8.0SHS	1.50	0.505
2617	ST	150X150X8.0SHS	1.50	0.505
2618	ST	150X150X8.0SHS	1.50	0.505
2619	ST	150X150X8.0SHS	1.50	0.505
2620	ST	150X150X8.0SHS	1.50	0.505
2621	ST	150X150X8.0SHS	1.50	0.505
2622	ST	150X150X8.0SHS	1.50	0.505
2623	ST	150X150X8.0SHS	1.50	0.505
2624	ST	150X150X8.0SHS	1.50	0.505
2625	ST	150X150X8.0SHS	1.50	0.505
2626	ST	150X150X8.0SHS	1.50	0.505
2627	ST	150X150X8.0SHS	1.50	0.505

2628	ST	150X150X8.0SHS	1.50	0.505
2629	ST	150X150X8.0SHS	1.50	0.505
2630	ST	150X150X8.0SHS	1.50	0.505
2631	ST	150X150X5.0SHS	1.50	0.327
2632	ST	150X150X5.0SHS	1.50	0.327
2633	ST	150X150X5.0SHS	1.50	0.327
2634	ST	150X150X5.0SHS	1.50	0.327
2635	ST	150X150X5.0SHS	1.50	0.327
2636	ST	150X150X5.0SHS	1.50	0.327
2637	ST	150X150X5.0SHS	1.50	0.327
2638	ST	150X150X5.0SHS	1.50	0.327
2639	ST	150X150X5.0SHS	1.50	0.327
2640	ST	150X150X5.0SHS	1.50	0.327
2641	ST	150X150X5.0SHS	1.50	0.327
2642	ST	150X150X5.0SHS	1.50	0.327
2643	ST	150X150X8.0SHS	1.50	0.505
2644	ST	150X150X8.0SHS	1.50	0.505
2645	ST	150X150X8.0SHS	1.50	0.505
2646	ST	150X150X5.0SHS	1.50	0.327
2647	ST	150X150X5.0SHS	1.50	0.327
2648	ST	150X150X5.0SHS	1.50	0.327
2649	ST	150X150X5.0SHS	1.50	0.327
2650	ST	150X150X5.0SHS	1.50	0.327
2651	ST	150X150X5.0SHS	1.50	0.327
2652	ST	150X150X8.0SHS	1.50	0.505
2653	ST	150X150X8.0SHS	1.50	0.505
2654	ST	150X150X8.0SHS	1.50	0.505
2655	ST	150X150X8.0SHS	1.50	0.505
2656	ST	150X150X8.0SHS	1.50	0.505
2657	ST	150X150X8.0SHS	1.50	0.505
2658	ST	150X150X8.0SHS	1.50	0.505
2659	ST	150X150X8.0SHS	1.50	0.505
2660	ST	150X150X8.0SHS	1.50	0.505
2661	ST	150X150X8.0SHS	1.50	0.505
2662	ST	150X150X8.0SHS	1.50	0.505
2663	ST	150X150X8.0SHS	1.50	0.505
2664	ST	150X150X8.0SHS	1.50	0.505
2665	ST	150X150X8.0SHS	1.50	0.505
2666	ST	150X150X8.0SHS	1.50	0.505
2667	ST	150X150X8.0SHS	1.50	0.505
2668	ST	150X150X8.0SHS	1.50	0.505
2669	ST	150X150X8.0SHS	1.50	0.505
2670	ST	150X150X8.0SHS	1.50	0.505
2671	ST	150X150X8.0SHS	1.50	0.505
2672	ST	150X150X8.0SHS	1.50	0.505
2673	ST	150X150X5.0SHS	1.50	0.327
2674	ST	150X150X5.0SHS	1.50	0.327
2675	ST	150X150X5.0SHS	1.50	0.327
2676	ST	150X150X5.0SHS	1.50	0.327
2677	ST	150X150X5.0SHS	1.50	0.327
2678	ST	150X150X5.0SHS	1.50	0.327
2679	ST	150X150X5.0SHS	1.50	0.327
2680	ST	150X150X5.0SHS	1.50	0.327
2681	ST	150X150X5.0SHS	1.50	0.327
2682	ST	150X150X5.0SHS	1.50	0.327
2683	ST	150X150X5.0SHS	1.50	0.327

2684	ST	150X150X5.0SHS	1.50	0.327
2685	ST	96X48X4.8RHS	4.88	0.461
2686	ST	96X48X4.8RHS	1.50	0.142
2687	ST	96X48X4.8RHS	4.88	0.461
2688	ST	96X48X4.8RHS	1.50	0.142
2689	ST	96X48X4.8RHS	4.88	0.461
2690	ST	96X48X4.8RHS	1.50	0.142
2691	ST	96X48X4.8RHS	4.88	0.461
2692	ST	96X48X4.8RHS	1.50	0.142
2693	ST	96X48X4.8RHS	4.88	0.461
2694	ST	96X48X4.8RHS	1.50	0.142
2695	ST	96X48X4.8RHS	4.88	0.461
2696	ST	96X48X4.8RHS	1.50	0.142
2697	ST	96X48X4.8RHS	4.88	0.461
2698	ST	96X48X4.8RHS	1.50	0.142
2699	ST	96X48X4.8RHS	4.88	0.461
2700	ST	96X48X4.8RHS	1.50	0.142
2701	ST	96X48X4.8RHS	4.88	0.461
2702	ST	96X48X4.8RHS	1.50	0.142
2703	ST	96X48X4.8RHS	4.88	0.461
2704	ST	96X48X4.8RHS	1.50	0.142
2705	ST	96X48X4.8RHS	4.88	0.461
2706	ST	96X48X4.8RHS	1.50	0.142
2707	ST	96X48X4.8RHS	4.88	0.461
2708	ST	96X48X4.8RHS	1.50	0.142
2709	ST	96X48X4.8RHS	4.88	0.461
2710	ST	96X48X4.8RHS	1.50	0.142
2711	ST	96X48X4.8RHS	4.88	0.461
2712	ST	96X48X4.8RHS	1.50	0.142
2713	ST	96X48X4.8RHS	4.88	0.461
2714	ST	96X48X4.8RHS	1.50	0.142
2715	ST	96X48X4.8RHS	4.88	0.461
2716	ST	96X48X4.8RHS	1.50	0.142
2717	ST	96X48X4.8RHS	4.88	0.461
2718	ST	96X48X4.8RHS	1.50	0.142
2719	ST	96X48X4.8RHS	4.88	0.461
2720	ST	96X48X4.8RHS	1.50	0.142
2721	ST	96X48X4.8RHS	4.88	0.461
2722	ST	96X48X4.8RHS	1.50	0.142
2723	ST	96X48X4.8RHS	4.88	0.461
2724	ST	96X48X4.8RHS	1.50	0.142
2725	ST	96X48X4.8RHS	4.88	0.461
2726	ST	96X48X4.8RHS	1.50	0.142
2727	ST	96X48X4.8RHS	4.88	0.461
2728	ST	96X48X4.8RHS	1.50	0.142
2729	ST	96X48X4.8RHS	4.88	0.461
2730	ST	96X48X4.8RHS	1.50	0.142
2731	ST	96X48X4.8RHS	4.88	0.461
2732	ST	96X48X4.8RHS	1.50	0.142
2733	ST	96X48X4.8RHS	4.88	0.461
2734	ST	96X48X4.8RHS	1.50	0.142
2735	ST	96X48X4.8RHS	4.88	0.461
2736	ST	96X48X4.8RHS	1.50	0.142
2737	ST	96X48X4.8RHS	4.88	0.461
2738	ST	96X48X4.8RHS	1.50	0.142
2739	ST	96X48X4.8RHS	4.88	0.461

2740	ST	96X48X4.8RHS	1.50	0.142
2741	ST	96X48X4.8RHS	4.88	0.461
2742	ST	96X48X4.8RHS	1.50	0.142
2743	ST	96X48X4.8RHS	4.88	0.461
2744	ST	96X48X4.8RHS	1.50	0.142
2745	ST	96X48X4.8RHS	4.88	0.461
2746	ST	96X48X4.8RHS	1.50	0.142
2747	ST	96X48X4.8RHS	4.88	0.461
2748	ST	96X48X4.8RHS	1.50	0.142
2749	ST	96X48X4.8RHS	4.88	0.461
2750	ST	96X48X4.8RHS	1.50	0.142
2751	ST	96X48X4.8RHS	4.88	0.461
2752	ST	96X48X4.8RHS	1.50	0.142
2753	ST	96X48X4.8RHS	4.88	0.461
2754	ST	96X48X4.8RHS	1.50	0.142
2755	ST	96X48X4.8RHS	4.88	0.461
2756	ST	96X48X4.8RHS	1.50	0.142
2757	ST	96X48X4.8RHS	4.88	0.461
2758	ST	96X48X4.8RHS	1.50	0.142
2759	ST	96X48X4.8RHS	4.88	0.461
2760	ST	96X48X4.8RHS	1.50	0.142
2761	ST	96X48X4.8RHS	4.88	0.461
2762	ST	96X48X4.8RHS	1.50	0.142
2763	ST	96X48X4.8RHS	4.88	0.461
2764	ST	96X48X4.8RHS	1.50	0.142
2765	ST	96X48X4.8RHS	4.88	0.461
2766	ST	96X48X4.8RHS	1.50	0.142
2767	ST	96X48X4.8RHS	4.88	0.461
2768	ST	96X48X4.8RHS	1.50	0.142
2769	ST	150X150X5.0SHS	1.50	0.327
2770	ST	150X150X5.0SHS	1.50	0.327
2771	ST	150X150X5.0SHS	0.67	0.147
2772	ST	150X150X5.0SHS	0.67	0.147
2773	ST	150X150X5.0SHS	1.50	0.327
2774	ST	150X150X5.0SHS	1.50	0.327
2775	ST	150X150X5.0SHS	1.68	0.366
2776	ST	150X150X5.0SHS	1.68	0.366
2777	ST	96X48X4.8RHS	4.88	0.461
2778	ST	96X48X4.8RHS	1.50	0.142
2779	ST	96X48X4.8RHS	4.88	0.461
2780	ST	96X48X4.8RHS	1.50	0.142
2781	ST	96X48X4.8RHS	4.88	0.461
2782	ST	96X48X4.8RHS	1.50	0.142
2783	ST	96X48X4.8RHS	4.88	0.461
2784	ST	96X48X4.8RHS	1.50	0.142
2785	ST	150X150X5.0SHS	1.50	0.327
2786	ST	180X180X8.0SHS	1.50	0.615
2787	ST	150X150X5.0SHS	0.71	0.154
2788	ST	180X180X8.0SHS	0.71	0.289
2789	ST	150X150X5.0SHS	1.50	0.327
2790	ST	180X180X8.0SHS	1.50	0.615
2791	ST	150X150X5.0SHS	1.68	0.366
2792	ST	180X180X8.0SHS	1.68	0.689
2793	ST	96X48X4.8RHS	4.88	0.461
2794	ST	96X48X4.8RHS	1.50	0.142
2795	ST	96X48X4.8RHS	4.88	0.461

2796	ST	96X48X4.8RHS	1.50	0.142
2797	ST	96X48X4.8RHS	4.88	0.461
2798	ST	96X48X4.8RHS	1.50	0.142
2799	ST	96X48X4.8RHS	4.88	0.461
2800	ST	96X48X4.8RHS	1.50	0.142
2801	ST	50X50X3.6SHS	0.75	0.037
2807	ST	50X50X3.6SHS	0.75	0.037
2809	ST	50X50X3.6SHS	0.75	0.037
2810	ST	50X50X3.6SHS	0.75	0.037
2811	ST	50X50X3.6SHS	0.75	0.037
2812	ST	50X50X3.6SHS	0.75	0.037
2813	ST	50X50X3.6SHS	0.75	0.037
2814	ST	50X50X3.6SHS	0.75	0.037
2815	ST	50X50X3.6SHS	0.75	0.037
2816	ST	50X50X3.6SHS	0.75	0.037
2817	ST	50X50X3.6SHS	0.75	0.037
2818	ST	50X50X3.6SHS	0.75	0.037
2819	ST	50X50X3.6SHS	0.75	0.037
2820	ST	50X50X3.6SHS	0.75	0.037
2821	ST	50X50X3.6SHS	0.75	0.037
2822	ST	50X50X3.6SHS	0.75	0.037
2823	ST	50X50X3.6SHS	0.75	0.037
2824	ST	50X50X3.6SHS	0.75	0.037
2825	ST	50X50X3.6SHS	0.75	0.037
2826	ST	50X50X3.6SHS	0.75	0.037
2827	ST	50X50X3.6SHS	0.75	0.037
2828	ST	50X50X3.6SHS	0.75	0.037
2829	ST	50X50X3.6SHS	0.75	0.037
2830	ST	50X50X3.6SHS	0.75	0.037
2831	ST	50X50X3.6SHS	0.75	0.037
2832	ST	50X50X3.6SHS	0.75	0.037
2833	ST	50X50X3.6SHS	0.75	0.037
2834	ST	50X50X3.6SHS	0.75	0.037
2835	ST	50X50X3.6SHS	0.75	0.037
2836	ST	50X50X3.6SHS	0.75	0.037
2837	ST	50X50X3.6SHS	0.75	0.037
2838	ST	50X50X3.6SHS	0.75	0.037
2839	ST	50X50X3.6SHS	0.75	0.037
2840	ST	50X50X3.6SHS	0.75	0.037
2841	ST	50X50X3.6SHS	0.75	0.037
2842	ST	50X50X3.6SHS	0.75	0.037
2843	ST	72X72X3.2SHS	0.75	0.049
2844	ST	72X72X3.2SHS	0.75	0.049
2845	ST	72X72X3.2SHS	0.75	0.049
2846	ST	72X72X3.2SHS	0.75	0.049
2847	ST	72X72X3.2SHS	0.75	0.049
2848	ST	72X72X3.2SHS	0.75	0.049
2849	ST	72X72X3.2SHS	0.75	0.049
2850	ST	72X72X3.2SHS	0.75	0.049
2851	ST	72X72X3.2SHS	0.75	0.049
2852	ST	72X72X3.2SHS	0.75	0.049
2853	ST	72X72X3.2SHS	0.75	0.049
2854	ST	72X72X3.2SHS	0.75	0.049
2855	ST	72X72X3.2SHS	0.75	0.049
2856	ST	72X72X3.2SHS	0.75	0.049
2857	ST	72X72X3.2SHS	0.75	0.049

STAAD SPACE -- PAGE NO. 691

2858 ST 72X72X3.2SHS 0.75 0.049

TOTAL = 484.614

********** END OF DATA FROM INTERNAL STORAGE **********

1852. FINISH

********** END OF THE STAAD.Pro RUN **********

**** DATE= NOV 5,2022 TIME= 19:18:24 ****


```
************************************************************
*   For technical assistance on STAAD.Pro, please visit    *
*   http://www.bentley.com/en/support/                     *
*                                                          *
*   Details about additional assistance from               *
*   Bentley and Partners can be found at program menu      *
*   Help->Technical Support                                *
*                                                          *
*      Copyright (c) 1997-2017 Bentley Systems, Inc.       *
*                http://www.bentley.com                    *
************************************************************
```