ZERTIFIKAT ◆ CERTIFICATE ◆ 認証書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Certificate of a Conformity-Examination

Industrie Service

Certificate No.:	**TorFV 9/150**
Approved testing institution:	TÜV SÜD Industrie Service GmbH Westendstrasse 199, 80686 München, Germany Testing institution for the building product (system 3): EN 13241-1 Industrial, commercial and garage doors and gates – Product standard – Part 1: Products without fire resistance or smoke control characteristics
Applicant / Holder of certificate:	ASSA ABLOY Entrance Systems AB Lodjursgatan 10 SE-261 44 Landskrona Sweden
Manufacturer:	ASSA ABLOY Entrance Systems AB Lodjursgatan 10 SE-261 44 Landskrona Sweden
Product, Type:	**Suspension breakage anti drop device** for power-operated windows, doors and gates Type **S 800**
Testing Laboratory:	TÜV SÜD Industrie Service GmbH Prüflaboratorium für Produkte der Fördertechnik Prüfbereich Maschinen der Fördertechnik Gottlieb-Daimler-Straße 7, 70794 Filderstadt, Germany
Date and number of test report:	1992-08-17 G2-FTA re-he MEGAPB_8
Testing standards:	EN 12604:2000 Industrial, commercial and garage doors and gates – Mechanical aspects – Requirements EN 12605:2000 Industrial, commercial and garage doors and gates – Mechanical aspects – Test methods
Highest measured values out of the free fall tests:	2.86 g 0.39 m/s 24 mm falling distance in the case of suspension breakage with a weight force of 2550 N
Result:	The anti drop device meets the requirements of the testing standards for the following **scope of application:** max. operating speed in closing direction: **0.30 m/s** permissible weight force of the leaf: **14200 N** (with anti drop device left and right) anti drop force per catching rail: **24500 N** respectively 1.7-times the entire weight of the leaf
Revision:	**1**
Date of issue:	2013-08-12

Testing institution – Identification number: 0036

Gerold Jilg

TÜV®