






Abbrevation's:
WOW-Wall Opening Width
WOH-Wall Opening Height
UC-Under Cut
FFL-Finished Floor Level

## ASSESORIES DETALES

(a) HINGES: 10 No. SS Ball bearing butt hinges 100x75x3mm


(b) LOCK : PHCR 1000 series puch bar (Make Dorma)
PHCR 1000 series puch bar vertical Bar (Make Dorma)

(c) DOOR CLOSER: 2 No. Door Colser TS 71 with std arm (Make Dorma)

(d) GLASS : Clear fire Vision Glass Clear 6mm of size 300x300mm.

Shutter thickness : 47 mm
Frame Sheet thick : 1.20mm
Shutter sheet thick : 0.80mm
Fixing : On Soliid Brick plasterd wall with Anchors

NOTE:- *All Dimensions are in mm.
*Tolerance:-All Linear Dimensions ±3mm,Others ±0.5mm.
*The Drawing Is For Location of Hardware only. Drawing Does Not Represent The Hardware For More Clarity, Please Go Through Hardware Broucher.




Detail view of Section A

| FIRE DOOR SIZES | | |
|---|---|---|
| WOW | WOH | QUANTITY |
| 1500 | 2900 | 5 |

This drawing & designing is the property of NIHVA TECHNOLOGIES. Not be sold or copy to any other concern.

Fire Door

CLIENT APPROVAL

ALL DIMENSION ARE IN mm

| | NAME | DATE | SIGN. |
|---|---|---|---|
| DRAWN | OMKAR | 30/01/16 | |
| CHECK | ANIL | 30/01/16 | |
| REV. | 01 | | |
| APPRD. | | | |
| MFG | | | |

NIHVA TECHNOLOGIES PVT. LTD.

NIHVA TECHNOLOGY PVT. LTD. PUNE
Tel : 020 66304033
Email:- info@nihva.com
Website:-www.nihva.com

CLIENT - SYNEFRA
PROJECT - LUPIN
SITE - SUS-PUNE
DWG. NO. - NIHVA/15-16/193
SCALE: 01 | WT: | SHEET: 01 OF 01
If any queries contact : projects@nihva.com