SKS ISPAT & POWER LIMITED
Near Siltara Industrial Area, 493111
Raipur Chhattisgarh
Fax:07721-264378/80

ISO 9001:2015
ISO 14001:2015

TEST CERTIFICATE

TEST CERTIFICATE NO QA/12/12/01 DATE- 12/12/2019

M/S:- SANKALP STEEL TECH. CORPORATION(P) LTD.

This is to certify that material supplied vide Invoice No.16419.....fully confirms to Specification equivalent to **IS 2062/2011**

Specification The Chemical Analysis & Mechanical Properties are enumerated below

P.O No./D.O NO. and Date	Section & Size In (mm)	HEAT NO/ LOT NO.	Quantity (M t)	CHEMICAL ANALYSIS						MECHANICAL PROPERTIES					GRADE
				C%	Mn%	S%	P%	Si%	CE	Yield Stress (MPa)	U.T.S. (MPa)	E (%)	BEND TEST (2t)	IMPACT (J)	
400003330	ISMC 175 X75 MM	306/C/II	2.180	0.17	0.65	0.032	0.041	0.22	0.278	319	478	28.6	OK	.....	E-250
										309	482	29.6	OK	.....	E-250
	ISMC 300X90 MM	372/C/I	2.980	0.17	0.60	0.034	0.042	0.19	0.270	310	496	30.5	OK	.....	E-250
										312	483	29.4	OK	.....	E-250
	ISMB 400X140 MM	359/B/I	9.570	0.16	0.67	0.029	0.040	0.17	0.270	301	520	31.5	OK	.....	E-250
										293	515	32.3	OK	.....	E-250
	ISMB 175X85 MM	271/B/II	2.080	0.18	0.70	0.030	0.041	0.20	0.296	301	475	31.5	OK	.....	E-250
										293	469	32.3	OK	.....	E-250

REMARKS: ----------

TRUCK NO:- CG07BN/2170

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
BUREAU VERITAS
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

NIHVA TECHNOLOGIES PVT. LTD. PUNE

SKS ISPAT & POWER LTD. RAIPUR (C.G.)

H.O.D. (Q.A.D)

ACCURATE LABORATORY SERVICES

CHEMICAL & MECHANICAL ANALYSIS OF FERROUS & NON FERROUS METALS & ALLOYS

Office & Works : Plot no. 21 / 1 - B, 7, General Block, MIDC, Bhosari, Pune - 411 026.
Phone : 020 - 2712 7056 email : cinkurp698@yahoo.com

Certificate No. Chem. :T-1506 Mech. :T-1507

To,
M/S SANKALP STEELTECH CORPORATION PVT LTD
PLOT NO 140/141,PCNTDA,MIDC,BHOSARI,
PUNE 411026

Test Certificate

T.C. NO	PLS_27L20_062.1	Condition of sample	Satisfactory
T.C. Date.	18/11/2020	Environmental Cond.	As Specified
Requisition No	4803/13/11/2020	Test Method Used	AS Applicable
Record From	Sankalp Steeltech Corporation Pvt Ltd	Received on	18/11/2020
Deviations/ Subcontracting	Nil		

Sample Code	PLS_27L20_062.1
Sample Description	16 mm thik Carbon Steel Plate
Marked As	--
Stamped As	--
General Information	--
Tested Specification	IS 2062 gr. Designation E 250 Quality A- Ed.2011

Chemical Analysis (OES)		IS8811:1998		Specified	SC_27L13_062.1
				Result	R/V
Carbon		(C)	%	0.17	(0.23 Max)
Silicon		(Si)	%	0.23	(0.60 Max)
Manganese		(Mn)	%	0.79	(1.70 Max)
Phosphours		(P)	%	0.033	(0.035 Max)
Sulphur		(S)	%	0.023	(0.035 Max)
Chromium		(Cr)	%	0.015	--
Molebdenum	(#)	(Mo)	%	0.015	--
Nickel	(#)	(Ni)	%	0.015	
Aluminium		(Al)	%	0.010	
Copper		(Cu)	%	0.02	
Vanadium		(V)	%	0.010	(0.60 Max)
Carbon Eq	(*)		%	0.30	(0.47 Max)

Tensile Testing		Result	R/V
Diameter	mm	10.07	
Area	mm2	79.65	
Gauge Length	mm	50.00	
Final Gauge Length	mm	64.78	
Yield Load	kN	38.36	
Ultimate Load	kN	48.52	
Yield Stress	N/mm2	359	(345 Min)
UTS	N/mm2	506	(470-630)
Elongation	%	29	(22.00 Min)
Fracture		W.G.L	

Remarks: The given sample/s meet/s the requirement/s of IS-2062 Gr.Designation E 250 Quality A-Ed.2011 With respect to the tests carried out

ACCURATE LABORATORY SERVICES MIDC., BHOSARI, PUNE-26

ACCURATE LABORATORY SERVICES

Checked By | Witness By | Authorised Signatory / Director

SANKALP STEELTECH CORPORATION BHOSARI, PUNE-26

NIHVA TECHNOLOGIES PVT.LTD. PUNE

BUREAU VERITAS

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020

Bureau Veritas India Pvt. Ltd. — Mahesh Hosamani Pune

STEEL AUTHORITY OF INDIA LIMITED
BHILAI STEEL PLANT
RESEARCH & CONTROL LAB (MECHANICAL TESTING LAB)

IS : 2062

CM/L-0057534
MTL-II/QR-2

TEST CERTIFICATE FOR HOT ROLLED MEDIUM AND HIGH TENSILE STRUCTURAL STEEL

Sold-to-Party:

T.C.No : RCL/MTL/PLM/80563656
T.C. Date : 20.12.2019
SALES ORDER NO : 1100315125
DA No : 80563656

Wagon No / Trailer No : SECR21141233225

Process of Manufacture : Basic Oxygen Converter> Continuous Cast> Fully Killed Steel> SIAIK

Specification : IS 2062 E 250 BR : 2011 RA 2016

We certify that the material described below fully conforms to IS 2062 : 2011 RA 2016. Chemical composition and Mechanical properties of the product, as tested in accordance with the scheme of testing and inspection contained in the BIS certification mark Number CM/L 0057534 are as indicated against each Order No.

(Please refer to IS 2062 : 2011 RA 2016 for details of specification requirements)

BHI0610

TEST RESULTS

SECTION (NOMINAL SIZE)			Plate No / Pc. No.	Heat No	MECHANICAL PROPERTIES									Bend Test	M Dia
THICK mm	WIDTH mm	LENGTH mm			YS 250 MPa Min	UTS 410 MPa	%E Min23(5.65SqrtS0)	%E2	CHARPY V NOTCH (L) Impact Values (J) I1	I2	I3	Iavg	°C		
16	2500	12000	2556945/2	304555	359	506	29	--	90	80	78	83	RT	OK	2.0 T
				304555	327	471	28	--	--	--	--	--	--	OK	2.0 T
16	2500	12000	2556945/2	304555	--	--	--	--	--	--	--	--	--	--	--
16	2500	12000	2556946/2	304555	321	430	29	--	96	90	92	93	RT	OK	2.0 T
				304555	347	465	26	--	--	--	--	--	--	OK	2.0 T
16	2500	12000	2556946/2	304555	--	--	--	--	--	--	--	--	--	--	--
16	2500	12000	2556927/2	304555	326	430	29	--	98	90	80	96	RT	OK	2.0 T
16	2500	12000		304555	345	465	26	--	--	--	--	--	--	OK	2.0 T
16	2500	12000	2556927/2	304555	--	--	--	--	--	--	--	--	--	--	--

Heat No	CHEMICAL COMPOSITION (LADLE ANALYSIS)															
	C %	S %	P %	Mn %	Si %	Al %	Cu %	Cr %	Ni %	Mo %	Nb %	V %	Ti %	N_2 ppm	B %	CE %
1555	0.17	0.023	0.033	0.79	0.23	0.010	< 0.02	< 0.015	< 0.015	< 0.015	< 0.010	< 0.010	< 0.005	--	< 0.0005	0.30

Total Pieces Page / Sales Order : 7 / 7 Total Pieces / TC : 15

The Material supplied conforms to the standard rolling and weight tolerances.,
CE calculated by formula: [C + Mn/6 + (Cr + Mo + V)/5 + (Ni + Cu)/15],
RT- Room temperature as defined in the specification,
Plate sides are in UNTRIMMED condition.,
Size of impact test specimen:10x10x55 mm(above 10mm thickness) ; 7.5x10x55 mm(upto 10mm thickness),
Note:* M = Mandrel Dia, T = Plate Thickness, Length is the rolling direction of the plate,

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

This Certificate is Issued
Against our Sales Invoice
No.....
For
Kgs.....to M/s.....

Authorised Signatory

A L SAHU
Authorized Signatory
Research & Control Laboratory, Bhilai Steel Plant

ORIGINAL

ORIGINAL / DUPLICATE / TRIPLICATE

URJA METALLURGICAL SERVICES

J/P-15, TELCO-BHOSARI ROAD, OPPOSITE TO RELIANCE COMMUNICATION, BHOSARI,
PUNE-26 PH-020-46768703, 4678190, Email-urjametallurgical@gmail.com

TEST CERTIFICATE

Test Report No. 92490		Report Date :	08/11/2020
ULR.TC-774820000037785F		Sample Received :	07/11/2020
NIHVA TECHNOLOGIES PVT.LTD.		Tested Date :	08/11/2020
12/4, D1 BLOCK, MIDC		Lab No:	UMH-405
CHINCHWAD, PUNE		Challan No :	238/6.11.2020
-		P.O. No:	-
- - 411 019			

Sample Description : CHEQUERED PLATE 320 X 290 X 8 MM THK, MATL.SPEC.IS 2062 E 250 GR.B

TENSILE TEST : IS:1608 PART-1 - 2018

	1	2
Gauge Dia mm	--	--
Thickness mm	7.86	7.86
Breadth mm	20.05	20.05
Area mm2	157.59	157.59
Gauge length mm	71.0	71.0
Final Gauge Length mm	89.87	89.57
Final Dia mm	--	--
Yield Load KN --	52.50	52.85
Ultimate Load KN	72.65	73.25

	MIN	MAX	OBS1	OBS2
Y Stress Kg-N/MM2 --	250.0	---	333.14	335.36
UTS Kg-N/MM2	410.0	--	461.0	464.80
Reduction %	--	--	--	--
Elogation %	23.0	--	26.58	26.15
Fracture	--	--	WGL	WGL

BEND TEST : IS 1599-RA-2019

	1	2
Thickness mm	7.86	7.86
Width mm	38.0	38.0
Former dia mm 2T	16.0	16.0
Degree of Bend	180° SATISFACTORY.	180° SATISFACTORY.

FERROUS TEST : IS 8811-1998(RA2018)/JIS G 1253-2013

	OBS	MIN	MAX
C %	0.16		0.22
S %	0.005		0.045
P %	0.018		0.045
Si %	0.065		0.40
Mn %	0.91		1.50
Ni %	0.002		
Cr %	0.011		
Mo %	0.002		
V %	0.0005	--	--
Cu%	0.008	--	--
CE VALUE	0.31	--	0.41

IMPACT TEST : IS 1757-PART1-2014

Characterization & Cond :MACHINING AND TESTING

Notch	V NOTCH CHARPY
Temp °C	-20°
Size mm	10 X 7.5
Energy Absorbed in Joules	92,94,96 J
Average	94.0 J(REQUIRED 27.0 J MIN.)

Remark: ABOVE TETS RESULT CONFORMS TO IS 2062 E 250 GR.B QUALITY MATERIAL.

END OF REPORT

FOR URJA METALLURGICAL SERVICES

Rohidas B. Chavhan (Technical Manager)
Authorized Signatory

Note- Sample(s) are not drawn by Urja Metallurgical Services.This report refers to sample(s) submitted for test.Report shall not be reproduced except in full, without the permission of the laboratory. Tests marked as * (Star) are not covered under the scope of NABL Accredition presently.

UM/QF/24

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
BUREAU VERITAS
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani Pune

NIHVA TECHNOLOGIES PVT.LTD. * PUNE *

STEEL AUTHORITY OF INDIA LIMITED
ROURKELA STEEL PLANT
ROURKELA - 769011 (ODISHA)
RESEARCH AND CONTROL LABORATORY

IS 3502

Test Certificate For: STEEL CHEQUERED PLATES / COILS

Test Certificate No.: 380024 | Dated: 03.08.2019 | Product: Cheq. Coil

To :

It is certified that the materials described below fully conforms to IS 3502 - 2009. The chemical composition and Mechanical properties of the product as tested in accordance with the scheme of Testing and Inspection contained in BIS Certification marks License No. CM / L 0002287763 are as indicated against each order. The material supplied conforms to standard Rolling and weight tolerances. (PLEASE REFER TO IS 3502 - 2009 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

Ladle Analysis

Cast No	C%	Mn%	P%	S%	Si%	Al%	CE
1910997	0.0690	0.2750	0.0170	0.0200	0.0880	0.0400	0.1150
1911057	0.0700	0.4100	0.0280	0.0400	0.0490	0.0290	0.1380
1911372	0.0500	0.3600	0.0300	0.0310	0.0530	0.0600	0.1100
1912183	0.0400	0.2800	0.0260	0.0150	0.0480	0.0480	0.0870

Sl. No.	MP / SO No.	Cast / Batch No.	Size(mm) (TxWxL)	Weight(T)	Grade / Mode Of Killing	YS (MPa)	UTS (MPa)	El (%)	Bend Test
1	1400417099	1911057 / M98725	6x1250xCOIL	15.900	IS3502(BASEIS10748GRII) / ALSIK	264	364	34	OK
2	1400417099	1910997 / M98877	6x1250xCOIL	16.360	IS3502(BASEIS10748GRII) / ALSIK	264	364	34	OK
3	1400417099	1911372 / N03310	6x1250xCOIL	15.870	IS3502(BASEIS10748GRII) / ALSIK	275	382	30	OK
4	1400417100	1912183 / N03326	8x1250xCOIL	16.210	IS3502(BASEIS10748GRII) / ALSIK	267	368	32	OK
						266	372	32	OK
						266	372	32	OK
						266	364	32	OK
						272	386	32	OK

Total Pieces : 4 Total Weight(Tons) : 64.340

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

This Certificate is issued Against our Sales Invoice No. 19:20/38 Dt. 16/03/20 For Kgs.....to M/s. NTPL

Dispatch Advice No.: 811267749 Dated: 02.08.2019 Wagon No: BRN/ECOR/94121336384

K PATWARI
AGM , R&C Lab
Rourkela Steel Plant

QUALITY NDT SERVICES

REGD. OFFICE : Plot No. B.G.A.- 1/1,2,3 Bhosari General Block,M.I.D.C,
Bhosari, Pune – 411026. Phone : 020 – 27121843, 27119490, Fax : 020 – 27129036
E-mail : bkp_qndt@yahoo.in / qndt2712@bsnl.in / bhausaheb@qualityndt.org
www.qualityndt.org

RADIOGRAPHY, ULTRASONIC, MAGENETIC PARTICLE, PENETRANT, DFT, THICKNESS GUAGEING TESTING SERVICES.

Our Ref.: Date:

PENETRANT EXAMINATION REPORT

Report No. : DP/20-21/79	**Date :** 16.10.2020
	Page : 01 OF 01

Client :	**NIHVA TECHNOLOGIES PVT. LTD.** 187 G Block . Thermax Chowk MIDC Chinchwad pune 411019

Component : DOCK LEVELLER	**Project No – NDL629**
Material : Mild Steel	**Stage.:-** After Welding
SIZE : - AS BELOW	**Light Intensity:-** 1400 Lux
Specification /: ASME Sec –V, ARTICAL 6 /ASME Sec VIII, DIV -1 APPENDIX 8	**Temperature :-** Ambient Temp.

Penetrant:	Dyeglo Make	**Batch No:-**2007R1	**Best Before:**24 month (MFG JULY 2020)	**Dwell Time:-** 20 Min.
Developer:	Dyeglo Make	**Batch No:-**2008D2	**Best Before:**24month (MFG AUG 2020)	
Cleaner :	Dyeglo Make	**Batch No:-**2008C2	**Best Before:** 12 month MFG AUG 2020)	

Obeservation:-

Sr no	Description	Qty	Observation	Remark
1)	**DOCK LEVELLER** **FILLET WELD DPT TESTING 20%**	01 Nos	NRI	ACCEPTABLE

NRI :- NO RELEVENT INDICATION OBSERVED

Examined By :	Reviewed By	
Abhishek Takalkar		
Level : PT Level 2	Noted / Reviewed / Witnessed Accepted / Not Accepted Bureau Veritas India Pvt. Ltd. 24/11/2020 Mahesh Hosamani Pune	**Inspecting Authority**

ABHISHEK J. TAKALKAR ASNT LV.-II UT,MT,PT,RT

NIHVA TECHNOLOGIES PVT.LTD. PUNE

CALITRON CALIBRATION LABORATORY

Unit-1 : 207 Kohinoor Arcade,Tilak Chowk, Old Pune Mumbai Road, Nigdi, Pune 411044
Unit-2 : 238 Kohinoor Majestic Plot No G185 & G186 Block, MIDC Chincwhad Pune 411035
Email : service@calitroncalibration.com, Telephone : 020 - 2765 7591 / 98224 55541

CALIBRATION CERTIFICATE

Certificate No.
CC - 2741

CERTIFICATE NO: CCL/1904-40/01

OBSERVATIONS :

9.0 Table 1: **Foils**

Sr no.	Nominal Denomination µm	Tolerance ± µm	Measured Value (µm)	Deviation µm	Uncertainty (µm)
1	50	0.5	51.3	-1.3	4.2
2	124	1.0	123.3	0.7	4.2
3	288	3.0	286.3	1.7	4.2
4	406	5.0	403.3	2.7	4.2
5	755	8.0	748.3	6.7	4.2

9.1 Table 2: **Verification of Meter**

Sr no.	Foil Nominal Denomination µm	Tolerance ± µm	Indicated Value on meter (µm)	Error ± µm
1	50	0.5	50.9	0.9
2	124	1.0	123.7	-0.3
3	288	3.0	287.1	-0.9
4	406	5.0	405.5	-0.5
5	755	8.0	756.5	1.5

10.0 General Remark:

The overall uncertainty is for k=2 at Approximately 90% confidence level.

Calibrated By

VG

(Cal. Engr)

Authorised Signatory

A.M.ZANPURE/M.R.ZANPURE

CCL/F/CC/R-8

#End#

CALITRON CALIBRATION LABORATORY ★PUNE★

Noted / Reviewed / Witnessed
Accepted / Not Accepted

24/11/2020

Bureau Veritas India Pvt. Ltd.

Mahesh Hosamani
Pune

CALITRON CALIBRATION LABORATORY

Unit-1 : 207 Kohinoor Arcade,Tilak Chowk, Old Pune Mumbai Road, Nigdi, Pune 411044
Unit-2 : 238 Kohinoor Majestic Plot No G185 & G186 Block, MIDC Chincwhad Pune 411035
Email : service@calitroncalibration.com, Telephone : 020 - 2765 7591 / 98224 55541

Certificate No.
CC - 274

CALIBRATION CERTIFICATE

Certificate No: CCL/1904-40/01
Calibration On: 29.04.2019
ULR No: CC274119100001870F

Issue Date: 30.04.2019
Due On: 29.04.2020

1.0 Customer : Sara Industries, Bhosari, Pune - 411026.

2.0 Instrument Details:

Calibrated Item	: DFT Meter (Foils) -(coating thickness gauge)
Make	: --
Model	: CM-8821
S.No	: N843381
Id.No	: --
Accuracy	: --
Range	: As per Observation
L.C.	: 0.1 µm
Location	: --

3.0 Registration Date	: 29.04.2019
4.0 Condition of item	: Functional
5.0 Calibration at	: In House
6.0 Environmental Condition	
Temperature	: *(20±2) °C*
Humidity	: *(50±10)%*
Barometric Pressure	: *NA*
7.0 Calibration Procedure	: CCL/CM/FG

8.0 STANDARD DETAILS:

Certificate No	Make/Model	Description	Traceable to	Validity
P/27/170079	Mitutoyo ID-S112X	Digital dial gauge with comparator stand	Accurate Engineering	17-Mar-2020

This Certificate refers only to item under calibration. Calibration Results reported or valid at the time of & under stated conditions of measurements. Calitron Calibration Laboratory shall not be liable for any change in calibration on account of malfunctioning of the instrument due to damage caused to it after report is issued. Measurement on the items where made over a period which was to short to yield long term stability information. Certificate shall not be reproduced in full without any prior information from Calitron Calibration Laboratory. Customer may decide to use, downgrade, scrap the instrument or gauge which is not confirming to the requirement.

Calibrated By

UG
(Cal. Engr)

Authorised Signatory

A.M.ZANPURE/M.R.ZANPURE

CCL/F/CC/R-8

CALITRON CALIBRATION LABORATORY ★PUNE★

NAVNIVA TECHNOLOGIES PVT.LTD. ★PUNE★

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

NIHVA TECHNOLOGIES PVT. LTD.	SURFACE PREPRATION AND PAINTING REPORT	
CLIENT:- L&T	EQUIPMENT:-	
PROJECT:- DOCK LEVELLER	QAP NO.:-IPEG-6389-NTPL(1)-8830-TP-207D-0001	
DRW. NO.:-IPEG-6389-NTPL(1)-8470-DS-2070-0001		
DESCRIPTION OF PAINT:-		
FINAL COAT :-RAL 7035	PRODUCT:-HARDTOP XP	
PRODUCTION DATE:- 15/05/2020	BATCH NO:- 2183383-1-*-1:3	

SR. NO.	DESCRIPTION OF ITEAM	FINAL		TOTAL		REMARK
		REQ. MICRON	ACTUAL MICRON	REQ. MICRON	ACTUAL MICRON	
1	OVERALL DOCK LEVELLER PAINT	150	150-180	150	150-180	

REMARK:-

CHECKED BY:-

NIHVA TECHNOLOGIES PVT. LTD. PUNE

REVIEWED BY:-

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani Pune

NIHVA TECHNOLOGIES PVT. LTD.	MATERIAL HISTORY SHEET	
CLIENT:- L&T	EQUIPMENT:-	DATE:-24-11-2020
PROJECT:- DOCK LEVELLER	QAP NO.:-IPEG-6389-NTPL(1)-8830-TP-207D-0001	
DRW. NO.:-IPEG-6389-NTPL(1)-8470-DS-2070-0001		

MTC

SR. NO.	DRAWING NO.	NAME	SIZE	MATERIAL	QTY	CAST NO.	TC NO.	REMARK	TC SR. NO
1	IPEG-6389-NTPL(1)-8470-DS-2070-0001	CHEQ. PLATE	5500MM	MS	1	1912183	380024		1
2	IPEG-6389-NTPL(1)-8470-DS-2070-0001	LIP PLATE	630MM	MS	1	304555	RCL/MTL/PLM/80563656		2
3	IPEG-6389-NTPL(1)-8470-DS-2070-0001	ISMB	5500*801	MS		306/C/II	QA/12/12/01		3

LAB TC

1	IPEG-6389-NTPL(1)-8470-DS-2070-0001	CHEQ. PLATE	5500MM	MS	1		92490		1
2	IPEG-6389-NTPL(1)-8470-DS-2070-0001	LIP PLATE	630MM	MS	1		PLS_27L20_062.1		2
3	IPEG-6389-NTPL(1)-8470-DS-2070-0001	ISMB	5500*801	MS			PLS_30L20_068.1		3

REMARK:-

CHECKED BY:-

NIHVA TECHNOLOGIES PVT. LTD. * PUNE *

REVIEWED BY:-

Noted / Reviewed / Witnessed
Accepted / Not Accepted

BUREAU VERITAS

Bureau Veritas
India Pvt. Ltd.

24/11/2020

Mahesh Hosamani
Pune

SIEMENS

Routine Test Certificate
3ph Ind. Motor

Machine No
30818154

107203140

Customer Part Code : .

S. O. No : -

NAME PLATE DATA :

Type	: 1LE75010DB323FA4	Frequency	: 50 Hz±5%	Duty	: S1
kW/HP	: 0.75/1.0	Efficiency	: 79.9 %	S1 Output	: -
Current	: 1.7 A	Power Factor	: 0.75	Ins. Cl.	: F
Voltage	: 415 V±10%	Connection	: Star	Frame	: 80
Speed	: 1433 RPM	Protection	: IP 55	Ref. Standard	: IS:12615/IEC60034-1

OTHER DATA :

Direction	: Clockwise	T. Box Position	: Top	Rotor Class	:
DE Bearing	: 6204-2Z/C3	Rotor Voltage	:	A. C. Heater	:
NDE Bearing	: 6204-2Z/C3	Rotor Current	:	PTC	:
Construction	: IM B5			RTD	:

TEST RESULTS :

RESISTANCE OF STATOR WINDING :

Polarity & Connection	Avg Res (Ohms)	Amb Temp (C)
4-Star	21.5667	28.0

NO LOAD TEST :

Polarity & Connection	Voltage (Volts)	Current (Amp.)			Input Power (Watts)
4-Star	415	1.15	1.13	1.15	94

Reduced Voltage Run Up Test : Motor runs upto full speed at 57% volts in both directions.(For Squirrel Cage Motors Only)

LOCKED ROTOR TEST :

Polarity and Connection	Voltage (Volts)	Current (Amp.)	Input Power (watts)
4-Star	85	1.7	159

HIGH VOLTAGE TEST :

	Voltage	Duration	Remarks
Stator	2 kV	1 Minute	OK

INSULATION RESISTANCE TEST :

Winding	Insulation Resistance
Stator	> 50 MOHMS

Remarks : We hereby confirm that the machine has been manufactured in accordance with the standard listed above and that the specified tests and inspections have been carried out. the machine was found to be electrically and mechanically in order.

Description :

SIEMENS LTD | **CHECKED BY :** | **TEST DATE : 04-03-2020**

This is computer generated output approved by Siemens Motor Quality Assurance hence no signature is required.

Noted / Reviewed / Witnessed
Accepted / Not Accepted
03/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

TECHNOLOGIES PVT. LTD.

Everything in Fluid Power

CREATIVE POWER & CONTROL

Manufacturers of Custom Built Hydraulic Power Packs & Special Purpose Machines
Stockist : Rexroth, Yuken, Vickers, Polyhydron, Danfose, Dowty, Denison, Kawassaki etc.

TEST CERTIFICATE

1. MANIFOLD BLOCK. : MANUFACTURED BY CREATIVE POWER & CONTROL.

   TESTED AT 250 BAR FOR BOTH DC VALVES . NO INTERNAL LEAKAGE FOUND.

2. DIRECTION CONTROL VALVE DSG 01 3C2 D 24. YUKEN MAKE.

   TESTED AT 250 BAR. FUNCTIONING WITHOUT PROBLEM.

3. GEAR PUMP. : DOWTY MAKE.

   TESTED AT 200 BAR. SMOOTH OPERATION.

4. PRESSURE RELIEF VALVE: TESTED AT 200 BAR. WORKING OK.
5. 1 HP. ELECTRIC MOTOR TEST REPORT SEPERATELY ENCLOSED.

FOR CREATIVE POWER & CONTROL

AUTHORISED SIGNATORY.

DATE : 31.08.2020.

Simen's motor - 1LE75010DB323FA4

Power Pack No! - DPRH06S315-04.

BUREAU VERITAS 1828

Noted / Reviewed / Witnessed
Accepted / Not Accepted

03/11/2020

Bureau Veritas
India Pvt. Ltd.

Mahesh Hosamani
Pune

TECHNOLOGIES PVT. LTD. * PUNE * NIHVA

Gala No.17, Ground Floor, Wing C, Sanghvi Steel Compound, Mohannagar, Chinchwad, Pune 411 019.

JYOTIBA WEIGHBRIDGE

JYOTIBA JWB WEIGHBRIDGE

Gat No. 88, Jyotiba Nagar, Talawade,
Pune - 411 062

80 TONS CAPACITY

SERIAL NO. : 9237
CHARGES Rs. : 150

VEHICLE NO. : MH14CP 5039
PARTY :

GROSS : 6400 Kg. DATE : 03/11/2020 TIME : 10:40

TARE : Kg. DATE : TIME :

NETT : Kg. DRIVER : IN OUT

OPERATOR'S SIGNATURE

24
HOURS SERVICE.

OUR RESPONSIBILITY CEASES ONCE THE VEHICLE LEAVES THE PLATFORM.

COMPU-TAX FORMS PVT. LTD., ☎ (020) 65102646 / 9422304725 *94-08-18

4-08-18

Noted / Reviewed / Witnessed
Accepted / Not Accepted

BUREAU VERITAS

Bureau Veritas
India Pvt. Ltd.

03/11/2020
Mahesh Hosamani
Pune

NIHVA TECHNOLOGIES PVT. LTD. ★ PUNE ★

CC - 3137

UNITED CALIBRATIONS
NABL APPROVED LAB PVT. LTD.

United Calibrations

Flat No-2, Shyama Enclave, Nr. Priyadarshani school, Indrayani Nagar, Bhosari, Pune - 411026.
Mob: +91- 8411009211/12, Email : info@unitedcalibrations.com, Website: www.unitedcalibrations.com

Calibration Certificate

CERTIFICATE NO.	UCPL/2021/H01549/02	CALIBRATION DATE	31.10.2020
		NEXT DUE DATE (As per Customer Requirement)	30.10.2021
		PAGE NO..	1 of 1
RECEIPT ENTRY NO.	UCPL/-IW-H01549	DATE OF RECEIPT	31.10.2020
		RECEIPT CONDITION	Functioning Properly
ULR NO.	CC313720000003573F	Certificate Issue Date	31.10.2020
CUSTOMER	M/s. NIHVA Technologies Pvt Ltd., 8/1 Coromant Hsg. Soc. Sector 27 Pradhikaran, Nigdi, Pune - 411044.		

UUC Details

Description	:	Measuring Tape- Steel	Make	:	Freemans
Size/Range	:	5 mtr	Sr. No.	:	-
L.C.	:	1 mm	ID. No.	:	-
Location	:	--	Accuracy	:	-

Reference Used : IS 1269 (Part 2)-1987
Procedure No. Used : UCPL/CP/MECH/32
Environmental Condition : Temperature: 20 ± 2°C & Humidity: 40 to 60 % Rh

Details of Standards / Equipments used for Calibration

Name of Master Equipment / Reference Standard	ID. No. / Sr. No.	Calibrated By	Certificate No..	Valid Upto
Tape & Scale Calibrator	UCPL/MSTC/01	JRPM Lab	JRPM-CCTR-DIM-2020-2662	09.09.2021

Traceability: Traceable to National / International standards through NABL Accredited calibration laboratory.

Calibration Results: All readings in mm

Error in Readings :

Standard Reading	Observed Reading*	Error	Standard Reading	Observed Reading*	Error	Standard Reading	Observed Reading*	Error
10.00	10.007	-0.007	1500.00	1500.018	-0.018	4000.00	4000.029	-0.029
500.00	500.012	-0.012	2000.00	2000.021	-0.021	5000.00	5000.035	-0.035
1000.00	1000.015	-0.015	3000.00	3000.025	-0.025			

*Note: Standard reading is the reading set on Measuring Tape (UUC) & Observed reading is the average of 3 readings of Master Equipment

Uncertainty of Measurement : 0.29 mm (at confidence level of 95.45% & coverage factor $k=2$)

Noted / Reviewed / Witnessed
Accepted / Not Accepted
03/11/2020
Bureau Veritas India Pvt Ltd. Mahesh Hosamani Pune

Minal Gaykar 12/11/20	P.D. Wadikar
CALIBRATED BY (Calibration Engineer)	APPROVED BY (Lab Manager)

. The calibration results reported in this certificate are valid at the time of and under stated condition of the measurements.
. The calibration certificate shall not be reproduced except in full without our prior permission in writing.
. This Certificate relates only to the item Calibrated.

United Calibrations Pvt. Ltd. Pune - 32

NIHVA TECHNOLOGIES PVT. LTD. PUNE

Calibration Certificate

CERTIFICATE NO.	UCPL/2021/H01549/07	CALIBRATION DATE	31.10.2020
		NEXT DUE DATE (As per Customer Requirement)	30.10.2021
		PAGE NO..	1 of 1
RECEIPT ENTRY NO.	UCPL/-IW-H01549	DATE OF RECEIPT	31.10.2020
		RECEIPT CONDITION	Functioning Properly
CUSTOMER	M/s. NIHVA Technologies Pvt Ltd., 8/1 Coromant Hsg. Soc. Sector 27 Pradhikaran, Nigdi, Pune - 411044.		

UUC Details

Description	: Spirit Level (Magnetic)		Make	:	TAPARIA
Size/Range	: 300 mm		Sr. No.	:	-
L.C.	: 0.5 mm / m		ID. No.	:	-
Location	: -		Model No.	:	SLM10 12

Reference Used : IS: 5706 –1993,
Procedure No. Used : UCPL/CP/MECH/35
Environmental Condition : Temperature: 20 ± 2°C & Humidity: 40 to 60 % Rh

Details of Standards / Equipments used for Calibration

Description	ID. No.	Calibrated By	Certificate No..	Valid Upto
Slip Gauge Set M 88/1	UCPL/SG/01	Samarth Calibration Laboratory	SCL/19-20/11/212-001	24.11.2021
Surface Plate	UCPL/SP/01	Samarth Calibration Laboratory	SCL/18-19/02/167-001	10.02.2021
Spirit Level	UCPL/SL/02	Shreyash Enterprises	SE.20.07.0310	16.07.2021

Traceability: Traceable to National / International standards through NABL Accredited calibration laboratory.

INSTRUMENTAL ERROR

SR. NO.	Scale Reading Of Spirit Level mm/m	Error Observed mm/m L.H.S.	Error Observed mm/m R.H.S.
1	0.02	-0.010	-0.012
2	0.04	-0.015	-0.013
3	0.06	-0.020	-0.021
4	0.08	-0.025	-0.025
5	0.10	-0.044	-0.042

*UUC:Unit Under Calibration , Test Point set on UUC.

Uncertainty of Measurement (at 95.45% of confidence level & coverage factor k=2): ± 0.01 µ/Meter

Noted / Reviewed / Witnessed
Accepted / Not Accepted
03/11/2020
Mahesh Hosamani
Pune

Bureau Veritas India Pvt. Ltd.

United Calibrations Pvt. Ltd. Pune

Minal Gaykar
CALIBRATED BY (Calibration Engineer)

P.D.Wadikar
APPROVED BY (Lab Manager)

- The calibration results reported in this certificate are valid at the time of and under stated condition of the measurements.
- The calibration certificate shall not be reproduced except in full without our prior permission in writing.
- This Certificate relates only to the item Calibrated.

UCPL/F/MECH/03/35

NIHVA TECHNOLOGIES PVT. LTD. PUNE

CC - 3137

UNITED CALIBRATIONS
NABL APPROVED LAB PVT. LTD.

United Calibrations

Flat No-2, Shyama Enclave, Nr. Priyadarshani school, Indrayani Nagar, Bhosari, Pune - 411026.
Mob: +91- 8411009211/12, Email : info@unitedcalibrations.com, Website: www.unitedcalibrations.com

Calibration Certificate

CERTIFICATE NO.	UCPL/2021/H01549/03	CALIBRATION DATE	31.10.2020
		NEXT DUE DATE (As per Customer Requirement)	30.10.2021
		PAGE NO..	1 of 2
RECEIPT ENTRY NO.	UCPL/-IW-H01549	DATE OF RECEIPT	31.10.2020
		RECEIPT CONDITION	Functioning Properly
ULR NO.	CC313720000003574F	Certificate Issue Date	31.10.2020
CUSTOMER	M/s. NIHVA Technologies Pvt Ltd., 8/1 Coromant Hsg. Soc. Sector 27 Pradhikaran, Nigdi, Pune - 411044.		

UUC Details

Description	:	Measuring Tape- Steel	Make	:	Freemans
Size/Range	:	15 mtr	Sr. No.	:	-
L.C.	:	1 mm	ID. No.	:	-
Location	:	At lab of United Calibrations Pvt. Ltd.,	Accuracy	:	-

Reference Used : IS 1269 (Part 2)-1987
Procedure No. Used : UCPL/CP/MECH/32
Environmental Condition : Temperature: 20 ± 2°C & Humidity: 40 to 60 % Rh

Details of Standards / Equipments used for Calibration

Name of Master Equipment / Reference Standard	ID. No. / Sr. No.	Calibrated By	Certificate No..	Valid Upto
Tape & Scale Calibrator	UCPL/MSTC/01	JRPM Lab	JRPM-CCTR-DIM-2020-2662	09.09.2021

Traceability: Traceable to National / International standards through NABL Accredited calibration laboratory.

Calibration Results: All readings in mm

Error in Readings :

Standard Reading	Observed Reading*	Error	Standard Reading	Observed Reading*	Error	Standard Reading	Observed Reading*	Error
10.00	10.005	-0.005	1500.00	1500.013	-0.013	4000.00	4000.025	-0.025
500.00	500.008	-0.008	2000.00	2000.017	-0.017	5000.00	5000.027	-0.027
1000.00	1000.011	-0.011	3000.00	3000.021	-0.021	6000.00	6000.032	-0.032

Noted / Reviewed / Witnessed
Accepted / Not Accepted
03/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani Pune

Minal Gaykar	P.D. Wadikar
CALIBRATED BY (Calibration Engineer)	APPROVED BY (Lab Manager)

. The calibration results reported in this certificate are valid at the time of and under stated condition of the measurements.
. The calibration certificate shall not be reproduced except in full without our prior permission in writing.
. This Certificate relates only to the item Calibrated.

United Calibrations Pvt. Ltd. Pune - 26

NIHVA TECHNOLOGIES PVT. LTD. PUNE

CERTIFICATE OF ANALYSIS
CoA

Product : **JOTAMASTIC 80 GREY A 16L**
Colour:
Production Date : **07-08-2020**
Batch No : **2277484-1-*-1:2**
Product Code : **0ARGRESVA**
Best Before Date : **06-08-2024**

Test	Result	Ref. Standard
DENSITY-PYKNOMETER/ISO-ASTM-BS-DIN	1558	1554 - 1614 kg/m3
GRINDOMETER/ISO 1524	50	- 50 um
SAG MEASURED/SAG INDEX APPLIC.	450	400 - um

This is an electronically generated document and need not any signature or stamp.

QC Laboratory
Analysis No : 2668176

ANHIVA TECHNOLOGIES PVT. LTD. * PUNE *

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

JOTUN

CERTIFICATE OF ANALYSIS
CoA

Product : **JOTAMASTIC 80, STD COMP B 2.3L**
Colour:
Production Date : **14/07/2020**
Batch No : **2253296-1-*-1:2**
Product Code : **0ARCASCNA**
Best Before Date : **30/07/2024**

Test	Result	Ref. Standard
CONE 0-10 P AT 23 DEG.C/ISO 2884	6100	5000 - 7000 cP
DENSITY-PYKNOMETER/ISO-ASTM-BS-DIN	1035	1030 - 1050 kg/m3

This is an electronically generated document and need not any signature or stamp.

QC Laboratory
Analysis No : 2668176

NIHVA TECHNOLOGIES PVT. LTD. * PUNE *

BUREAU VERITAS
Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

JOTUN

CERTIFICATE OF ANALYSIS
CoA

Product:	**HARDTOP XP, COMP B 1.8L**
Colour:	
Production Date:	**28/09/2020**
Batch No:	**2315526-1-*-1:2**
Product Code:	**0UVCPBBTA**
Best Before Date:	**27/09/2024**

Test	Result	Ref.Standard
CONE 0-10 P AT 23 DEG.C/ISO 2884	537	500 – 800 cP
DENSITY-PYKNOMETER/ISO 2811-1	1.13	1.11 – 1.15 kg/m3

"This is an electronically generated document and need not any signature or stamp."

QC-laboratory
Analysis number: 2279961

NIHVA TECHNOLOGIES PVT. LTD. * PUNE *

BUREAU VERITAS

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020

Bureau Veritas
India Pvt. Ltd.

Mahesh Hosamani
Pune

JOTUN

CERTIFICATE OF ANALYSIS
CoA

Product:	**HARDTOP XP**
Colour:	**RAL 7035**
Production Date:	**15/05/2020**
Batch No:	**2183383-1-*-1:3**
Product Code:	**0UVBAWSPA**
Best Before Date:	**14/05/2024**

Test	Result	Ref.Standard
APPLIC. PROP. AIRLESS SPRAY & SAG	200	200 - um
COLOUR/STRENGTH MCI-BASE/DIN 53234	97.88	96 -104 *
CONE 0-10 P AT 23 DEG.C/ISO 2884	290	200 – 300 cP
DENSITY-PYKNOMETER/ISO 2811-1	1.427	1.411 – 1.451 kg/m3
DRYING TIME/BECK KOLLER	4	3 – 6 h
GRINDOMETER/ISO 1524	20	0 - 30 um
POT LIFE AT 23 DEG.C	2	1.25 - h
SAG MEASURED/SAG INDEX APPLIC.	175	175 - um
SPECULAR GLOSS AT 60 DEG.	81.6	70 – 90 GU

"This is an electronically generated document and need not any signature or stamp."

QC-laboratory
Analysis number: 2304751

NIHVA TECHNOLOGIES PVT. LTD. * PUNE *

BUREAU VERITAS

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020

Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

METASYS LABORATORIES

Chemical, Physical,Metallurgical Testing of Metal, Hardness Testing
Surface Roughness, On Site Surface Hardness, Salt Spray Testing.
F - 44, VIP Industrial Premises, 1st Floor, Near Vishweshwar Bank, Sector No 7, Bhosari , Pune-26
Email- metasyslab2018@gmail.com Mob- 7721095959, 8446716218

TEST REPORT

Customer Name:-
M/s Dutta Control
Gat No. 83, Jyotiba Nagar, Talwade
Ph No. 02027691152

T.C. No.- DEC 416
Date -: 31.12.2019

Your Ref- Challan No - --

Sample Description : Piston Rod Dia 35.0 mm, **Material** -EN 8D

Date -: 31.12.2019

The above samples has been tested and result are as below.

Chemical Analysis			
Element	Observed	Specified	
	%	Min	Max
C %	0.41	0.40	0.45
Mn %	0.79	0.70	0.90
Si %	0.14	0.05	0.35
S %	0.023	----	0.050
P %	0.013	----	0.050

Remark-Chemical report of sample material tested as above meet with the requirement of BS 970 : 1991; Gr. EN 8D

For Metasys Laboratories

Authorised Signature

METASYS LABORATORIES PUNE

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani Pune

NIHVA TECHNOLOGIES PVT. LTD. PUNE

METASYS LABORATORIES

Chemical, Physical,Metallurgical Testing of Metal, Hardness Testing
Surface Roughness, On Site Surface Hardness, Salt Spray Testing.
F - 44, VIP Industrial Premises, 1st Floor, Near Vishweshwar Bank, Sector No 7, Bhosari , Pune-26
Email- metasyslab2018@gmail.com **Mob**- 7721095959, 8446716218

TEST REPORT

Customer Name;-
M/s Dutta Control
Gat No. 83, Jyotiba Nagar, Talwade
Ph No. 02027691152

T.C. No.- DEC 415
Date -: 31.12.2019

Your Ref - Challan No - ---

Date -: 31.12.2019

Sample Description:- Honed Tube ID 50 X OD 60 mm, **Material** - ST 52

The above sample has been tested and result are as below.

Chemical Analysis			
Element	Observed	Specified	
	%	Min	Max
C %	0.14	----	0.20
Mn %	1.44	0.90	1.70
Si %	0.190	----	0.50
S %	0.014	----	0.025
P %	0.016	----	0.030

Remark- Chemical report of sample material tested as above meet with the requirement of ST 52

For Metasys Laboratories

Authorised Signature

NIHVA TECHNOLOGIES PVT.LTD. * PUNE *

METASYS LABORATORIES PUNE

Witnessed / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

METASYS LABORATORIES

Chemical, Physical,Metallurgical Testing of Metal, Hardness Testing
Surface Roughness, On Site Surface Hardness, Salt Spray Testing.
F - 44, VIP Industrial Premises, 1st Floor, Near Vishweshwar Bank, Sector No 7, Bhosari , Pune-26
Email- metasyslab2018@gmail.com Mob- 7721095959, 8446716218

TEST REPORT

Customer Name:-
M/s Dutta Control
Gat No. 83, Jyotiba Nagar, Talwade
Ph No. 02027691152

T.C. No.- DEC 417
Date -: 31.12.2019

Your Ref- Challan No - --

Date -: 31.12.2019

Sample Description : Piston Rod Dia 25.0 mm, **Material** -EN 8D

The above samples has been tested and result are as below.

Chemical Analysis			
Element	Observed	Specified	
	%	Min	Max
C %	0.43	0.40	0.45
Mn %	0.82	0.70	0.90
Si %	0.16	0.05	0.35
S %	0.021	----	0.050
P %	0.016	----	0.050

Remark-Chemical report of sample material tested as above meet with the requirement of BS 970 : 1991: Gr. EN 8D

For Metasys Laboratories

Authorised Signature

METASYS LABORATORIES PUNE

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani
Pune

NIMA TECHNOLOGIES PVT. LTD. PUNE

ACCURATE LABORATORY SERVICES

CHEMICAL & MECHANICAL ANALYSIS OF FERROUS
& NON FERROUS METALS & ALLOYS

Office & Works : Plot no. 71/1 - B : 7, General Block, MIDC Bhosari, Pune - 411 026.
Phone : 020 - 2712 1056 email : dinkarp698@yahoo.com

NABL Certificate No. Chem. :-T-1596 Mech. :-T-1597

To,
M/S SANKALP STEELTECH CORPORATION PVT LTD
PLOT NO 140/141,PCNTDA,MIDC,BHOSARI,
PUNE 411026

Test Certificate

T.C. NO	PLS_30L20_068.1	Condition of sample	Satisfactory
T.C. Date	18/11/2020	Environmental Cond.	As Specified
Requisition No	4810/13/11/2020	Test Method Used	AS Applicable
Record From	Sankalp Steeltech Corporation Pvt Ltd	Received on	18/11/2020
Deviations/ Subcontracting	Nil		
Sample Code	PLS_30L20_062.1		
Sample Description	175 X 82 mm MS Beam		
Marked As	--		
Stamped As	--		
General Information	--		
Tested Specification	IS 2062 gr. Designation E 250 Quality A- Ed.2011		

Chemical Analysis (OES)		IS8811:1998	Specified	SC_30L13_068.1
			Result	R/V
Carbon	(C)	%	0.21	(0.23 Max)
Silicon	(Si)	%	0.210	(0.60 Max)
Manganese	(Mn)	%	0.75	(1.70 Max)
Phosphours	(P)	%	0.020	(0.035 Max)
Sulphur	(S)	%	0.020	(0.035 Max)
Chromium	(Cr)	%	NS	--
Molebdenum (#)	(Mo)	%	NS	--
Nickel (#)	(Ni)	%	NS	
Aluminium	(Al)	%	NS	
Copper	(Cu)	%	NS	
Vanadium	(V)	%	0.000	
Carbon Eq (*)		%	0.335	

Noted / Reviewed / Witnessed
Accepted / Not Accepted
24/11/2020
Bureau Veritas India Pvt. Ltd.
Mahesh Hosamani Pune

Mechanical Analysis		Result	R/V
Yield Load	kN	35.38	
Ultimate Load	kN	46.50	
Yield Stress	N/mm2	345	(345 Min)
UTS	N/mm2	491	(470-630)
Elongation	%	29	(22.00 Min)
Bend		Pass	

Remarks: The given sample/s meet/s the requirement/s of IS-2062 Gr.Designation E 250 Quality A-Ed.2011 With respect to the tests carried out

ACCURATE LABORATORY SERVICES MIDC.. BHOSARI. PUNE-26

ACCURATE LABORATORY SERVICES

Checked By

O. T. Patil [Technical Manager (Director)]

SANKALP STEELTECH CORPORATION PUNE-26

NIHVA TECHNOLOGIES PVT.LTD. PUNE