

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


1 TYPA -A


TYPE A- 1200X2100
2hr,FIRE RATED, PRESS METAL SINGLE SHUTTER

NOTES :-
1) Door Frame shall be fabricated from 1.2mmThk. Glav. steel sheets to form a double rebate profile & fixed to wall with Anchor bolts.
2) Shutter Panels shall be fabricated from 0.8mmThk. Galv.steel having Tray & Cover Construction to provide a nominal thickness of 43mm. Shutter flatness may vary till 5mm.& shutters shall have infill material with reinforcements at top, bottom edges & for hardware fitments.
3) 4nos. of SS Ball Bearing Butt Hinges shall be provided on each Shutter Size 4"x3"X3mm--
4) Dorma PHCR 1000 Panic bar with Outsie trim
5) SS D Handle Pair
6) Godrej Door Closer









This drawing & designing is the property of NIHVA TECHNOLOGIES. Not be sold or copy to any other concern

TITLE: FIRE DOOR			NIHVA TECHNOLOGIES PVT. LTD.
	SIGN	DATE	CLIENT –INDO COUNT
DRAWN	ABHIJIT	09/07/15	PROJECT–
CHECK	ANIL	09/07/15	SITE –HATKANGALE, MIDC
MFG			DWG. NO. –NIHVA/15–16/056
Ref. No.			SCALE: 01 | WT: | SHEET: 01
CLIENT APPROVAL	ALL DIMENSION ARE IN mm		If any queries contact : projects@nihva.com

NIHVA TECHNOLOGY PVT. LTD. PUNE
Tel : 020 66304033
Email:– info@nihva.com
Website:– www.nihva.com

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT
PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT
PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT