ACO Passavant

Grease separator — size calculation
Per kitchen equipment and outlet valves

Object / installation area

Date
23.7.2018

Builder-owner
PANCHSHIL REALTY

Planner

Nominal size (NS)	**15**
Grid trap size in liters	**1500**
Nominal size (NS) not rounded:	13.287

Calculation
with this formula
NS = Qs * fd * ft * fr

Our recommendations for planning and dimensioning are non-binding, generated upon your specification and have to be responsibly checked by customers.

Notes

Input data			**Calculated data**
Equipment units	Rinsing with odour seal, 40 mm:	32	
	Dish washer according to specification of the producer:	2	
	Outflow volume:	5	
	Outlet valves Nominal diameter DN 15 R 1/2:	6	Qs = 10.22
Difficulty factor	Density:	up to 0,94 g/cm³	fd = 1
	Inlet temperature:	up to 60° C	ft = 1
	Cleaning agents:	yes	fr = 1.3

Note: Calculation based on the outflow volume of dish washers according to specification of the producer.

ACO Passavant GmbH

Postfach 11 62
36267 Philippsthal
Ulsterstraße 3
36269 Philippsthal
Tel. 06620 77 - 0
Fax 06620 77 - 52
www.aco-haustechnik.de

Rechtsform GmbH
Sitz- und Registergericht:
Bad Hersfeld, HRB 757
Geschäftsführer:
Peter Fröhlich
Ust-Id-Nr. DE 812 611 394

Commerzbank AG, Bad Hersfeld
BLZ 520 800 80, Kto.-Nr.: 463 255 200
IBAN DE10 5208 0080 0463 2552 00, BIC COBADEFFXXX
Deutsche Bank AG, Hamburg
BLZ 210 700 20, Kto.-Nr.: 613 219 500
IBAN DE96 2107 0020 0613 2195 00, BIC DEUTDEHH210

Im Gewerbepark 11c
36457 Stadtlengsfeld
Tel. 036965 819 - 0
Fax 036965 819 - 361