Smith Structures India Pvt. Ltd.

Minutes of Meeting

Title	INSPECTION OF FIRE DOOR SINGLE AND DOUBLE LEAF		
Date	30-03-2024	**Time**	3.30 PM
Location	PUNE	**Duration**	

Participants

Serial No.	Name	Company
1)	SUNIL CHAUHAN 30/03/24	SSIPL
2)	ROHIT SHINDE 30/03/24	NIHVA
3)	JIGNESH SHUKLA	SSIPL (Telephonic Discussion)
4)	DHRUVAL PATEL	SSIPL (Telephonic Discussion)

Sr. No	Particulars	Action By	Remark
1)	Only One sample of Single Leaf Checked By Team	Rest Under Final Touch -up	
2)	Clear Height Required 2025 Found 2040 & Clear Width Required 1115 found 1102	Required Minimum 15mm Clearance to open Close the Door.	Gap Required to fixing the door Accessories
3)	Fire Rated Glass Thk Required 6 mm found 5.4 mm	Std Size Of Glass is 5 mm.	
4)	Door Opening of Single Leaf Door Must Be 07 Nos LHS & 07 RHS	During Fixing We are Ensure 07 NOS LHS 07 RHS	
5)	Powder Coating Must be As Per RAL 5010 and as Per The Sample Given By SSIPL	After Powder coating We will Share The Photos.	
6)	All Accessories Will be Gaze Make only but supporting document Not Available	Accessories Come With Engraving and punching	
7)	Complete Finish Product Not Available During Inspection.	After Powder coating work we will share the photos.	