


Abbrevation's:
WOW-Wall Opening Width
WOH-Wall Opening Height
UC-Under Cut
FFL-Finished Floor Level

## ASSESORIES DETALES

(a) HINGES: 4 No. SS Ball bearing butt hinges 100x75x3mm


(b) LOCK : PHCR 1000 series puch bar (Make Dorma)

(c) DOOR CLOSER: 1 No. Door Colser TS68 with std arm


(d) GLASS : 1No. Clear fire Vision Glass Clear 6mm of size 200x300mm.

Shutter thickness : 47 mm
Frame Sheet thick : 1.20mm
Shutter sheet thick : 0.80mm
Fixing : On RCC concreate plasterd wall with Anchors


NOTE:- *All Dimensions are in mm.
*Tolerance:-All Linear Dimensions ±3mm,Others ±0.5mm.
*The Drawing Is For Location of Hardware only. Drawing Does Not Represent The Hardware For More Clarity, Please Go Through Hardware Broucher.




Inside Elevation




Top View




Detail view of Section A

| FIRE DOOR SIZES | | |
|---|---|---|
| WOW | WOH | QUANTITY |
| 1200 | 2400 | 7 |

Color:- RAL 7035

This drawing & designing is the property of NIHVA TECHNOLOGIES. Not be sold or copy to any other concern.

Fire Door

CLIENT APPROVAL

ALL DIMENSION ARE IN mm

| | NAME | DATE | SIGN. |
|---|---|---|---|
| DRAWN | OMKAR | 08/02/16 | |
| CHECK | ANIL | 08/02/16 | |
| REV. | 00 | | |
| APPRD. | | | |
| MFG | | | |

NIHVA
NIHVA TECHNOLOGIES PVT. LTD.
NIHVA TECHNOLOGY PVT. LTD. PUNE
Tel : 020 66304033
Email:- info@nihva.com
Website:-www.nihva.com

CLIENT - S.S. GHORPADE
PROJECT -
SITE -
DWG. NO. - NIHVA/15-16/202
SCALE: 01 | WT: | SHEET: 01 OF 01
If any queries contact : projects@nihva.com