THESE ARE THE TWO AREAS WHERE WE ARE LOOKING FOR METAL + GLASS/PLASTIC RETRACTABLE ROOFING SYSTEMS - THIS AREA IS APPROX - 250SQFT

450 CFM
TOI.EX.FAN

HANDICAPPED

GRILLS TO BE PLACED ON FALSE CEILING @ 2380MM AFFL

FEMALE TOILET

GRILLS TO BE PLACED ON FALSE CEILING @ 2380MM AFFL

MALE TOILET

4100 CFM NEW
PROPOSED AHU
LOCATED ON SERVICE FLOOR

4100 CFM
750X350

12 SEATS

BAMBOO GARDEN

D'

FLOWER BED

1.5 TR EXISTING UNIT WITH BOXING

WAY TO BAMBOO GARDEN

we can consider adding a service door to cater to guests seated In bamboo garden

600 CFM
350X200

GRILLS MOUNTED ON FALSE CELING
AC Supply @ 2300mm AFFL

RECEPTION DESK

LIFT LOBBY

WAY TO BANQUET

A'

150 MM WIDE GRILLE

SIDE GRILLS - AC Supply @ 2900mm AFFL

C'

GRILLS MOUNTED ON FALSE CELING
AC Supply @ 2690mm AFFL

double height

48 SEATS

B

1100 CFM
500X250

2#150 CFM
200X150

2300 CFM
500X300

D

ENTRANCE TO ADD FOR INHOUSE GUESTS

COLD BUFFET

DESSERT BUFFET

DN

CHINESE

4100 CFM
750X300

MAIN ENTRANCE

150 MM WIDE GRILLE

GRILLS ALONG SIDE OF BULKHEAD - AC Supply @ 3500mm AFFL

THIS SHOULD COOL THE WAITING

PIZZA STATION

150 MM WIDE GRILLE

GRILLS ALONG SIDE OF COVE

GRILLS A'LACARTE

SLAB NEEDS TO BE 600MM

ENTRANCE
+ 0.450LVL

GRILLS MOUNTED ON FALSE CELING
AC Supply @ 3500mm AFFL

WAITING LOUNGE

9-10 SEATS WAITING LOUNGE

ALL - DAY DINING

COVE HT - 4500MM AFFL

GRILLS MOUNTED ON FALSE CELING
AC Supply @ 2690mm AFFL

COFFEE STATION

450 CFM
300X200

150 MM WIDE GRILLE

GRILLS MOUNTED ON FALSE CELING
600 AC Supply @ 2690mm AFFL

TANDOOR

6#SA DUCT
920 CFM
400X400

1 2 3 4 5

ENTRANCE TO ADD FOR WALK-INS

24 SEATS

AC Supply @ 2690mm AFFL

1350 CFM
300X400

C

EX DUCT
6500 CFM
750X450

SA DUCT
5500 CFM
700X450

A

PLEASE SUGGEST SOME A.C SYSTEM WHICH CAN BE SEAMLESSLY INTEGRATED WITHIN THE EXHISTING SLACKS IN THE ALFRESCO

IF THERE IS A POSSIBILITY TO PROVIDE A DOOR FOR EASY SERVICE TO ALFRESCO GUEST.

THESE ARE THE TWO AREAS WHERE WE ARE LOOKING FOR METAL + GLASS/PLASTIC RETRACTABLE ROOFING SYSTEMS - THIS AREA IS APPROX - 600SQFT

**1 Level 0**
1 : 50

| Rev | Description | Date |
|---|---|---|
| | | |

| | |
|---|---|
| CODE | SUITABILITY DESCRIPTION |
| STATUS | PURPOSE OF ISSUE |

www.autodesk.com/revit

PROJECT
Project Name

TITLE
Unnamed


CLIENT
Owner

| DRAWN BY | CHECKED BY | DATE |
|---|---|---|
| Author | Checker | 01/23/07 |

| SCALE (@ A1) | PROJECT NUMBER |
|---|---|
| 1 : 50 | Project Number |

| DRAWING NUMBER | REV |
|---|---|
| A100 | |

12/12/2022 4:38:41 PM



REFERENCE IMAGE FOR
PERPENDICULAR AND HORIZONTAL
RETRACTABLE ROOF.