Date : 25-12-18

TEST CERTIFICATE

To,

M/S Ratnarup projects pvt ltd

Please note that 01 No. Fire Rated Sliding door supplied by us vide your P.O. No.RPPL/PUNE/2258/KINGFA/18-19 Dated 17-11-18, qualify for fire resistance test as per test reference NoFR/0212. In this respect test report for similar Door is enclosed for your reference.

Fire Rated Sliding Door Size – 1600(W)mm X 2200(H)mm

Sliding door supplied specification will withstand standard fire exposure for 120 minutes.

For Nihva Technologies Pvt. Ltd.

PUNE ★ NIHVA TECHNOLOGIES PVT. LTD. ★

Authorized Signatory

Office Add:- 187/ G-Block, 1st Floor, Thermax Chowk, MIDC, Above Renault Showroom, Chinchwad, Pune - 411019
Reg. Add:- 8/1 Coromant Heg. Soc. Sec. No. 27, Nigdi, Pradhikaran, Pune - 411044.
+91 2066 3040 33 +91 85 51091 333 sales@nihva.com www.nihva.com | CIN No U72900PN2012PTC143948

This is to certify that the specimens described below were tested by the Fire research laboratory, CSIR – Central Building Research Institute, Roorkee – 247667. Under the test schedule 1/1 (reference No – FR/0212)

1.	Name of the laboratory:	Fire research laboratory, CSIR – Central Building Research Institute, Roorkee – 247667
2.	Name of the test:	Fire resistance test
3.	Date of test:	19/11/2015
4.	Ambient temp:	11 degree Celsius
5.	Fire exposure:	As per BS:476, Part20 & 22
6.	Applicability of test criteria:	Stability: yes Integrity: Yes Insulation: Yes
7.	Specimen details:	Double leaf sliding G.I. composite fire door(counter weight System) Door dimension (panel) Height: 3000 mm Width: 3200 mm Thickness: 40 mm Door panel thickness: 40 mm
8.	Door type:	Insulated
9.	Intended test duration:	Two hours

Test result:

The data of evaluation reveals that the double leaf sliding G.I. composite fire door with counter weight system has been found to be able to withstand standard fire exposure for 120 mins w.r.t. stability, integrity and thermal insulation.

