

<b><u>Class</u></b>	<b><u>Treatment Process</u></b>	<b><u>Design Flow</u></b> (in million gallons per day)
I	Pond.....	All
	Primary.....	1.0 or less
II	Primary.....	Greater than 1.0 through 5.0
	Biofiltration.....	1.0 or less
	Extended Aeration.....	All
III	Primary.....	Greater than 5.0 through 20.0
	Biofiltration.....	Greater than 1.0 through 10.0
	Activated Sludge.....	5.0 or less
	Tertiary.....	1.0 or less
IV	Primary.....	Greater than 20.0
	Biofiltration.....	Greater than 10.0 through 30.0
	Activated Sludge.....	Greater than 5.0 through 20.0
	Tertiary.....	Greater than 1.0 through 10.0
V	Biofiltration.....	Greater than 30.0
	Activated Sludge.....	Greater than 20.0
	Tertiary.....	Greater than 10.0