

RIL-Patalganga ETAP

Project:

Location: Patalganga 7.0.0 Date: 01-07-2011

Page:

1

12345678

Contract: SN:

Engineer: Siddharth bhal Study Case: OPF
Filename: patalganga Study Case: OPF

Revision: Base
Config.: Normal

2-Winding Transformer Input Data

Transformer		Rating						n	% Tap	Adjusted	
ID	MVA	Prim. kV	Sec. kV	% Z	X/R	+ 5%	- 5%	% Tol.	Prim.	Sec.	% Z
gtg-1-tr	53.000	11.000	22.000	17.86	34.10	0	0	0	0	0	17.8600
GTG-2-TR	53.000	11.000	22.000	17.86	34.10	0	0	0	0	0	17.8600
TA-1	15.000	11.000	22.000	11.20	18.60	0	0	0	0	0	11.2000
TA-2	15.000	11.000	22.000	11.20	18.60	0	0	0	0	0	11.2000
TA-3	15.000	11.000	22.000	11.20	18.60	0	0	0	0	0	11.2000
TB-1	10.000	6.600	11.000	7.32	15.50	0	0	0	0	0	7.3200
TB-2	10.000	6.600	11.000	7.32	15.50	0	0	0	0	0	7.3200
TC 1	10.000	6.600	11.000	7.30	15.50	0	0	0	0	0	7.3000
TC-2	10.000	6.600	11.000	7.30	15.50	0	0	0	0	0	7.3000
TR-1	2.000	22.000	0.433	6.45	7.10	0	0	0	0	0	6.4500
TR-1-gen	40.000	100.000	22.000	14.30	27.30	0	0	0	0	0	14.3000
TR-2-gen	40.000	100.000	22.000	14.30	27.30	0	0	0	0	0	14.3000
TR-3	2.000	22.000	0.433	6.45	7.10	0	0	0	0	0	6.4500
TR-3-gen	40.000	100.000	22.000	14.30	27.30	0	0	0	0	0	14.3000
TR-4	2.000	22.000	0.433	6.50	7.10	0	0	0	0	0	6.5000
TR-6	2.000	22.000	0.433	6.38	7.10	0	0	0	0	0	6.3800
TR-7	2.000	22.000	0.433	6.35	7.10	0	0	0	0	0	6.3500
TR-9	2.000	22.000	0.433	6.51	7.10	0	0	0	0	0	6.5100
TR-11	2.000	6.600	0.433	6.33	7.10	0	0	0	0	0	6.3300
TR-13	2.000	6.600	0.433	6.33	7.10	0	0	0	0	0	6.3300
TR-14	2.000	6.600	0.400	6.31	7.10	0	0	0	0	0	6.3100
TR-16	2.000	6.600	0.400	6.31	7.10	0	0	0	0	0	6.3100
TR-17	2.000	6.600	0.433	6.41	7.10	0	0	0	0	0	6.4100
TR-19	2.000	6.600	0.433	6.41	7.10	0	0	0	0	0	6.4100
TR-21	12.500	22.000	6.600	10.74	18.60	0	0	0	0	0	10.7400
TR-22	12.500	22.000	6.600	10.74	18.60	0	0	0	0	0	10.7400
TR-23	12.500	22.000	6.600	10.74	18.60	0	0	0	0	0	10.7400
TR-24	12.500	22.000	6.600	10.74	18.60	0	0	0	0	0	10.7400
TR-26	2.000	22.000	0.433	6.44	7.10	0	0	0	0	0	6.4400
TR-27	2.000	22.000	0.433	6.44	7.10	0	0	0	0	0	6.4400
TR-30	2.000	6.600	0.433	7.05	7.10	0	0	0	0	0	7.0500
TR-31	15.000	22.000	11.000	11.00	18.60	0	0	0	0	0	11.0000
TR-32	15.000	22.000	11.000	11.00	18.60	0	0	0	0	0	11.0000
TR-32A	15.000	22.000	11.000	11.00	18.60	0	0	0	0	0	11.0000
TR-33	2.000	11.000	0.433	6.63	7.10	0	0	0	0	0	6.6300
TR-35	1.600	11.000	0.433	6.70	7.10	0	0	0	0	0	6.7000
TR-36	1.600	11.000	0.433	6.70	7.10	0	0	0	0	0	6.7000
TR-CH-A	1.600	11.000	0.433	6.50	7.10	0	0	0	0	0	6.5000

ETAP RIL-Patalganga

Project: 7.0.0 Location: Patalganga

Contract:

Siddharth bhal Engineer: Revision: Study Case: OPF Filename: patalganga Config.:

Transformer Rating **Z** Variation % Tap Setting Adjusted ID - 5% MVA Prim. kV Sec. kV % Z + 5% % Tol. % Z X/R Prim Sec TR-CH-B 7.10 0 0 6.5000 1.600 11.000 0.433 6.50 0 0 TR-CH-C 1.600 11.000 0.433 6.50 7.10 0 0 0 0 0 6.5000 TR-CP7-1 3.500 11.000 0.433 6.66 11.41 0 0 0 0 0 6.6600 TR-CP7-3 11.000 0.433 11.41 0 6.6600 3.500 6.66 0 0 0 0 TR-CP7-4 11 000 0.433 7 37 10 67 7 3700 2.500 0 0 0 0 0 TR-CP7-6 11 000 0.433 7 37 10 67 0 0 0 0 0 7 3700 2 500 TR DG Aux 0.315 6.600 0.433 4.49 4.70 0 0 0 0 0 4.4900 TR-DL2 0.433 0 1.350 6.600 5.80 7.10 5.8000 TR- DL3 2.250 6.600 0.433 7.45 10.67 0 7.4500 TR-DL4 2.250 6.600 0.433 7.45 10.67 0 0 0 7.4500 TR-LP-I 1.500 11.000 0.433 6.20 7.10 0 0 0 0 0 6.2000 TR-UTL1 2.500 11.000 0.433 7.20 10.67 0 0 0 0 0 7.2000 TR-UTL-2 0 7.2000 2.500 11 000 0.433 7.20 10.67 0 0 0 0

Page:

Date:

SN:

2

01-07-2011

12345678

Base

Normal

2-Winding Transformer Load Tap Changer (LTC) Settings

Transformer Load Tap Changer Setting Transformer Connected Buses ("*" LTC Side) % Min. % Max. ID % V kV Primary Bus ID Secondary Bus ID Regulated Bus ID % Step Tap Tap TA-1 * Bus236 Bus237 1.250 Bus236 100.00 11.000 -10.00 10.00 * Bus43 Bus17 100.00 11.000 TA-2 -10.00 10.00 1.250 Bus43 * Bus238 Bus239 -10.00 10.00 Bus238 100.00 11.000 TA-3 1.250 TR-1-gen * 100kv_100kv_b 22kv_100kv_b -10.00 10.00 100kv_100kv_b 100.00 100.000 TR-2-gen * 100kv_100kv_c $22kv_100kv_c$ -10.00 10.00 1.250 22kv_100kv_c 100.00 22.000 22kv_100kv_a 22kv_100kv_a * 100kv_100kv_a 10.00 1.250 100.00 22.000 TR-3-gen -10.00 n tr-21 2 n tr-21 2 100.00 6.600 TR-21 * n_tr-21 -10.00 10.00 1.250 * n_tr-22 6.600 n_tr-22_2 10.00 1 250 n_tr-22_2 100 00 TR-22 -10.00 TR-23 * n_tr-23 n_tr-23_2 -10.00 10.00 1.250 n_tr-23_2 100.00 6.600 TR-24 n_tr-24_2 n_tr-24_2 100.00 * n_tr-24 -10.00 10.00 6.600

3-Winding Transformer Input Data

Transformer	Rating			Tap			Z Variation				
ID	Winding	MVA	kV	%	%	Z	X/R	MVAb	% Tol.	+ 5%	- 5%
TR-ZZ	Primary:	15.000	11.000	0	Zps =	11.64	20.00	15.000	0	0	0
	Secondary:	15.000	6.600	0	Zpt =	11.42	20.00	15.000	0		
	Tertiary:	15.000	6.600	0	Zst =	11.37	18.60	15.000	0		

ETAP RIL-Patalganga

Project: 3 Page: 7.0.0 Date: Location: Patalganga

01-07-2011 Contract: SN: 12345678

Siddharth bhal Engineer: Revision: Base Study Case: OPF

Filename: patalganga Config.: Normal

3-Winding Transformer Load Tap Changer (LTC) Settings

Transformer	Transformer LTC Side			Transformer Load Tap Changer Setting							
ID	Bus ID	% Min. Tap	% Max .Tap	% Step	Regulated Bus ID	% Voltage	kV				

ETAP RIL-Patalganga

Project: Page: 1 7.0.0 01-07-2011 Location: Patalganga Date:

Contract: SN: 12345678

Engineer: Siddharth bhal Revision: Base Study Case: OPF Filename: patalganga Config.: Normal

Line/Cable Input Data

Ohms or Siemens per 1000 m per Conductor (Cable) or per Phase (Line)

Line/Cable		Length								
ID	Library	Size	Length(m)	% Tol.	#/Phase	T (0C)	R	X	Y	
	`					T (°C)			1	
CHW-A Cable CHW-B Cable	6.6NALS3 6.6NALS3	300 400	150.0 150.0	0.0	1	75 75	0.130000 0.102000	0.105000 0.090000		
CHW-C Cable	6.6NALS3	400	70.0	0.0	1	75 75	0.102000	0.090000		
FIB Incomer-2 Cable	33NCUN3	300	300.0	0.0	3	75	0.076302	0.105000	0.000081	
FIB- Incomer 1 Cable	33NCUN3	300	300.0	0.0	3	75 75	0.076302	0.105000	0.000081	
HP-A Cable		300	70.0	0.0		75 75		0.105000	0.000081	
HP-C Cable	6.6NALS3 6.6NALS3	400		0.0	1	75 75	0.130000 0.102000	0.103000		
Incomer-1 Cable	6.6NALS3	400	70.0 50.0	0.0	1 2	75 75	0.102000	0.090000		
		400	50.0	0.0	2	75 75	0.102000	0.090000		
Incomer-2 Cable LA Cable	6.6NALS3 6.6NALS3	300	100.0	0.0	4	75 75	0.102000	0.105000		
LB Cable	6.6NALS3	300	100.0	0.0	4	75 75	0.130000	0.105000		
LLP-J Cable	11NALS3	400	250.0	0.0	2	75	0.102000	0.090000		
LP-A Cable	6.6NALS3	300	70.0	0.0	1	75	0.130000	0.105000		
LP-B Cable	6.6NALS3	300	70.0	0.0	1	75 75	0.130000	0.105000		
LP-C Cable	6.6NALS3	300	70.0	0.0	1	75	0.130000	0.105000		
LP-D Cable	6.6NALS3	400	70.0	0.0	1	75	0.102000	0.090000		
LP-H Cable	6.6NALS3	400	70.0	0.0	1	75	0.102000	0.090000		
LP-K Cable	6.6NALS3	400	70.0	0.0	1	75	0.102000	0.090000		
McQy -1 Cable	6.6NALS3	400	12.2	0.0	1	75	0.102000	0.090000		
McQy-2 Cable	6.6NALS3	300	70.0	0.0	1	75	0.130000	0.105000		
McQy-3 Cable	6.6NALS3	300	70.0	0.0	1	75	0.130000	0.105000		
McQy-4 Cable	6.6NALS3	400	40.0	0.0	1	75	0.102000	0.090000		
McQy-5 Cable	6.6NALS3	400	70.0	0.0	1	75	0.102000	0.090000		
McQy-6 Cable	6.6NALS3	300	70.0	0.0	1	75	0.130000	0.105000		
Offsite-A Cable	6.6NALS3	300	150.0	0.0	1	75	0.130000	0.105000		
Offsite B Cable	6.6NALS3	400	150.0	0.0	1	75	0.102000	0.090000		
Offsite C Cable	6.6NALS3	400	150.0	0.0	1	75	0.102000	0.090000		
Offsite D Cable	6.6NALS3	400	70.0	0.0	1	75	0.102000	0.090000		
TA-1 Cable P	11NALS3	300	300.0	0.0	3	75	0.130000	0.105000		
TA-1 Cable S	22NALS3	300	250.0	0.0	3	75	0.130000	0.105000		
ΓA-2 Cable P	11NALS3	300	300.0	0.0	3	75	0.130000	0.105000		
TA-2 Cable S	22NALS3	300	250.0	0.0	3	75	0.130000	0.105000		
TA-3 Cable P	11NALS3	300	350.0	0.0	3	75	0.130000	0.105000		
TA-3 Cable S	22NALS3	300	250.0	0.0	2	75	0.130000	0.105000		
TB-1 Cable P	6.6NALS3	400	50.0	0.0	1	75	0.102000	0.090000		
ΓB-1 Cable S	11NALS3	400	150.0	0.0	1	75	0.102000	0.090000		
ΓB-2 Cable P	6.6NALS3	400	50.0	0.0	1	75	0.102000	0.090000		
TB-2 Cable S	11NALS3	400	150.0	0.0	1	75	0.102000	0.090000		

ETAP

7.0.0 Location: Patalganga

RIL-Patalganga

Siddharth bhal

patalganga

Project:

Contract:

Engineer:

Filename:

01-07-2011 SN: 12345678

2

Page:

Date:

Revision: Base

Study Case: OPF Config.: Normal

Line/Cable Input Data

Ohms or Siemens per 1000 m per Conductor (Cable) or per Phase (Line)

Line/Cable			Length	1					
ID	Library	Size	Length(m)	% Tol.	#/Phase	T (°C)	R	X	Y
ГС-1 Cable P	6.6NALS3	400	20.0	0.0	2	75	0.102000	0.090000	
ГС-1 Cable S	11NALS3	400	500.0	0.0	2	75	0.102000	0.090000	
ГС-2 Cable P	6.6NALS3	400	20.0	0.0	2	75	0.102000	0.090000	
ГС-2 Cable S	11NALS3	400	500.0	0.0	2	75	0.102000	0.090000	
Γie-1 Cable	22NALS3	300	1200.0	0.0	3	75	0.130000	0.105000	
Γie-2 Cable	22NALS3	300	1200.0	0.0	3	75	0.130000	0.105000	
Fie-3 Cable	22NALS3	300	1200.0	0.0	3	75	0.130000	0.105000	
Γie-4 Cable	22NALS3	300	1600.0	0.0	3	75	0.130000	0.105000	
TR-1 Cable P	22NALS3	300	700.0	0.0	1	75	0.130000	0.105000	
R-3 Cable P	22NALS3	300	700.0	0.0	1	75	0.130000	0.105000	
ΓR-4 Cable P	22NALS3	300	35.0	0.0	1	75	0.130000	0.105000	
ΓR-6 Cable P	22NALS3	300	35.0	0.0	1	75	0.130000	0.105000	
ΓR-7 Cable P	22NALS3	300	35.0	0.0	1	75	0.130000	0.105000	
TR-9 Cable P	22NALS3	300	35.0	0.0	1	75	0.130000	0.105000	
R-11 Cable P	6.6NALS3	400	300.0	0.0	1	75	0.102000	0.090000	
R-13 Cable P	6.6NALS3	400	300.0	0.0	1	75	0.102000	0.090000	
TR-14 Cable P	6.6NALS3	400	300.0	0.0	1	75	0.102000	0.090000	
R-15 Cable P	6.6NALS3	400	300.0	0.0	1	75	0.102000	0.090000	
R-16 Cable P	6.6NALS3	400	300.0	0.0	1	75	0.102000	0.090000	
R-17 Cable P	6.6NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TR-19 Cable P	6.6NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TR-21 Cable P	22NALS3	300	100.0	0.0	1	75	0.130000	0.105000	
TR-21 Cable S	6.6NALS3	400	100.0	0.0	2	75	0.102000	0.090000	
R-22 Cable P	22NALS3	300	100.0	0.0	1	75	0.130000	0.105000	
TR-22 Cable S	6.6NALS3	400	100.0	0.0	2	75	0.102000	0.090000	
FR-23 Cable P	22NALS3	300	100.0	0.0	1	75	0.130000	0.105000	
TR-23 Cable S	6.6NALS3	400	100.0	0.0	2	75	0.102000	0.090000	
R-24 Cable P	22NALS3	300	100.0	0.0	1	75	0.130000	0.105000	
TR-24 Cable S	6.6NALS3	400	100.0	0.0	2	75	0.102000	0.090000	
TR-26 Cable P	22NALS3	300	213.4	0.0	1	75	0.130000	0.105000	
R-27 Cable P	22NALS3	300	700.0	0.0	1	75	0.130000	0.105000	
R-30 Cable P	6.6NALS3	400	50.0	0.0	1	75	0.102000	0.090000	
TR-31 Cable P	22NALS3	400	100.0	0.0	2	75	0.102000	0.090000	
R-31 Cable S	11NALS1	630	100.0	0.0	3	75	0.060600	0.086000	
R-32A Cable P	22NALS3	400	100.0	0.0	2	75	0.102000	0.090000	
FR-32A Cable S	11NALS3	400	100.0	0.0	2	75	0.102000	0.090000	
R-32 Cable P	22NALS3	300	100.0	0.0	2	75	0.130000	0.105000	
R-32 Cable S	11NALS1	630	100.0	0.0	2	75	0.060600	0.086000	

ETAP

RIL-Patalganga Project: 7.0.0 Location: Patalganga

Contract:

Engineer: Siddharth bhal

Filename: patalganga Page: 3 Date:

01-07-2011

SN: 12345678

Revision: Base

Config.: Normal

Line/Cable Input Data

Study Case: OPF

Ohms or Siemens per 1000 m per Conductor (Cable) or per Phase (Line)

Line/Cable	_		Length						
ID	Library	Size	Length(m)	% Tol.	#/Phase	T (°C)	R	X	Y
TR-33 Cable P	11NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TR-35 Cable P	11NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TR-36 Cable P	11NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TRANE-A Cable	6.6NALS3	400	70.0	0.0	1	75	0.102000	0.090000	
TRANE B Cable	6.6NALS3	400	70.0	0.0	1	75	0.102000	0.090000	
TR-CH-A Cable P	11NALS3	400	150.0	0.0	1	75	0.102000	0.090000	
TR-CH-B Cable P	11NALS3	400	150.0	0.0	1	75	0.102000	0.090000	
TR-CH-C Cable P	11NALS3	400	150.0	0.0	1	75	0.102000	0.090000	
TR-CP7-1 Cable P	11NALS3	400	450.0	0.0	1	75	0.102000	0.090000	
TR-CP7-3 Cable P	11NALS3	400	450.0	0.0	1	75	0.102000	0.090000	
TR-CP7-6 Cable P	11NALS3	400	450.0	0.0	1	75	0.102000	0.090000	
TR-CP7 4 Cable P	11NALS3	400	450.0	0.0	1	75	0.102000	0.090000	
TR-DG Aux Cable P	6.6NALS3	400	50.0	0.0	1	75	0.102000	0.090000	
TR-DL2 Cable P	6.6NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TR-DL3 Cable P	6.6NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TR-DL4 Cable P	6.6NALS3	400	700.0	0.0	1	75	0.102000	0.090000	
TR-LP-I Cable P	11NALS3	400	30.0	0.0	1	75	0.102000	0.090000	
TR-UTL-1 Cable P	11NALS3	400	110.0	0.0	1	75	0.102000	0.090000	
TR-UTL-2 Cable P	11NALS3	400	110.0	0.0	1	75	0.102000	0.090000	
TR ZZ Cable P	6.6NALS3	400	1200.0	0.0	3	75	0.102000	0.090000	
TR ZZ Cable S	6.6NALS3	300	50.0	0.0	2	75	0.130000	0.105000	

Line / Cable resistances are listed at the specified temperatures.