STEADY STATE RESULTS FOR OPENLOOP

(Results from Matlab/Simulink implementation by Dr Ulf Jeppsson, IEA, Lund University, Sweden, May 21 2009 based on Matlab R2008b (ver 7.7.0))

```
Influent characteristics
********
   SI = 30 \text{ mg COD/l}
   SS = 69.5 \text{ mg COD/l}
   XI = 51.2 \text{ mg COD/l}
   XS = 202.32 \text{ mg COD/l}
   XBH = 28.17 \text{ mg COD/l}
   XBA = 0 mg COD/1
   XP = 0 mg COD/1
   SO = 0 mg - COD/1
   SNO = 0 mg N/1
   SNH = 31.56 mg N/1
   SND = 6.95 mg N/1
   XND = 10.59 mg N/1
   SALK = 7 mol HCO3/m3
   TSS = 211.2675 \text{ mg } SS/1
Flow conditions
**********
   Influent flow to WWTP = 18446 \text{ m}3/d
   Influent flow to AS = 92230 \text{ m}3/d
   Internal recirculation = 55338 m3/d
   Settler feed flow = 36892 \text{ m}3/d
   Returned sludge flow = 18446 m3/d
   Wastage sludge flow = 385 \text{ m}3/d
   Effluent flow = 18061 \text{ m}3/d
Input to AS
******
   SI = 30 \text{ mg COD/l}
   SS = 14.6116 \text{ mg COD/l}
   XI = 1149.1183 \text{ mg COD/l}
   XS = 89.3302 \text{ mg COD/1}
   XBH = 2542.1684 \text{ mg COD/l}
   XBA = 148.4614 \text{ mg COD/l}
   XP = 448.1754 \text{ mg COD/l}
   SO = 0.39275 \text{ mg} - COD/1
   SNO = 8.3321 \text{ mg N/l}
   SNH = 7.6987 mg N/1
   SND = 1.9406 mg N/1
   XND = 5.6137 mg N/1
   SALK = 4.7005 mol HCO3/m3
   TSS = 3282.9402 mg SS/1
Reactor 1
******
   SI = 30 \text{ mg COD/l}
   SS = 2.8082 \text{ mg COD/l}
   XI = 1149.1252 \text{ mg COD/l}
   XS = 82.1349 \text{ mg COD/1}
   XBH = 2551.7658 \text{ mg COD/l}
   XBA = 148.3894 \text{ mg COD/l}
   XP = 448.8519 \text{ mg COD/l}
   SO = 0.0042984 \text{ mg } -COD/1
   SNO = 5.3699 mg N/1
   SNH = 7.9179 mg N/1
   SND = 1.2166 mg N/1
   XND = 5.2849 \text{ mg N/l}
   SALK = 4.9277 mol HCO3/m3
```

XP = 449.5227 mg COD/1SO = 6.3132e-05 mg -COD/1

SNO = 3.6620 mg N/1 SNH = 8.3444 mg N/1 SND = 0.88206 mg N/1 XND = 5.0291 mg N/1 SALK = 5.0802 mol HCO3/m3

TSS = 3282.5463 mg SS/1

Reactor 3 ******

SI = 30 mg COD/l

SS = 1.1495 mg COD/lXI = 1149.1252 mg COD/l

XS = 64.8549 mg COD/lXBH = 2557.1314 mg COD/l

XBA = 148.9413 mg COD/l

XP = 450.4184 mg COD/lSO = 1.7184 mg -COD/l

SNO = 6.5409 mg N/1SNH = 5.5479 mg N/1

SND = 0.82889 mg N/lXND = 4.3924 mg N/l

SALK = 4.6748 mol HCO3/m3

TSS = 3277.8534 mg SS/1

Reactor 4 ******

SI = 30 mg COD/l

SS = 0.99532 mg COD/lXI = 1149.1252 mg COD/l

XS = 55.6940 mg COD/1

XBH = 2559.18 mg COD/l

XBA = 149.5271 mg COD/1 XP = 451.3147 mg COD/1SO = 2.4289 mg -COD/1

SO = 2.4289 mg -COD/SNO = 9.2990 mg N/1

SNO = 9.2990 mg N/ISNH = 2.9674 mg N/I

SND = 0.76679 mg N/l

XND = 3.8790 mg N/l

SALK = 4.2935 mol HCO3/m3TSS = 3273.6327 mg SS/1

Reactor 5 ******

SI = 30 mg COD/l

SS = 0.88949 mg COD/l

XI = 1149.1252 mg COD/l

XS = 49.3056 mg COD/l

XBH = 2559.3437 mg COD/1

XBA = 149.7971 mg COD/1

XP = 452.2111 mg COD/1

SO = 0.49094 mg -COD/1

```
SNO = 10.4152 mg N/1
   SNH = 1.7333 mg N/1
   SND = 0.68828 mg N/1
   XND = 3.5272 \text{ mg N/l}
   SALK = 4.1256 \text{ mol } HCO3/m3
   TSS = 3269.8370 \text{ mg } SS/1
Settler underflow
******
   SI = 30 \text{ mg COD/l}
   SS = 0.88949 \text{ mg COD/l}
   XI = 2247.0504 \text{ mg COD/l}
   XS = 96.4143 \text{ mg COD/l}
   XBH = 5004.6542 \text{ mg COD/l}
   XBA = 292.9200 \text{ mg COD/l}
   XP = 884.2737 \text{ mg COD/1}
SO = 0.49094 mg -COD/1
   SNO = 10.4152 mg N/1
   SNH = 1.7333 mg N/1
   SND = 0.68828 \text{ mg N/l}
   XND = 6.8972 \text{ mg N/l}
   SALK = 4.1256 \text{ mol } HCO3/m3
   TSS = 6393.9844 \text{ mg } SS/1
Settler effluent
******
   SI = 30 \text{ mg COD/l}
   SS = 0.88949 \text{ mg COD/l}
   XI = 4.3918 \text{ mg COD/l}
   XS = 0.18844 \text{ mg COD/l}
   XBH = 9.7815 \text{ mg COD/l}
   XBA = 0.57251 mg COD/1
   XP = 1.7283 \text{ mg COD/l}
   SO = 0.49094 \text{ mg} - COD/1
   SNO = 10.4152 \text{ mg N/l}
   SNH = 1.7333 mg N/1
   SND = 0.68828 \text{ mg N/1}
   XND = 0.01348 \text{ mg N/l}
   SALK = 4.1256 \text{ mol } HCO3/m3
   TSS = 12.4969 \text{ mg } SS/1
Settler internal (1 is top layer)
*********
   TSS1 = 12.4969 mg SS/1
   TSS2 = 18.1132 mg SS/1
   TSS3 = 29.5402 \text{ mg } SS/1
   TSS4 = 68.9781 mg SS/1
   TSS5 = 356.0747 mg SS/1
   TSS6 = 356.0747 mg SS/1
   TSS7 = 356.0747 \text{ mg } SS/1
   TSS8 = 356.0747 \text{ mg } SS/1
   TSS9 = 356.0747 \text{ mg } SS/1
   TSS10 = 6393.9844 \text{ mg } SS/1
Other variables
******
   Trad. sludge age (XS + XP + XI + XBH + XBA in reactors) = 7.3155 days
   Spec. sludge age (XBH + XBA in reactors and settler) = 9.1436 days
   Total hydraulic retention time = 15.6118 hours
   Reactor hydraulic retention time = 7.8053 hours
   Thickening factor at bottom of settler (TSSu/TSSfeed) = 1.9554
   Thinning factor at top of settler (TSSeff/TSSfeed) = 0.0038219
```

Dimensions ******

Reactor 1 is anoxic

Volume reactor 1 = 1000 m3

Reactor 2 is anoxic

Volume reactor 2 = 1000 m3

Reactor 3 is aerobic

Volume reactor 3 = 1333 m3

Reactor 4 is aerobic

Volume reactor 4 = 1333 m3

Reactor 5 is aerobic

Volume reactor 5 = 1333 m3

Settler height = 4 m

Settler area = 1500 m2

Settler volume = 6000 m3