## Influent characteristics \*\*\*\*\*\*\* SI = 27.2262 mg COD/lSS = 58.1762 mg COD/lXI = 92.499 mg COD/1XS = 363.9435 mg COD/1XBH = 50.6833 mg COD/lXBA = 0 mg COD/1XP = 0 mg COD/1 SO = 0 mg -COD/1SNO = 0 mg N/1SNH = 23.8595 mg N/1SND = 5.6516 mg N/1XND = 16.1298 mg N/lSALK = 7 mol HCO3/m3TSS = 380.3443 mg SS/1Flow rate = 20648.3612 m3/dTemperature = 14.8581 degC Flow conditions Influent flow rate to WWTP = 20648.3612 m3/dPrimary clarifier feed flow rate = 21086.3838 m3/d Primary clarifier sludge flow rate = 147.6047 m3/d Primary clarifier effluent flow rate = 20938.7791 m3/d Influent flow rate to AS = 103530.7791 m3/dInternal recirculation flow rate = 61944 m3/d Settler feed flow rate = 41588.7791 m3/d Settler effluent flow rate = 20640.7791 m3/dReturned sludge flow rate = 20648 m3/d Wastage sludge flow rate = 300 m3/dThickener feed flow rate = 300 m3/d Thickener sludge flow rate = 30.8628 m3/d Thickener effluent flow rate = 269.1372 m3/d Digester feed flow rate = 178.4674 m3/d Digester output flow rate = 178.4674 m3/d Dewatering feed flow rate = 178.4674 m3/d Dewatering sludge flow rate = 9.5821 m3/d Dewatering effluent flow rate = 168.8853 m3/d Storage tank feed flow rate (not bypass) = 0 m3/dStorage tank effluent flow rate = 0 m3/dStorage tank bypass flow rate = 168.8853 m3/d Effluent flow rate = 20640.7791 m3/dSludge disposal flow rate = 9.5821 m3/d Primary clarifier effluent \*\*\*\*\*\* SI = 28.067 mg COD/lSS = 59.0473 mg COD/1XI = 49.3363 mg COD/lXS = 186.5845 mg COD/lXBH = 26.6115 mg COD/lXBA = 0.049484 mg COD/lXP = 0.34149 mg COD/lSO = 0.017547 mg -COD/1SNO = 0.11736 mg N/lSNH = 34.9215 mg N/1SND = 5.5457 mg N/lXND = 8.2683 mg N/l

SALK = 7.6965 mol HCO3/m3

TSS = 197.1925 mg SS/l Flow rate = 20938.7791 m3/d Temperature = 14.8581 degC

#### 

SI = 28.067 mg COD/l

SS = 59.0473 mg COD/1

XI = 6480.6885 mg COD/l

XS = 24509.2827 mg COD/1

XBH = 3495.6259 mg COD/l

XBA = 6.5001 mg COD/l

XP = 44.8572 mg COD/l

SO = 0.017547 mg -COD/1

SNO = 0.11736 mg N/1

SNH = 34.9215 mg N/1

SND = 5.5457 mg N/l

XND = 1086.1057 mg N/l

SALK = 7.6965 mol HCO3/m3

TSS = 25902.7158 mg SS/1

Flow rate = 147.6047 m3/d

Temperature = 14.8581 degC

## Input to AS

#### \*\*\*\*\*

SI = 28.0648 mg COD/l

SS = 12.4793 mg COD/l

XI = 1532.2905 mg COD/l

XS = 69.4433 mg COD/l

XBH = 2232.9521 mg COD/l

XBA = 166.7684 mg COD/l

XP = 964.1366 mg COD/l

SO = 1.1003 mg - COD/1

SNO = 7.3589 mg N/l

SNH = 7.1892 mg N/l

SND = 1.5679 mg N/l

XND = 4.0493 mg N/l

SALK = 5.198 mol HCO3/m3

TSS = 3724.1931 mg SS/1

Flow rate = 103530.7791 m3/d

Temperature = 14.8581 degC

## AS reactor 1

### \*\*\*\*\*

SI = 28.0643 mg COD/l

SS = 3.0503 mg COD/1

XI = 1532.2609 mg COD/l

XS = 63.0433 mg COD/l

XBH = 2245.0634 mg COD/l

XBA = 166.6699 mg COD/l

XP = 964.8992 mg COD/l

SO = 0.0093422 mg -COD/1

SNO = 3.935 mg N/1

SNH = 6.8924 mg N/1

SND = 0.95797 mg N/l

XND = 3.8453 mg N/l

SALK = 5.4213 mol HCO3/m3

TSS = 3728.9525 mg SS/1

Flow rate = 103532.7791 m3/d

Temperature = 14.8581 degC

```
AS reactor 2
*****
   SI = 28.0643 \text{ mg COD/l}
   SS = 1.3412 \text{ mg COD/l}
   XI = 1532.2609 \text{ mg COD/1}
   XS = 58.8579 \text{ mg COD/1}
   XBH = 2245.3852 \text{ mg COD/l}
   XBA = 166.5512 \text{ mg COD/l}
   XP = 965.6805 \text{ mg COD/l}
   SO = 0.00010907 \text{ mg} - COD/1
   SNO = 2.2207 \text{ mg N/l}
   SNH = 7.2028 mg N/1
   SND = 0.68624 mg N/1
   XND = 3.7424 \text{ mg N/l}
   SALK = 5.5659 \text{ mol } HCO3/m3
   TSS = 3726.5518 \text{ mg } SS/1
   Flow rate = 103532.7791 \text{ m}3/d
   Temperature = 14.8581 degC
AS reactor 3
*****
   SI = 28.0643 \text{ mg COD/l}
   SS = 0.95531 \text{ mg COD/l}
   XI = 1532.2609 \text{ mg COD/l}
   XS = 46.2983 \text{ mg COD/l}
   XBH = 2246.7994 \text{ mg COD/1}
   XBA = 167.3077 \text{ mg COD/l}
   XP = 967.2442 \text{ mg COD/l}
   SO = 0.46635 \text{ mg} - COD/1
   SNO = 5.5141 mg N/l
   SNH = 3.4247 mg N/1
   SND = 0.65129 \text{ mg N/l}
   XND = 3.1405 \text{ mg N/l}
   SALK = 5.0608 \text{ mol } HCO3/m3
   TSS = 3719.9329 \text{ mg } SS/1
   Flow rate = 103532.7791 \text{ m}3/d
   Temperature = 14.8581 degC
AS reactor 4
******
   SI = 28.0643 \text{ mg COD/l}
   SS = 0.78055 \text{ mg COD/l}
   XI = 1532.2609 \text{ mg COD/l}
   XS = 37.3881 \text{ mg COD/l}
   XBH = 2245.6315 mg COD/1
   XBA = 167.8339 \text{ mg COD/l}
   XP = 968.8072 \text{ mg COD/l}
   SO = 1.4284 \text{ mg} - COD/1
   SNO = 8.4066 \text{ mg N/l}
   SNH = 0.69216 mg N/1
   SND = 0.60938 \text{ mg N/l}
   XND = 2.6815 mg N/1
   SALK = 4.659 \text{ mol } HCO3/m3
   TSS = 3713.9412 \text{ mg } SS/1
   Flow rate = 103532.7791 \text{ m}3/d
   Temperature = 14.8581 degC
AS reactor 5
   SI = 28.0643 \text{ mg COD/l}
   SS = 0.67336 \text{ mg COD/1}
```

XI = 1532.2609 mg COD/lXS = 31.9144 mg COD/lXBH = 2242.1274 mg COD/lXBA = 167.8482 mg COD/lXP = 970.3678 mg COD/1SO = 1.3748 mg - COD/1SNO = 9.1948 mg N/lSNH = 0.15845 mg N/lSND = 0.55943 mg N/lXND = 2.3926 mg N/lSALK = 4.5646 mol HCO3/m3TSS = 3708.389 mg SS/1Flow rate = 103532.7791 m3/dtemperature = 14.8581 degC Settler underflow \*\*\*\*\* SI = 28.0643 mg COD/lSS = 0.67336 mg COD/lXI = 3036.2175 mg COD/lXS = 63.2392 mg COD/lXBH = 4442.8377 mg COD/1XBA = 332.5958 mg COD/lXP = 1922.8108 mg COD/lSO = 1.3748 mg - COD/1SNO = 9.1948 mg N/lSNH = 0.15845 mg N/lSND = 0.55943 mg N/lXND = 4.7411 mg N/lSALK = 4.5646 mol HCO3/m3TSS = 7348.2757 mg SS/1Flow rate = 20648 m3/dTemperature = 14.8581 degC Settler effluent \*\*\*\*\*\* SI = 28.0643 mg COD/lSS = 0.67336 mg COD/lXI = 5.9191 mg COD/lXS = 0.12329 mg COD/lXBH = 8.6614 mg COD/lXBA = 0.6484 mg COD/lXP = 3.7485 mg COD/lSO = 1.3748 mg - COD/1SNO = 9.1948 mg N/lSNH = 0.15845 mg N/lSND = 0.55943 mg N/lXND = 0.0092428 mg N/lSALK = 4.5646 mol HCO3/m3TSS = 14.3255 mg SS/1Flow rate = 20640.7791 m3/dTemperature = 14.8581 degC Settler internal (1 is top layer) TSS1 = 14.3255 mg SS/1TSS2 = 20.8756 mg SS/1TSS3 = 34.2948 mg SS/1TSS4 = 81.0276 mg SS/1TSS5 = 423.2035 mg SS/1TSS6 = 423.2035 mg SS/1

```
TSS7 = 423.2035 \text{ mg } SS/1
   TSS8 = 423.2035 \text{ mg } SS/1
   TSS9 = 3710.5517 \text{ mg } SS/1
   TSS10 = 7348.2757 \text{ mg } SS/1
Thickener effluent
*****
   SI = 28.0643 \text{ mg COD/l}
   SS = 0.67336 \text{ mg COD/l}
   XI = 67.6878 \text{ mg COD/l}

XS = 1.4098 \text{ mg COD/l}
   XBH = 99.0462 \text{ mg COD/l}
   XBA = 7.4147 \text{ mg COD/l}
   XP = 42.8661 \text{ mg COD/l}

SO = 1.3748 \text{ mg -COD/l}
   SNO = 9.1948 \text{ mg N/l}
   SNH = 0.15845 mg N/1
   SND = 0.55943 \text{ mg N/l}
   XND = 0.10569 \text{ mg N/l}
   SALK = 4.5646 mol HCO3/m3
   TSS = 163.8185 mg SS/1
   Flow rate = 269.1372 \text{ m}3/d
   Temperature = 14.8581 degC
Thickener underflow
******
   SI = 28.0643 \text{ mg COD/l}
   SS = 0.67336 \text{ mg COD/l}
   XI = 28923.142 \text{ mg COD/l}
   XS = 602.4198 \text{ mg COD/l}
   XBH = 42322.6689 \text{ mg COD/l}
   XBA = 3168.3222 \text{ mg COD/l}
   XP = 18316.7804 \text{ mg COD/l}
   SO = 1.3748 \text{ mg} - COD/1
   SNO = 9.1948 \text{ mg N/l}
   SNH = 0.15845 \text{ mg N/l}
   SND = 0.55943 \text{ mg N/l}
   XND = 45.1636 \text{ mg N/l}
   SALK = 4.5646 \text{ mol } HCO3/m3
   TSS = 70000 mg SS/1
   Flow rate = 30.8628 \text{ m}3/d
   Temperature = 14.8581 degC
Anaerobic digester influent (pre ASM2ADM interface)
   SI = 28.0665 \text{ mg COD/l}
   SS = 48.9526 \text{ mg COD/l}
   XI = 10361.7101 \text{ mg COD/l}
   XS = 20375.0176 \text{ mg COD/l}
   XBH = 10210.0698 \text{ mg COD/l}
   XBA = 553.2808 \text{ mg COD/1}
   XP = 3204.6601 \text{ mg COD/l}
   SO = 0.25225 \text{ mg} - COD/1
   SNO = 1.6871 mg N/1
   SNH = 28.9098 mg N/1
   SND = 4.6834 \text{ mg N/l}
   XND = 906.0933 \text{ mg N/l}
   SALK = 7.1549 \text{ mol } HCO3/m3
   TSS = 33528.5538 \text{ mg } SS/1
```

Flow rate = 178.4674 m3/d Temperature = 14.8581 degC

```
ADM1 influent (post ASM2ADM interface)
*********
   Ssu = monosacharides (kg COD/m3) = 0
   Saa = amino acids (kg COD/m3) = 0.04388
   Sfa = long chain fatty acids (LCFA) (kg COD/m3) = 0
   Sva = total valerate (kg COD/m3) = 0
   Sbu = total butyrate (kg COD/m3) = 0
   Spro = total propionate (kg COD/m3) = 0
   Sac = total acetate (kg COD/m3) = 0
   Sh2 = hydrogen gas (kg COD/m3) = 0
   Sch4 = methane gas (kg COD/m3) = 0
   Sic = inorganic carbon (kmole C/m3) = 0.0079326
   Sin = inorganic nitrogen (kmole N/m3) = 0.0019721
   Si = soluble inerts (kg COD/m3) = 0.028067
   Xc = composites (kg COD/m3) = 0
   Xch = carbohydrates (kg COD/m3) = 3.7236
   Xpr = proteins (kg COD/m3) = 15.9235
   Xli = lipids (kg COD/m3) = 8.047
  Xsu = sugar degraders (kg COD/m3) = 0
  Xaa = amino acid degraders (kg COD/m3) = 0
  Xfa = LCFA degraders (kg COD/m3) = 0
  Xc4 = valerate and butyrate degraders (kg COD/m3) = 0
  Xpro = propionate degraders (kg COD/m3) = 0
  Xac = acetate degraders (kg COD/m3) = 0
  Xh2 = hydrogen degraders (kg COD/m3) = 0
  Xi = particulate inerts (kg COD/m3) = 17.0106
  Scat+ = cations (base) (kmole/m3) = 0
   San-= anions (acid) (kmole/m3) = 0.0052101
   Flow rate (m3/d) = 178.4674
  Temperature (degC) = 35
ADM1 effluent (prior ADM2ASM interface)
*********
   Ssu = monosacharides (kg COD/m3) = 0.012394
   Saa = amino acids (kg COD/m3) = 0.0055432
   Sfa = long chain fatty acids (LCFA) (kg COD/m3) = 0.10741
   Sva = total valerate (kg COD/m3) = 0.012333
   Sbu = total butyrate (kg COD/m3) = 0.014003
   Spro = total propionate (kg COD/m3) = 0.017584
   Sac = total acetate (kg COD/m3) = 0.089315
   Sh2 = hydrogen gas (kg COD/m3) = 2.5055e-07
   Sch4 = methane gas (kg COD/m3) = 0.05549
   Sic = inorganic carbon (kmole C/m3) = 0.095149
   Sin = inorganic nitrogen (kmole N/m3) = 0.094468 (= 1.3226 kg
N/m3)
   Si = soluble inerts (kg COD/m3) = 0.13087
   Xc = composites (kg COD/m3) = 0.10792
   Xch = carbohydrates (kg COD/m3) = 0.020517
   Xpr = proteins (kg COD/m3) = 0.08422
  Xli = lipids (kg COD/m3) = 0.043629
  Xsu = sugar degraders (kg COD/m3) = 0.31222
  Xaa = amino acid degraders (kg COD/m3) = 0.93167
  Xfa = LCFA degraders (kg COD/m3) = 0.33839
  Xc4 = valerate and butyrate degraders (kg COD/m3) = 0.33577
   Xpro = propionate degraders (kg COD/m3) = 0.10112
  Xac = acetate degraders (kg COD/m3) = 0.67724
   Xh2 = hydrogen degraders (kg COD/m3) = 0.28484
   Xi = particulate inerts (kg COD/m3) = 17.2162
   Scat+ = cations (base) (kmole/m3) = -4.0789e-34
   San- = anions (acid) (kmole/m3) = 0.0052101
```

```
Flow rate (m3/d) = 178.4674
   Temperature (degC) = 35
   pH = pH within AD system = 7.2631
   S H+ = protons (kmole/m3) = 5.4562e-08
   Sva- = valerate (kg COD/m3) = 0.012284
   Sbu- = butyrate (kg COD/m3) = 0.013953
   Spro- = propionate (kg COD/m3) = 0.017511
   Sac- = acetate (kg COD/m3) = 0.089035
   Shco3- = bicarbonate (kmole C/m3) = 0.08568
   Sco2 = carbon dioxide (kmole C/m3) = 0.0094689
   Snh3 = ammonia (kmole N/m3) = 0.001884
   Snh4+ = ammonium (kmole N/m3) = 0.092584
   Sgas, h2 = hydrogen concentration in gas phase (kg COD/m3) =
1.1032e-05
   Sgas, ch4 = methane concentration in gas phase (kg COD/m3) = 1.6535
   Sgas, co2 = carbon dioxide concentration in gas phase (kmole C/m3)
= 0.01354
   pgas, h2 = partial pressure of hydrogen gas (bar, true value i.e.
not normalized) = 1.7666e-05
  pgas, ch4 = partial pressure of methane gas (bar, true value i.e.
not normalized) = 0.66195
   pgas,co2 = partial pressure of carbon dioxide gas (bar, true
value, i.e. not normalized) = 0.34691
   pgas, total = total head space pressure of H2+CO2+CH4+H2O (bar,
true value, i.e. not normalized) = 1.0645
   qgas = gas flow rate normalized to atmospheric pressure (m3/d) =
2708.3431
 Extra calculated outputs
   Produced hydrogen gas (kg H2/d) = 0.0035541
   Produced methane gas (kg CH4/d) = 1065.3523
   Produced carbon dioxide gas (kg CO2/d) = 1535.4118
   Energy content of methane gas (MJ/d) = 53282.5305
   Energy content of methane gas (kWh/d) = 14800.7029
Anaerobic digester output (post ADM2ASM interface)
SI = 130.867 \text{ mg COD/l}
   SS = 258.5789 \text{ mg COD/l}
   XI = 17216.2434 \text{ mg COD/l}
   XS = 2611.4843 \text{ mg COD/l}
  XBH = 0 mg COD/1
  XBA = 0 mg COD/1
  XP = 626.0652 \text{ mg COD/l}
   SO = 0 mq - COD/1
   SNO = 0 mg N/1
   SNH = 1442.7882 mg N/1
   SND = 0.54323 \text{ mg N/l}
  XND = 100.8668 \text{ mg N/l}
   SALK = 97.8459 \text{ mol } HCO3/m3
   TSS = 15340.3447 \text{ mg } SS/1
   Flow rate = 178.4674 \text{ m}3/d
   Temperature = 14.8581 degC
Dewatering effluent (reject water)
SI = 130.867 \text{ mg COD/l}
   SS = 258.5789 \text{ mg COD/l}
   XI = 363.861 \text{ mg COD/l}
   XS = 55.1931 \text{ mg } COD/1
   XBH = 0 mg COD/1
```

```
XBA = 0 mg COD/1
   XP = 13.2317 \text{ mg COD/l}
   SO = 0 mg - COD/1
   SNO = 0 mg N/1
   SNH = 1442.7882 \text{ mg N/l}
   SND = 0.54323 \text{ mg N/l}
   XND = 2.1318 \text{ mg N/l}
   SALK = 97.8459 \text{ mol } HCO3/m3
   TSS = 324.2144 \text{ mg } SS/1
   Flow rate = 168.8853 \text{ m}3/d
   Temperature = 14.8581 degC
Storage tank effluent
******
   SI = 136.0888 mg COD/1
SS = 253.4258 mg COD/1
XI = 363.2948 mg COD/1
XS = 56.0649 mg COD/1
   XBH = 0 mg COD/1
   XBA = 0 mg COD/1
   XP = 13.5135 \text{ mg COD/l}

SO = 0 \text{ mg -COD/l}
   SNO = 0 mg N/1
   SNH = 1512.3975 mg N/1
   SND = 0.4663 \text{ mg N/l}
   XND = 2.1557 \text{ mg N/l}
   SALK = 102.7732 \text{ mol } HCO3/m3
   TSS = 324.6548 \text{ mg } SS/1
   Flow rate = 0 \text{ m}3/d
   Temperature = 14.6913 degC
   Storage tank water volume = 144.1608 m3
Storage tank bypass
******
   SI = 130.867 \text{ mg COD/l}
   SS = 258.5789 \text{ mg COD/l}
   XI = 363.861 \text{ mg COD/l}
   XS = 55.1931 \text{ mg COD/l}
   XBH = 0 mg COD/1
   XBA = 0 mg COD/1
   XP = 13.2317 \text{ mg COD/l}
   SO = 0 mq - COD/1
   SNO = 0 mg N/1
   SNH = 1442.7882 \text{ mg N/l}
   SND = 0.54323 \text{ mg N/l}
   XND = 2.1318 mg N/1
   SALK = 97.8459 \text{ mol } HCO3/m3
   TSS = 324.2144 \text{ mg } SS/1
   Flow rate = 168.8853 \text{ m}3/d
   Temperature = 14.8581 degC
Storage tank output + bypass
   SI = 130.867 \text{ mg COD/l}
   SS = 258.5789 \text{ mg COD/1}
   XI = 363.861 \text{ mg COD/l}
   XS = 55.1931 \text{ mg COD/l}
   XBH = 0 mg COD/1
   XBA = 0 mg COD/1
   XP = 13.2317 \text{ mg COD/l}
   SO = 0 mg - COD/1
```

```
SNO = 0 mg N/1
   SNH = 1442.7882 \text{ mg N/l}
   SND = 0.54323 \text{ mg N/l}
   XND = 2.1318 \text{ mg N/l}
   SALK = 97.8459 \text{ mol } HCO3/m3
   TSS = 324.2144 \text{ mg } SS/1
   Flow rate = 168.8853 \text{ m}3/d
   Temperature = 14.8581 degC
WWTP effluent
******
   SI = 28.0643 \text{ mg COD/l}

SS = 0.67336 \text{ mg COD/l}
   XI = 5.9191 \text{ mg COD/l}
   XS = 0.12329 \text{ mg COD/l}
   XBH = 8.6614 \text{ mg COD/l}
   XBA = 0.6484 \text{ mg COD/l}
   XP = 3.7485 \text{ mg COD/l}
   SO = 1.3748 \text{ mg} - COD/1
   SNO = 9.1948 mg N/1
   SNH = 0.15845 mg N/1
   SND = 0.55943 \text{ mg N/l}
   XND = 0.0092428 \text{ mg N/l}
   SALK = 4.5646 \text{ mol } HCO3/m3
   TSS = 14.3255 \text{ mg } SS/1
   Flow rate = 20640.7791 \text{ m}3/d
   Temperature = 14.8581 degC
WWTP sludge disposal
******
   SI = 130.867 \text{ mg COD/l}
   SS = 258.5789 \text{ mg COD/l}
   XI = 314239.8855 \text{ mg COD/l}
   XS = 47666.1788 \text{ mg COD/l}
   XBH = 0 mg COD/1
   XBA = 0 mg COD/1
   XP = 11427.269 \text{ mg COD/l}
   SO = 0 mg - COD/1
   SNO = 0 mg N/1
   SNH = 1442.7882 mg N/1
   SND = 0.54323 \text{ mg N/l}
   XND = 1841.0745 \text{ mg N/l}
   SALK = 97.8459 \text{ mol } HCO3/m3
   TSS = 280000 \text{ mg } SS/1
   Flow rate = 9.5821 \text{ m}3/d
   Temperature = 14.8581 degC
Other variables
   Trad. sludge age (XS + XP + XI + XBH + XBA in reactors) = 17.8428
davs
   Spec. sludge age (XBH + XBA in reactors and settler) = 20.9128
davs
   Spec. sludge age 2 (XS + XP + XI + XBH + XBA in reactors and
settler) = 20.9391 days
   Primary clarifier hydraulic retention time = 1.0461 hours
   Hydraulic retention time in AS + settler = 20.9218 hours
   AS reactors hydraulic retention time = 13.9478 hours
   Anaerobic digester retention time = 19.0511 days
   Thickening factor at bottom of settler (TSSu/TSSfeed) = 1.9815
   Thinning factor at top of settler (TSSeff/TSSfeed) = 0.003863
```

# Dimensions \*\*\*\*\*\*

Primary clarifier volume = 900 m3 Reactor 1 is anoxic Volume reactor 1 = 1500 m3Reactor 2 is anoxic Volume reactor 2 = 1500 m3Reactor 3 is aerobic Volume reactor 3 = 3000 m3Reactor 4 is aerobic Volume reactor 4 = 3000 m3Reactor 5 is aerobic Volume reactor 5 = 3000 m3Settler height = 4 mSettler area = 1500 m2Settler volume = 6000 m3 Anaerobic digester volume (liquid) = 3400 m3 Anaerobic digester head space volume = 300 m3Total storage tank volume (10-90% used) = 160 m3