



McDOWELL & ASSOCIATES
Geotechnical, Environmental, & Hydrogeologic Services
21355 Hatcher Avenue • Ferndale, MI 48220
Phone: (248) 399-2066 • Fax: (248) 399-2157

LOG OF SOIL

BORING NO. 107

PROJECT

Soils Investigation
Pauline/ Maple Townhouses

JOB NO. 02-446

LOCATION

Maple Road and Pauline Boulevard

SURFACE ELEV. _____

DATE 10-2-02

Ann Arbor, Michigan

Sample & Type	Depth	Legend	SOIL DESCRIPTION	Penetration Blows for 6"	Moisture %	Natural Wt. P.C.F.	Dry Den Wt. P.C.F.	Unc. Comp. Strength PSF	Str. %
			0'3" Moist dark brown clayey TOPSOIL						
	1								
A	2		Very stiff moist variegated silty CLAY with trace of vegetation	8					
UL				10	9.8				
	3			14			*	(7000)	
	4		3'0"						
B									
UL	5		Extremely stiff moist brown silty CLAY	8					
				16	11.4				
	6			30			*	(9000+)	
			6'0"						
C	7			7					
UL			Extremely stiff moist brown silty CLAY with pebbles	13					
	8			22					
	9								
D				7					
UL	10		9'9" Extremely stiff moist blue CLAY with pebbles	13					
			10'0"	22					
	11								
	12								
	13								
	14								
	15								
	16								
	17								
	18								
	19								
	20								
	21								
	22								
	23								
	24								
	25								

TYPE OF SAMPLE
D. - DISTURBED
U.L. - UNDIST. LINER
S.T. - SHELBY TUBE
S.S. - SPLIT SPOON
R.C. - ROCK CORE
() - PENETROMETER

REMARKS:

*Calibrated penetrometer

Standard Penetration Test - Driving 2" OD Sampler 1' With
140# Hammer Falling 30": Count Made at 6" Intervals

GROUND WATER OBSERVATIONS

G.W. ENCOUNTERED AT FT. INS.
G.W. ENCOUNTERED AT FT. INS.
G.W. AFTER COMPLETION FT. INS.
G.W. AFTER HRS. FT. INS.
G.W. VOLUMES
None