

JOB NO. 08-096

LOCATION 1015 East Ann Street

SURFACE ELEV. _____ DATE 6-6-08

Ann Arbor, Michigan

Sample & Type	Depth	Legend	SOIL DESCRIPTION	Penetration Blows for 6"	Moisture %	Natural Wt. P.C.F.	Dry Den Wt. P.C.F.	Unc. Comp. Strength PSF.	Str. %
	1		0'1" ASPHALT						
			0'6" Milled ASPHALT						
A	2		1'6" Moist brown clayey SAND with pebbles, fill	4					
UL				4					
	3			7					
	4		Compact moist brown and discolored brown clayey SAND with gravel and layers of brown clay with brick, fill						
B	5			2					
UL				4	17.1	130		2030	
	6			5					
	7		6'6"						
C	8			2					
UL				2					
	9			4					
	10								
D	11		Medium compact moist to wet discolored brown clayey SAND with gravel, brick and brown clay layers, fill	5					
UL				3	24.7	--			
	12			2					
	13								
	14								
E	15			1					
UL				2	21.6	--			
	16			5					
	17								
	18								
	19		18'0"						
F	20		Extremely compact moist brown clayey SAND & GRAVEL	5					
UL				11	7.8	115			
	21			16					
	22		22'0"						
	23								
	24		Compact moist grayish brown silty SAND with gravel and seams of gravel and brown fine sand						
G	25			8					
UL				5	6.1	122			
				11					

TYPE OF SAMPLE

D. - DISTURBED
U.L. - UNDIST. LINER
S.T. - SHELBY TUBE
S.S. - SPLIT SPOON
R.C. - ROCK CORE
() - PENETROMETER

REMARKS:

Standard Penetration Test - Driving 2" OD Sampler 1' With
140# Hammer Falling 30": Count Made at 6" Intervals

GROUND WATER OBSERVATIONS

G.W. ENCOUNTERED AT
G.W. ENCOUNTERED AT
G.W. AFTER COMPLETION
G.W. AFTER
G.W. VOLUMES

6
30
Dry
HRS.
Light

6
0
FT.
FT.
FT.

INS.
INS.
INS.
INS.



McDOWELL & ASSOCIATES
Geotechnical, Environmental, & Hydrogeologic Services
21355 Hatcher Avenue • Ferndale, MI 48220
Phone: (248) 399-2066 • Fax: (248) 399-2157

LOG OF SOIL
BORING NO. 2 (continued)

PROJECT Soils Investigation-Retaining Wall Replacement

JOB NO. 08-096

LOCATION 1015 East Ann Street

SURFACE ELEV. _____ DATE 6-6-08

Ann Arbor, Michigan

Sample & Type	Depth	Legend	SOIL DESCRIPTION	Penetration Blows for 6"	Moisture %	Natural Wt. P.C.F.	Dry Den Wt. P.C.F.	Unc. Comp. Strength PSF.	Str. %
	26		Compact moist grayish brown silty SAND with gravel and seams of gravel and brown fine sand						
	27								
	28								
	29								
H				15					
UL	30		30'0" Very compact moist to wet brown gravelly 30'6" SAND with trace of silt	10	3.2	--			
	31			8					
	32		Note: Boring located in line with east side of building and 12' south of retaining wall.						
	33								
	34								
	35								
	36								
	37								
	38								
	39								
	40								
	41								
	42								
	43								
	44								
	45								
	46								
	47								
	48								
	49								
	50								

TYPE OF SAMPLE
D. - DISTURBED
U.L. - UNDIST. LINER
S.T. - SHELBY TUBE
S.S. - SPLIT SPOON
R.C. - ROCK CORE
() - PENETROMETER

REMARKS:

Standard Penetration Test - Driving 2" OD Sampler 1' With
140# Hammer Falling 30": Count Made at 6" Intervals

GROUND WATER OBSERVATIONS

G.W. ENCOUNTERED AT 6 FT. 6 INS.
G.W. ENCOUNTERED AT 30 FT. 0 INS.
G.W. AFTER COMPLETION Dry FT. INS.
G.W. AFTER HRS. FT. INS.
G.W. VOLUMES Light