



McDOWELL & ASSOCIATES
Geotechnical, Environmental, & Hydrogeologic Services
21355 Hatcher Avenue • Ferndale, MI 48220
Phone: (248) 399-2066 • Fax: (248) 399-2157

LOG OF SOIL
BORING NO. 23

PROJECT Proposed Tennis Courts
LOCATION Huron High School
Fuller Road and Huron Parkway

JOB NO. 08-019A

SURFACE ELEV. 788.0 DATE 3-03-08

Ann Arbor, Michigan

Sample & Type	Depth	Legend	SOIL DESCRIPTION	Penetration Blows for 6"	Moisture %	Natural Wt. P.C.F.	Dry Den Wt. P.C.F.	Unc. Comp. Strength PSF	Str. %
	1		0'2" Moist dark brown silty sandy TOPSOIL with vegetation, fill						
A	2			4					
UL	3			8	13.2	103			
	4		Compact to very compact moist brown clayey sandy SILT with moist brown silty fine to medium sand seams and brown silty clay layers, fill	10					
B	5			5					
UL	6			6	12.9	116			
	7			10					
C	8								
UL	9		6'6" Extremely compact moist brown SAND with gravel	21					
	10			23/3"					
D	11			--					
UL	12			40					
	13			46/3"					
	14								
	15								
	16								
	17								
	18								
	19								
	20								
	21								
	22		Coordinates: 5823.4 North 4041.6 East						
	23								
	24								
	25								
TYPE OF SAMPLE D. - DISTURBED UL. - UNDIST. LINER S.T. - SHELBY TUBE S.S. - SPLIT SPOON R.C. - ROCK CORE () - PENETROMETER			REMARKS: Standard Penetration Test - Driving 2" OD Sampler 1' With 140# Hammer Falling 30"; Count Made at 6" Intervals	GROUND WATER OBSERVATIONS G.W. ENCOUNTERED AT FT. INS. G.W. ENCOUNTERED AT FT. INS. G.W. AFTER COMPLETION none FT. INS. G.W. AFTER HRS. FT. INS. G.W. VOLUMES					