



McDOWELL & ASSOCIATES
Geotechnical, Environmental, & Hydrogeologic Services
21355 Hatcher Avenue • Ferndale, MI 48220
Phone: (248) 399-2066 • Fax: (248) 399-2157

LOG OF SOIL
BORING NO. H

PROJECT Soils Investigation
LOCATION Proposed Soccer Field
Huron High School
Fuller Road and Huron Parkway
Ann Arbor, Michigan

JOB NO. 08-019B

SURFACE ELEV. 763.3 DATE 3-06-08

Sample & Type	Depth	Legend	SOIL DESCRIPTION	Penetration Blows for 6"	Moisture %	Natural Wt. P.C.F.	Dry Den Wt. P.C.F.	Unc. Comp. Strength P.S.F.	Str. %
			0'5" Frozen dark brown silty sandy TOPSOIL						
	1								
A	2			26					
UL	3			28					
	4		Extremely compact frozen to moist brown medium to coarse SAND with gravel	--					
B	5			11					
UL	6		5'0"	17					
	7			--					
	8								
	9								
	10								
	11								
	12								
	13								
	14								
	15								
	16								
	17								
	18								
	19								
	20								
	21		Coordinates: 4901.2 North 4615.4 East						
	22								
	23								
	24								
	25								
TYPE OF SAMPLE D. - DISTURBED U.L. - UNDIST. LINER S.T. - SHELBY TUBE S.S. - SPLIT SPOON R.C. - ROCK CORE () - PENETROMETER			REMARKS: Standard Penetration Test - Driving 2" OD Sampler 1' With 140# Hammer Falling 30": Count Made at 6" Intervals	GROUND WATER OBSERVATIONS G.W. ENCOUNTERED AT FT. INS. G.W. ENCOUNTERED AT FT. INS. G.W. AFTER COMPLETION none FT. INS. G.W. AFTER HRS. FT. INS. G.W. VOLUMES					