

# A Survey on AMI Communication Technologies and Routing Protocols in the NAN domain

Diego F. Ramírez, Sandra Céspedes  
 Department of Information and Communications Technologies  
 Icesi University, Cali, Colombia  
 Email: {*dframirez,scespedes*}@icesi.edu.co

## Abstract

Smart Grid is defined as the modern infrastructure of the electric grid, whose objective is to improve efficiency, reliability, and security. This is achieved through the control automation of the transmission and distribution lines, the enhancement of consumption metering technologies, the implementation of new renewable energy sources and new energy management techniques. The growing demand of energy, changes in global weather, problems in the storing and distribution, and the need to implement more efficient consumption metering systems, are some of the factors that have led to transit towards a more complex and robust electric grid. A fundamental component of this new grid is an Advanced Metering Infrastructure (AMI), which provides a two-way communication flow between Utilities and meters and the customer side. In this paper we outline the main features of this new infrastructure, including communication technologies, topologies for deployment, and routing requirements in the Neighborhood Area Network (NAN) domain. For this purpose, we present the communication requirements for the AMI network (such as scalability, interoperability, latency, security, quality of service, among others), and a full analysis of different routing strategies and protocols within the AMI context.

## Index Terms

AMI, AODV, DADR, DSR, Geographical Routing, HAN, HWMP, Mesh Under, NAN, PLC, Route Over, routing, Smart Grid, WiFi

## I. INTRODUCTION

Smart Grid is defined as the modern infrastructure of the electric grid, whose objective is to improve efficiency, reliability, and security. This is achieved through the control automation of the transmission and distribution lines, the enhancement of consumption metering technologies, the implementation of new renewable energy sources, and the introduction of new energy management techniques [1]. The growing demand of energy, changes in global weather, problems in the storing and distribution, and the need to implement more efficient consumption metering systems, are some of the factors that have led to transit towards a more complex and robust electric grid. At the same time, the improvement in the response time to network faults, natural disasters, interference problems, and energetic resources loss, constitutes a strong reason to structure an electric grid with better energy transport, generation, and distribution technologies.

The electric grid transformation involves the integration of a bidirectional communication infrastructure. Regarding the distribution component of the electric grid, an advanced metering infrastructure (AMI), which results from the integration of advanced sensors, smart meters, monitoring systems, and energy management systems, has been a focus of interest for governments, utilities and academia. An initial implementation of the AMI involved the deployment of communication technologies to enable a two-way data flow for sending commands and information in real time to smart meters, as well as the reception of consumption information from the customer premises [2]. Nowadays, it has been identified that the exchange of information between AMI devices will not be related exclusively to client's consumption, or the sending of control commands to smart meters. The list of applications is expanding to real time pricing, outage management, emergency response, in-home displays, among others [3]. Therefore, it is critical for the utilities to define the communications requirements and the more suitable technologies for implementing the bidirectional communication system.

In this paper, we first identify the set of design factors that need to be considered in order to support the aforementioned applications in the AMI network. Since both wired and wireless technologies have been proposed for communications in the AMI, we survey the different communications technologies that have been proposed, with a focus on the network segment that connects the smart meters and data collectors, i.e., the Neighborhood Area Networks (NAN). Additional to communications technologies, we also survey and provide a detailed description of the different routing protocols proposed for the NAN domain. The protocols are compared based on a set of metrics and the performance results reported in the literature. In our survey, we consider the fact that the chosen technology and routing protocol should adapt well to the kind of traffic that will be transmitted. Furthermore, the choice will be subject to other factors, such as the deployment time, the type of environment (rural/urban), and the operational costs of deployment and maintenance.

The remainder of this paper is organized as follows. In Section II-A, we describe the AMI network, its evolution regarding the AMI deployments reported around the world, and the design factors to consider at the time of deployment. In Section III, we classify the communications technologies according to the network segment they fit better, and identify their advantages and disadvantages. Next, in Section IV we provide the descriptions for the routing protocols proposed for the NAN domain, followed by Section V with a qualitative comparison among the routing protocols. The open networking issues are described in Section VI. Finally, concluding remarks are provided in Section VII.

## II. ADVANCED METERING INFRASTRUCTURE

Smart grid communications comprise three types of networks: Home Area Networks (HAN), which serve as the communication infrastructure for sensors and devices inside homes; Neighborhood Area Networks (NAN), which connect smart meters and data collectors; and a Wide Area Network (WAN), which communicates data collectors with a utility control center [4]. The Advanced Metering Infrastructure (AMI) refers to the architecture that provides a two-way communication between the Utility and the Home Area Networks (HANs). It includes smart meters, a Meter Data Management System (MDMS), a communication network, access points, and a head-end [5] [6]. An example of a typical AMI deployment is depicted in Fig. 1.

The main purpose of the AMI is to measure, gather, and analyze energy consumption as well as patterns of energy use. The AMI must support traffic generated at a variety of sources (meters, data collectors, and Utility). Therefore, the AMI network must fulfill the needs of different natures of traffic while it




Fig. 1. Basic AMI deployment

may face constraints such as limited bandwidth and interaction with low-capacity devices (in terms of memory, processing capacity, and others).

While many utility companies started deploying AMI networks based on proprietary protocols, it is expected for the AMI communications architecture to be IP-based to guarantee interoperability with standard applications. As discussed by Yan *et al.* [7], an IP-based network will provide an effective solution for the communication needs of the smart grid, as it becomes a non-technology dependant deployment. Thus, the cost of implementation and maintenance can be reduced significantly using an IP-based approach. The main requirements for the IP-based communications network deployed in the AMI are as follows [5] [8]:

- **Interoperability:** The IP suite and protocols should be standards-based with the purpose of enabling the communication between segments using different technologies and networking protocols, as well as providing end-to-end services.
- **Scalability:** Supporting large and dense deployments is a must in the AMI network.
- **Security:** Smart meters transmit sensitive information on a regular basis; hence, the network must provide security for data transfer. Security services must cover different types of traffic and be provided at both network and application layers [6]. Real time information, for instance neighbors' energy consumption habits, become data that must be protected since third-party visibility of this information would constitute an invasion of privacy.
- **Reliability:** It refers to the ability of the system to avoid, detect and repair eventual network faults. This involves avoiding data corruption, isolating faults in case of uncorrectable errors and eventually reporting them to recovery mechanisms.
- **Quality of Service:** It refers to the ability of a system to provide different priority levels to different applications and types of traffic, so a certain level of performance of a data flow can be guaranteed.

An important aspect of the AMI's network operation is the routing of packets. The implementation of efficient routing strategies becomes paramount to guarantee that the information reaches its final destination. Therefore, routing protocols should be designed according to the aforementioned requirements. Furthermore, routing should be more or less robust, depending on the type of communication technology over which the AMI is deployed. In this article, we compare and discuss the routing strategies and protocols that have been adopted in the communications backbone of the AMI context.

### *A. Overview of global deployment status of AMI*

The Advanced Metering and Demand Response Survey performed by FERC [9] indicates that, in the U.S., the AMI penetration together with potential peak load reductions from electric power demand response have increased significantly since the last survey in 2008. The growth is around four percentage points (from 4.7% in 2008 to 8.7% in 2010). The study also shows that the Upper Midwest, West, and Texas have advanced metering penetration exceeding 13%.

But not only the U.S shows a significant increase in AMI deployments. The European Union (EU) has set a target of 80% smart meter deployment by 2020. However, there are still many questions to answer regarding demand response, off-peak usage, and planning for the deployment and support of electric vehicles. The main motivation in Europe for installing AMI appears to be limited to the operational efficiency of the Automatic Meter Reading (AMR) systems. However, due to the diversity of EU members and country-specific goals, the definition of a common AMI deployment methodology is a challenging task. Regarding the penetration of advanced metering approaches in Europe, countries such as Italy and Sweden have a near 100% AMI implementation, but a large percentage of these deployments only have unidirectional communication capabilities (for AMR purposes). Functionalities such as demand response and load-shifting applications are restricted to larger customers [9].

In Canada, the largest AMI project in the region, called Hydro-Quebec, considers the deployment of four million smart meters. This is expected to be completed by 2017. As for Asia, China is on the way to expand their energy metering infrastructure by promoting projects aimed at providing a two-way communication architecture between utilities and final consumers. Similarly, in Latin America, Brazil leads the AMI initiative by considering projects that contribute to the implementation of a more automated metering approach, in the pursuit of investment recovery [10].

### *B. Design Factors of the AMI Network*

Due to the evolution of the electrical grid, specifically electricity metering, a two-way communication network has been required. Applications such as smart metering, demand response (DR) and remote disconnect/reconnect require a communication network that supports them, as well as future application that will become prevalent, such as the sending of information about real time pricing from the Utility to the consumers homes or electric vehicles charging stations. Aspects regarding the choice of technology in which the AMI will be deployed, the constraints of the routing protocols, and the system capacity limits are some of the issues to be solved through a proper network planning. This plan requires the use of best practice guidelines for the design and deployment of the AMI. The main factors to consider when designing AMI networks are outlined as follows [11] :

- Understanding the networking needs and goals of the Utility
- Identifying the main design constraints of the AMI vendor's equipment (in terms of hardware and software capacity).
- Considering the compatibility with AMI communication protocols
- Planning production costs
- Design of network topology, considering adaptability with wireless and wired communications
- Identifying the need for pilot installation, field testing, and site infrastructure exploration
- Developing a plan for deployment, testing, and post-design adjustments

Given that each Utility has different needs and expectations on the behavior of the AMI network, and considering the varying constraints on performance requirements, a fully understanding of these operation needs must be taken into account when designing the AMI. The design of the AMI Network should then consider all the factors described above, as they will define the approach to meet the Utility's expectations.

In relation to the selection of vendors' equipment, the creation of link budgets for the various types of devices that will be used in the network deployment is the first step. In this process, issues such as calculation of hopping limits, battery capacity limits and transmission power must be considered [11]. Also, computer-aided design tools may be required for simulation, dimensioning and placement of infrastructure equipment purposes. Through this kind of tools, the model of the network is created and then the planning of the whole systems architecture can be deployed in the service area destined for that aim.

Another integral part in the design process is setting up a pilot system. In [11] a set-up of test transmitters in multiple locations within the service area is recommended. Execution of field measurements by testing the link configurations such as collector-to-meter, collector-to-repeater, and meter-to-meter is also proposed, in order to get a general view of the system performance.

### III. COMMUNICATION TECHNOLOGIES IN AMI

In this section, we address the communication technologies suitable for AMI deployments. Although we introduce technologies related to the other domains in the smart grid (HAN and WAN), we devote a more detailed analysis for technologies in the NAN domain.

#### A. HAN domain

1) *802.15.4-based technologies*: The IEEE 802.15.4 standard specifies the physical and medium access control layers for Low Rate-Wireless Personal Area Networks (LR-WPAN). The physical layer is divided in two layers: PHY data service and PHY management. The main function of the physical layer is to transmit and receive messages through the radio medium. MAC layer provides two main services: MAC data service and MAC management service. Both of them allow the transmission and reception of frames through the PHY data service. Functions such as channel switching, energy detection measurement, clear channel assessment, security functions (AES encryption) and quality of service through guaranteed time slots are some of other features of this standard. Other technical characteristics of the 802.15.4 standard are listed below:

- Frequency bands: 868 MHz/915 MHz and 2.4GHz
- Raw data rates: 868 MHz: 20kbps; 915 MHz: 40 kbps; 2.4GHz: 250 kbps
- Channels: 11 in the 868/915 MHz ; 16 in the 2.4 GHz
- Range: 10-20 m
- Latency: Down to 15ms
- Addressing: Short 8 bit or 64bit IEEE
- Channel access: CSMA-CA and slotted CSMA-CA
- Modulation technique: DSSS (Direct Sequence Spread Spectrum)

One of the most well-known 802.15.4-based technologies is ZigBee [12]. It is a wireless communications technology considered ideal for real time monitoring of multiple targets, due to its low power

consumption, low deployment cost, self-organization and self-configuration characteristics. As a result, ZigBee is especially useful in the HAN domain [13]. Many AMI operators prefer smart meters on which the ZigBee protocol can be integrated, embracing the recommendation of the National Institute for Standards and Technology (NIST). Two different ZigBee specifications are available: *i)* the one based on the RF4CE Specification, which is designed for running in low-power and resource-constrained devices, mostly for control applications. It employs specially-developed protocols for network and transport layers; and *ii)* the IP-based version, named ZigBee IP, which provides mesh networking and IPv6 connectivity, enabling Internet access from ZigBee devices. The PHY and MAC layers of both specifications are based on the IEEE 802.15.4 standard.

WirelessHART is another technology based on 802.15.4. This technology, however, defines Data Link, Network, and Transport layers for deploying real-time industrial control applications [14]. It has become very popular in the electric sector. In the link access, WirelessHART defines a 10ms time-slot for guaranteed link access. In the upper layers, it designates a centralized network manager in charge of maintaining updated routes. It also employs mesh-networking with self-healing and self-organizing characteristics.

There is also the possibility of employing standard Internet protocols directly over the 802.15.4 technology. 6LoWPAN, a standard defined by the IETF, builds an adaptation layer between MAC layer and network layer to enable the transmission of IPv6 packets over IEEE 802.15.4 [15]. It describes the way packets of large sizes (i.e., IPv6 packets) can be transported through a wireless link that only accepts packets of a maximum 127 bytes size. For this purpose, header compression and fragmentation of IPv6 packets is performed, and mesh forwarding is also allowed for the delivery of packets from source to destination over multihop scenarios. Therefore, wireless embedded Internet access is enabled on any device, which provides an option for communications in HAN environments.

Among the advantages of technologies based on the 802.15.4 standard we can mention simplicity, robustness, low bandwidth requirements, low deployment cost, easy implementation, and the fact that they operate over a non-licensed spectrum band. They also allow for mobility of devices. Regarding the drawbacks, one could mention the interference caused by other devices using the same transmission media, and the fact that technologies based on the 802.15.4 standard suffer from the scope expansion of sensor networks, the reason why these kind of technologies are only appropriate for small-scale networks deployments [16].

2) *802.11 and WiFi*: IEEE 802.11 standard [17] specifies PHY and MAC layers for WiFi. It operates in the ISM 2.4 GHz. The IEEE 802.11b version of the standard is the one that has been widely adopted for WiFi. Main technical specifications of this standard are as follows:

- Frequency bands: 2.4GHz
- Maximum data rate: 11 Mbps
- Channels: 13 overlapping 22 MHz wide frequency channels
- Range: 100 ft at 11 Mbps; 300 ft at 1 Mbps
- Channel access: CSMA-CA
- Modulation technique: DSSS)

As WiFi is a very mature technology (it's estimated that more than 100 million households worldwide have a WiFi installation for home networking) [18], it becomes a suitable communication technology inside the HAN through which devices at home send information to the smart meter. WiFi becomes a very

scalable technology, providing extensive radio performance and network management mechanisms to provide records of radio quality, history reports and channel selection optimization. Regarding technical specifications, WiFi offers data rates from 1 Mbps (at 802.11b) to 600 Mbps (at 802.11n), and support multichannels in the 2.4GHz and 5 GHz ISM bands.

WiFi operates in unlicensed spectrum, so it's resilient to many types of interference but can coexist with other technologies that share this bands (it provides mechanisms to deliver robust performance in shared-spectrum and noisy RF environments [18]). Other advantages of this technology include the fact that it enables IP-based applications, as it transports all IPv4 and IPv6-based protocols, the fact that many vendors implement the technology in a wide range of devices and enhancements in power management. As for the drawbacks, one could mention a higher power consumption (when compared with other HAN technologies such as ZigBee).

3) *Ethernet*: It is a very popular communication technology standard primarily used within the HAN, but can also be used on the NAN. A variety of speeds can be achieved, including 10Mbps, 100Mbps, 1000Mbps and 10000Mbps. Main advantages and drawbacks are the following:

Advantages: Being standard-based, set up and configuration are easier.

Drawbacks: This technology may not be appropriate for connecting all devices in the HAN, due to the high cost and power requirements plus the need for separate cabling back to a central point.

## *B. NAN domain*

1) *IEEE. 802.15.4g*: This is an amendment to the 802.15.4 standard whose objective is to facilitate very large scale process control applications such as the ones found in Smart Utility Networks. It is capable of supporting large and geographically diverse networks with minimal infrastructure and millions of fixed endpoints. The standard features an alternate PHY and the MAC modifications needed to support its implementation. The ammendment features the following [19]:

- Frequency bands: 700 MHz to 1GHz and the 2.4 GHz band.
- Frame Sizes: up to a minimun of 1500 octets
- It addresses SG geographic requirements by defining appropriate power levels
- It increases data rates formally to hundreds of kbps, and even Mbps, thus broadening the applicability of mesh systems beyond AMR and AMI to support the full sweep of smart grid applications.
- The standard defines technologies supporting up to 1 Mbps
- It establishes a global standard by explicitly including unlicensed and region-specific frequency ranges, or spectrum bands
- It supports for Frequency Hopping Spread Spectrum (FHSS) transmission techniques.

It is natural that technologies based on the 802.15.4 standard (see Section III-A1) evolve to support the 802.15.4g technology, in order to provide communications for NAN environments. Such is the case for ZigBee, whose participation in standardization activities for smart grid NANs has been announced in early 2014. As for the advantages of the adoption of this standard, it provides backward compatibility built into the standard; thus, utilities' hardware can be integrated with no changes, so their investment in the technology is protected. IEEE 802.15.4g addresses reliability in outdoor environments, interference resiliency, and support of high density operation by FHSS techniques. The latter represents a vast improvement over historical not so reliable wireless technologies.

A summary of the technologies used in the HAN domain is depicted in (Fig. 2).

<b>Technology</b>	<b>Data Rate (mbps)</b>	<b>Range (m)</b>	<b>Security Level</b>	<b>Cost of deployment</b>
<b>ZigBee</b>	0.02 - 025	10-20	Low	Low
<b>802.11</b>	Up to 11	10-100	Low	Medium
<b>WiFi</b>	5-100	30-100	Low	Medium
<b>Ethernet</b>	10-100	Up to 100	High	High

Fig. 2. Main technologies used in the HAN Domain

2) *802.11s*: The IEEE 802.11s standard envisions a small-to medium- scale WLAN mesh network configured with a maximum of 32 mesh nodes (called Mesh Points MPs). An amendment to the standard has been made with the aim of developing a more flexible and extensible standard for wireless mesh networks based on IEEE 802.11. One of the most important functionalities of the new IEEE 802.11s is the multi-hop routing, which sets up the paths for the wireless forwarding. Mesh capabilities are provided to the mesh points, so they are able to participate in the forwarding process. Regarding the changes in this standard when compared with IEEE 802.11, the amendment is performed only in the MAC layer (modifications to PHY layer are not required) [20].

3) *Power Line Communication (PLC)*: PLC is a technology that uses the existing electric grid to transmit data. PLC becomes a well suited alternative as it is a no-cost medium for the Utility and is spread along the distribution system. Thus, PLC is a natural solution for the communication between the Utility and the Smart Meters. By reusing the electric grid as communication media, the implementation investment is low. In a typical PLC network, the smart meters are connected to the data center through power lines. The main technical specifications of this technology are stated below.

Two main types of communication architectures based on PLC have been defined: NarrowBand PLC (NBPLC) and Broadband PLC (BPLC). The first type allows data transmission at lower rates than those provided by BPLC (from few dozens of kbps to 100 Mbps, respectively) [13]. NBPLC systems generally use the CENELEC (Comit European de Normalisation Electrotechnique) bands (3-148.5 kHz). NBPLC generally operates in transmission frequencies of up to 500 kHz, as opposed to BPLC, which targets much higher bandwidth at shorter distances and operates over a much higher frequency band. Frequencies of 148.5 kHz and less have been recognized by CENELEC standards for use in NBPLC systems on a public utility's power wires. Regarding the BPLC, the operation bands go from 1.8 MHz up to 250 MHz. Some examples of NBPLC technologies are described in IEEE 1901 and ITU-T G-hn (G.9960/G.9961) recommendations. NBPLC generally refers to PLC systems supporting data rates over 1 Mbps.

The main advantage of PLC is associated to the low implementation costs. Additionally, the coverage provided by PLC is exactly the one intended by the Utility. As it uses the power feeder, PLC behaves as an enabler for sensing, control, and automation in large systems comprising tens or even hundreds of components spread over relatively wide areas, which contributes to provide scalability. Furthermore, as the power lines are owned by the Utility, there is more independence in relation to sending information through third-party networks or operators. Nonetheless, the very nature of PLC's physical transmission



media generates some challenges. It is highly susceptible to signal degradation due to the harsh power lines. The technology is also limited by its low bandwidth, which is why it may not be suitable for more robust applications where large amounts of data need to be transferred. Besides the fact that feeder cables are not designed for data transmission, they are also prone to be interfered by the inverters outcome.

A summary of the technologies used in the NAN domain is depicted in (Fig. 3).

<b>Technology</b>	<b>Máximum Data Range (mbps)</b>	<b>Range (m)</b>	<b>Security Level</b>	<b>Cost of deployment</b>
<b>PLC</b>	100	100	High	Medium
<b>WiFi</b>	54	100-200	Low	Medium
<b>802.15.4g</b>	1	10-100	Medium	Medium
<b>DSL</b>	3	10-100	High	Low

Fig. 3. Main technologies used in the NAN Domain

4) *Digital Subscriber Lines (DSL)*: DSL is a high speed digital data transmission technology, which employs the wires of the voice telephone network for data transmission. As with PLC, this technology may be a suitable candidate for the implementation of network segments within the AMI, as it reuses the existing infrastructure, thus reducing installation cost of an implementation from scratch. As for the technical specifications, the network performance and perceived throughput will depend on how far away the subscriber is from the serving telephone [1]. Main technical details, advantages and drawbacks of this technology are listed below:

Technical specifications: Commonly, the frequencies on which this technology works are greater than 1MHz through an ADSL enabled telephone line.

As for the advantages of this technology, one could mention that given a high data transmission rate and the low installation costs for the network deployment, DSL is a good option for the AMI implementation. Regarding the drawbacks, distance dependency is the primary constraint of this technology.

### C. WAN domain

1) *Cellular Networks*: Cellular Networks became a popular technology for the communication between meters and the Utility, as a solution for Automatic Meter Reading systems. By employing short messaging services (SMS) or data plans through a cellular operator, the AMR system is supported over existing infrastructure, thus avoiding incurring in additional installation and deployment costs from the Utility's viewpoint. Furthermore, this technology is also suitable for communicating collectors to the central data center at the Utility's premises. Some of the cellular technologies employed for the long-haul communication are: 2G, 2.5G, 3G, and LTE. The latter has a high-capacity of bandwidth and, consequently, can also support several QoS requirements.

Among the advantages of employing this technology we can mention that by outsourcing the communications network to a mobile operator, utilities can significantly reduce operative costs, as they do not

have to bear the cost of deploying and maintaining the infrastructure. Data rates for cellular technologies in AMI projects are now much more competitive. Furthermore, coverage provided by cellular networks is another outstanding advantage, which helps to improve network capabilities. On the contrary, among the drawbacks identified are those associated to information security. As the physical medium used for transmission is susceptible to interceptions, sensitive information (such as contractual data or bills) must be protected, to guarantee that it reaches its intended recipient with no understanding by other individuals or devices attempting to intercept it. In addition, given that the communication channel is shared with mobile telephony users, the network performance may be impaired at certain times or places. Moreover, transmission through cellular networks still has a high cost, especially when SMS is used as communication media between smart meters and data collectors.

2) *WiMAX*: Wimax (Worldwide Interoperability for Microwave Access) is a wireless broadband technology based on the standard IEEE 802.16 [21]. One of the main characteristics of Wimax is that its adaptive modulation and coding scheme allows the whole network to adjust signal modulation or coding depending on how noisy the link is. This is why the technology provides high data rates, as the modulation increases when signal to noise ratio is also increasing. Some technical specifications of the technology are [22]:

- Data rates: up to 70 Mbps
- Not protocol-dependent
- Low latency:  $\leq 100$  ms round trip
- It supports QoS, policy and traffic management
- It provides secure communication and provides 128 -bit Advanced Encryption Standard (AES)

Regarding the advantages of Wimax as technology enabling communications in the NAN domain, one could focus mainly in the fact that it provides a balance between deployment cost, complexity, flexibility, and control. Being based on a flat architecture, the technology is flexible and scalable. On the other hand, it can use a wide range of frequencies and this gives Utilities the possibility to deploy a wide range of applications with different bandwidth requirements and priority levels [23]. As for the drawbacks, while Wimax provides a solution with a large communication range and high data rates, it tends to be costlier due to the greater licensing and subscription fees.

#### IV. ROUTING FOR NEIGHBORHOOD AREA NETWORKS IN AMI

The Advanced Metering Infrastructure (AMI) is expected to be deployed on networks with a dense number of nodes (meters) that connect to numerous data collectors. Furthermore, the AMI network should provide efficient and suitable routing functionalities, which guarantee a reliable and effective delivery of information. Regarding the traffic involved in the two-way communication channel, different types of traffic can be identified: 1) traffic consisting of data containing the meter-reading, going from homes to Utilities data collectors, 2) traffic consisting of data containing data going from collectors to substation or the Utility itself, and 3) traffic consisting of data from applications in the Smart Grid. Some of these applications are [24]: lighting control, heating, ventilation, detection of fluctuations and power outages, switchin on and off (remote control of the meter from customer side), demand response and vehicle charging.

Considering the the importance behind the implementation of efficient routing strategies and protocols lies in the need of an effective data packet delivery mechanism, we focuse on the routing for the NAN

domain the AMI architecture. As it is required that information from data collectors can be successfully received by the Utility, through the bidirectional communication channel outlined under the AMI concept, and conversely information from Utility must reach data collector and meters at the customer side, we analyse several routing protocols that have been proposed for the NAN domain. In [13] several routing protocols have been classified and evaluated according to a certain set of metrics that will further be explained.

#### A. RPL

In an AMI network, the routing protocol must guarantee low energy consumption, assure privacy and information security, as well as support self-organization and self-configuration features. For this purpose, the IETF has proposed the Routing Protocol for Low Power and Lossy Networks [25]. This protocol is of the distance-vector type, and is based on IPv6. It was designed considering the requirements specified in RFC 5826 [26], RFC 5673 [27], RFC 5548 [28] and RFC 5867 [29]. Some of these requirements include: i) Scalability, which refers to the capability of supporting the organization of a large number of nodes into areas of configurable size; ii) Dinamicity, which makes reference to the capability of the routing protocol to support updating mechanisms in order to be informed of changes of connectivity, facilitating reorganization and self-healing features; iii) Latency, which refers to how long it takes for a packet to get from source to destination throughout the network; and iv) ParameterConstrained Routing, which has to do with identifying node capabilities that will be used by the routing protocol for forwarding decision (e.g. CPU, memory size, battery level, etc.).

One of the main advantages of this protocol is that it does not define a unique routing metric, but gathers a set of metrics. This is a must in the AMI network, given its heterogeneous and diverse traffic natures. Multiple devices involved in the AMI, as well as the different types of applications uploaded to the network, entails a need to define several types of metrics to ensure the protocol efficiency. An objective function (OF) is defined for the purpose of combining a set of metrics. The main idea behind RPL is to maintain information about the network status using one or more directed acyclic graphs (DAGs). A DAG is a directed graph in which all edges are oriented in such a way that no cycles exist. For each DAG created in RPL there is a root. The DAGs root is typically the gateway in the AMI network. All edges in the DAG are contained in the routes oriented to the root node. Each node in the DAG is associated to a rank. For the construction of the DAG, the gateway creates control messages called DIOS (DAG Information Object). The main functions executed by the DIO messages are listed below [8]:

- To identify the DAG from which any root is originated
- To spread the Rank information of the starting node
- To define the objective function (OF) that specifies the metric, or the combination of metrics, used to compute the rank in each node.

Once multiple DIO messages have been received, a node computes its own rank and determines its position in the DAG. One way to compute the rank is utilizing the Expected Transmission Count (ETX) as a metric. ETX measures the quality of a route between two nodes, by estimating the average number of required transmissions to send data packets to a neighbor. Since nodes in a network are susceptible to multiples faults, RPL builds a Destination Oriented DAG (DODAG) with several routes from each node. This contributes to enhance the performance and robustness of the network, as well as to guarantee quality of service and to handle traffic in real time [30].

A detailed implementation of RPL for AMI networks is presented in [31]. The authors considered a static multi-hop wireless AMI network that consists of  $n$  meter nodes and one gateway node. In the proposed protocol, a DAG structure is maintained at the gateway node. Once the information that must be stored and maintained by each node is defined, the data traffic forwarding rules are introduced. The authors also provide a detailed characterization for the DAG construction and maintenance, and propose a reverse path recording mechanism in order to enable routing support for outward unicast traffic, which flows from the gateway to each meter. The practical implementation of RPL presented by Wang *et al.* aims at providing reliable and low-latency routing support for large-scale AMI networks, through the integration with CSMA-based MAC layer protocols.

### B. Geographic routing

Geographic routing considers packet forwarding by means of position information instead of network addresses and routing tables. The destination location is employed to route packets. Through the knowledge of neighbors' locations, each node selects the next hop that is closer to the destination. Regarding the determination of every node's position, GPS devices are the main tool for making position information available. In order to enable the node's awareness of its neighbors' positions, it is required the broadcasting of the position information to other nodes. To determine the position of the destination, a location service that maps network addresses to geographic locations is needed.

One of the main advantages of this routing protocol is that routing tables maintenance and route discovery are unnecessary tasks, as the packet forwarding function is only based on geographic information. Three assumptions are required for geographic routing to be performed: i) a node can determine its own position; ii) a node is aware of its neighbors' positions; and iii) the position of the destination is known [32]. Among the drawbacks of this protocol, we can mention that GPS devices are costly. In addition, if hard coding of location is employed, the geographic coordinates cannot be changed. This may result in a lack of flexibility when a smart meter is relocated in the premises of a different customer. In general terms, the determination of geographical location is a challenging task [13].

A performance analysis of geographical routing in AMI networks through a simulation set up is presented in [8]. The routing protocol has been widely used in smart utility networks and AMI deployments, currently running in over 2 million metering end-points. For analysis purposes, a 100-node network obtained from a rural real AMI deployment was set up. Several data was collected, such as the ratio of total transmitted packets to received packets per node, the packet success probability, and the latency.

### C. AODV

Ad Hoc On-Demand Vector routing protocol builds on the Destination-Sequenced Distance- Vector (DSDV) protocol and is based on the RFC 3561 [33]. In this protocol, routes are created on demand, by minimizing the number of broadcasts (which, unlike DSDV, does not maintain a list of available routes). For this reason, AODV is often called a 'pure on-demand' routing acquisition system because only the nodes on the selected path are involved in the routing process. When a source node wants to communicate with a node but it does not have a valid route to reach it, the source node then initiates a path discovery process to discover the other node. To achieve this, source node broadcasts Route Request (RREQ) packet to its neighbors. This request is in turn sent to its neighbors and so on until either the

destination route or an intermediate node route to the destination is traced. This protocol uses hop count as routing metric.

In [34], a test-bed implementation of AODV in an AMI small-scale scenario is presented. In the simulation, the nodes were placed at distances such that the transmitted signal was only received by the neighboring nodes. As the number of hops increased, the throughput decreased, which is evident due to the routing overhead increment. Regarding the scalability of AODV, it was tested in a large scale string scenario, showing an inverse relationship between the throughput and the number of nodes. A modification to the protocol was proposed in [34], where selected nodes are provided with more intelligence, contributing to lower latency than regular AODV, and making it a useful communication protocol for current and future AMI applications. Among these application we can cite [34]: demand response, remote control of meters (switching on and off of eletrical devices), detection of power outages and electric vehicle charging.

#### *D. DSR*

Dynamic Source Routing protocol is an on-demand routing protocol and is based on the concept of source routing. It is based on the RFC 4728 [35]. In this protocol, a node maintains a route cache which contains source routes that are known by all other nodes. The route cache is continually updated as new routes to the source are learnt by the nodes. This protocol maintains two major phases: Route discovery and Route maintenance. Whenever a node has to send a packet to some destination, it initially checks the route cache to find out whether the route to the destination is already known. On the one hand, if the route to the destination is already present in the route cache, it uses the same route to transmit the packet. On the other hand, if the route to destination is not present in the route cache, then the node initiates route discovery by broadcasting a route request packet. This route request packet contains a destination address, a source node address, and a unique identification number. Each and every node checks if it has the destination route to the address sent in the route request packet. If the node does not find the destination route in its route cache, it adds its own address to the route record packet and forwards the packet to the nodes among its outgoing links. A route reply is generated only when the route request packet reaches the destination or an intermediate node has the route to the destination in its route cache.

If the route reply is generated by the destination, then the destination places the route record contained in the route request into the route reply. If the route request is responded by an intermediate node, then it will append its cache route to the route record to generate the route reply. The responding node must have a route to the initiator in order to send the route reply. If the responding node has the route to the initiator in its route cache, then it should use that route. Otherwise, if symmetric link is supported, then the node must send the route reply by using the reverse route in the route record. An overview of the operation of DSR is provided in (Fig. 4)

In [36] an evaluation of DSR together with AODV in a grid based cluster network is performed. For this purpose, Qualnet 5.0.2 simulator was used to excecute the performance analysis. A total of 33 nodes are deployed in an area of 1500m x 1500m. The evaluation considered the following performance metrics: i) energy consumed in transmission mode; ii) energy consumed in received mode; iii) energy consumed in idle mode; and iv) residual battery capacity (remaining battery after simulation). Regarding the first three metrics, AODV shows a better consumption of energy that DSR (0.1 mWh vs. 0.3 mWh in the transmission mode, 0.1 mWh vs 0.3 mWh in the received mode, and 1 mWh vs. 2.5 mWh in the idle mode). The residual battery capacity shows similar values for both protocos (around 99.7 mAhr).




Fig. 4. Dynamic Source Routing. A) Route Discovery B) Route Maintenance

### E. DADR

Distributed Autonomous Depth-First Routing (DADR) [37] is a proactive distance vector protocol that uses a control mechanism to provide at most  $k$  (if available) paths for each destination. It also utilizes Depth First Search algorithm for path recovery in cases of link failures [38]. As the data forwarding occurs, all the information learned is used to update the routing table. This happens during periodic Hello Messages exchanged among neighboring nodes, or when the nodes receive a route poisoning message. In order to control and detect loops, a unique FID (Frame ID) is added to a packet. Each time a node forwards a packet, its FID is stored, together with the packet's sender and the packet's next hop. The FID is useful for loop detection, so that when a loop is detected, a poisoning message is generated and the other nodes in the topology are informed about the situation.

A simulation scenario of more than two thousand smart meters is presented in [39]. The authors present an analysis of the routing protocol while it is tested in a 1500-node network topology. As for adaptability, the protocol shows the capability of learning new routes in both indoor and outdoor environments. In addition, the protocol demonstrated it does not need too much control overhead when updating routes, which is an advantage in a large-scale network. The study also shows that packet latency in a flat mesh network is affected by the several hops that data packets need to traverse in order to reach the destination.

### F. HYDRO

Hybrid Routing Protocol [40] is a link state routing protocol for Low Power and Lossy Networks. It uses DAGs to provide multiple reliable paths to a border router. To this end, each node builds its default route table by adding its neighboring nodes toward a border router. The entries in the route table will be ordered following an ETX metric. According to the top ranked entries of its default table, each node periodically creates a topology report. The nodes piggyback the topology reports on periodic collection traffic, allowing border routers to build and maintain a global view of the topology. The first primitive of HYDRO is the provision of a Default Route Table, which is made of a list of entries (each containing the link-layer address of a node in the direction of a border router). Thus, each node has

information about the link-layer packet success rates, so an evaluation of the quality of that link can be performed. This feature is especially important to fulfill the reliability, as multiple routes are provided to a given destination. HYDRO is considered both a centralized and distributed forward mechanism: on the one hand, the low-power nodes maintain a distributed DAG that provides the set of default routes for communicating with border routers; on the other hand, the border routers maintain a global view of the network topology, through the reports sent by each node.

In [40], a performance evaluation of HYDRO with different metrics is presented. It involves the implementation of a set of testbeds and a real network deployment. In the latter, a 57-node network was run for six months, with HYDRO as the routing protocol. The offered load consisted of each node transmitting a packet to an external server every minute. The statistics collected showed that the PDR is an average 98.9%. As for the scalability, every node's state is bound by the number of destinations it communicates with.

### G. HWMP

The Hybrid Wireless Mesh Protocol (HWMP) is the multihop default routing protocol for IEEE 802.11s WLAN mesh networking. With the purpose of allowing interoperability between devices from different vendors, HWMP serves as a common path selection protocol for every IEEE 802.11s-compliant device. The term hybrid is due to the use of both reactive and proactive approaches in the routing scheme. HWMP results from an adaptation of AODV called Radio-Metric AODV (RM-AODV), which, unlike AODV, works on layer 2 and uses a radio-aware routing metric.

When a node needs a path to a given destination, it broadcasts a route request message requesting a route to that destination [20]. This route request message is processed and forwarded by all mesh points to the originator of the route discovery. The destination node, or an intermediate node that owns a path to the destination, answers with a unicast reply message indicating the route requested. After this, the forward path to the destination is set up.

Considering the diverse nature of applications that generate traffic throughout the network, and given that applying a same retransmission mechanism for all packets may reduce the network throughput [41], a new method of selective retransmission has been proposed. Jung *et al.* [42] considered the use of HWMP in a smart grid deployment, utilizing the air cost (failure rate of each node calculated by MAC retransmission count of each packet) as a performance metric. The new method gives more priority to retransmission of small packets, as they are likely to have fewer bit errors. As a consequence, the protocol becomes more adapted for the NAN domain and the applications that are part of that architecture.

## V. COMPARISON OF ROUTING PROTOCOLS IN AMI NETWORKS

The communication infrastructure in AMI involves an important exchange of information, which is the foundation for the location-distributed electric power devices to work in a coordinated manner. Unsatisfactory communication performance not only limits the AMI from achieving its full energy efficiency and service quality, but also poses potential damages to the grid system. To protect the AMI and ensure optimal operation, the communication infrastructure must meet a number of requirements.

In this section we compare, based on a set of selected metrics, the routing protocols for NAN environments in AMI networks introduced in Section IV. We employ the description of operation, as

well as the performance results reported in the literature to classify the protocols. The metrics employed for comparison are introduced as follows:

#### *A. Comparison Metrics*

1) *Routing strategy*: Depending on the layer in which the routing decision takes place, the data forwarding mechanisms can be classified as route-over or mesh-under.

- **Route-over**: In a route-over scheme, all routing decisions are taken in the network layer where each node acts as an IP router. In route-over, each link layer hop is an IP hop. The IP routing supports the forwarding of packets between these links. In the forwarding process, IP routing tables and hop-by-hop options are used. For routing and forwarding processes, the network layer makes decisions using the information encapsulated in the IP header. The adaptation layer of 6LoWPAN establishes a direct mapping between the frame and the IP headers. When an IP packet is fragmented by the adaptation layer, fragments are sent to the next hop based on the routing table information. The adaptation layer of the next hop checks received fragments. If all fragments are received successfully, the adaptation layer creates an IP packet from fragments and sends it to the network layer. If the packet is destined for itself, the network layer sends the IP packet to the transport layer, otherwise forwards the packet to the next hop based on the routing table information. If there are one or more fragments missing, then all fragments are retransmitted to one hop distance. After receiving all fragments successfully the adaptation layer creates an IP packet from these fragments and passes it to the network layer. The network layer then forwards or processes the IP packet based on the destination of the packet.
- **Mesh-under**: In this scheme, the network layer does not perform any IP routing. The forwarding decision is made at the adaptation layer which forwards the packet to the destination over multiple radio hops. In Mesh-Under scheme, routing and forwarding are performed at link layer based on 802.15.4 frame. To send a packet to a particular destination, 64 bit address or the 16 bit short address is used and sent it to a neighbor node to move the packet closer to the destination. Because multiple hops based on link layers are used to complete a single IP hop, it is called the mesh-under approach. An IP packet is fragmented by the adaptation layer to a number of fragments. On the other hand, these fragments are delivered to the next hop by mesh routing to reach the destination. Different fragments of an IP packet can go through different paths and they are all gathered at the destination. If all fragments are reached successfully, then the reassembling of the IP packet takes place at the adaptation layer. In case of loss of any fragment, the entire IP packet (this is, all fragments for this IP packet) must be retransmitted to the destination for recovery.

#### *B. Latency*

The concept of latency refers to the maximum time in which a particular message should reach its destination through a communication network. It is important to state that the messages between various entities within the AMI may have different network latency requirements. Thus, while commands exchanged between devices in the distribution network may require lower latency values, information exchanged between sensors and control centers may accept higher values. In [43] two limit value for latency are specified, on the basis of the components that generate the traffic. As for the Phase Measurement Units (PMU) and Control Centres, 10ms is considered as the limit for an accepted value of latency. Regarding the AMI, and considering a reporting rate less than 1 Hz, accepted latency is under 1s.



The messages exchanged can be event driven (e.g., protection and control related) or periodic (e.g., monitoring related) [25]. The network architecture and communication medium must support the diverse requirements. The network architecture will determine if the message sent from one communicating entity to the other will reach its destination in one or more hops. This will directly affect the latency. Similarly, the data rates supported by the communication medium also dictate how fast an entity can communicate an event observed or reply to a message received. The communication technology employed should be able to provide low-latency communications from the data generation or collection point to the eventual destination. Control commands from grid operators should similarly reach smart meters and consumers with minimal delay. For the AMI application, a higher latency may be tolerable for the data collected from smart meters to the control center, but there are control commands in the other direction (from the control center to smart meters) for controlling loads and remote connect/disconnect that may need to communicate immediately.

### *C. Availability*

This metric indicates if the network services are available and will survive possible attacks or failures that could occur. In the HAN scenario, for example, resource depletion is typically not a concern when it comes to a resource such as energy, where both the smart meter and appliances are assumed to have access to the grid power. But computation capabilities and memory constraints could be exploited by keeping these resources fully loaded, affecting the ability of the network to function as desired. Equipment failures may also be more common, especially with the low cost of HAN radio (like the ones provided by ZigBee).

1) *Data delivery priority*: This refers to the priority of arrival of packets throughout the network, and it depends on the needs of the application. The priority may be decided at the time of connection establishment between two applications. Different levels of data delivery priority can be considered, as following: i) high, it is used where the confirmation of end-to-end data delivery is a must and a retry will be mandatory in case of absence of confirmation; ii) medium which is used where end-to-end confirmation is not required but the receiver is able to detect data loss; iii) non-critical, which is used when data loss is acceptable to the receiver. In the latter case, reliability can be improved by means of repetitive messages. The non-critical level can be used for periodic data employed for monitoring purposes.

2) *Reliability*: The grid stability will depend, to a great extent, on the reliability of the distribution network. Hence, it becomes extremely important for the communication backbone to be reliable, in order to enable successful and timely messages exchange. Different events may affect the communication backbone reliability. Some of these failures include time-out failures, network failures, and resource failures. A time-out failure occurs if the time spent in detecting, assembling, delivering and taking action in response to a control message exceeds the timing requirements [44]. A network failure occurs when there is a failure in one of the layers of the protocol suite employed for communication (i.e., the failure may be originated in a logical level, and it prevents packets from reaching their destination although the physical link is operative). Other factors can affect the communication, such as noise and interference. A resource failure means that one end node (i.e., sender or receiver) has failed. One of the mechanisms utilized for reliability measurements purposed is through the Packet Delivery Ratio (PDR), defined as the quotient between the number of packets received and the number of packets sent.

3) *Interoperability*: Interoperability of a smart grid is the ability of diverse systems to work together, use the compatible parts, exchange information or equipment from each other, and work cooperatively to

perform tasks. It enables integration, effective cooperation, and the two-way communications proposed in the AMI concept, among the many interconnected elements of the smart grid. The NIST, which works as the first International Coordinator for smart grid interoperability, developed a framework that includes protocols and standards for information management to achieve interoperability of smart grid devices and system.

4) *Scalability*: This metric can be considered as the ability of a system to handle increasing amounts of work in an efficient manner [45]. Most of the time, the concern lies on the load scalability, which is the easiness for a system to increase its resources to accommodate the increasing load. For this purpose, it is necessary to define the specific requirements for scalability in this dimension. In the AMI case, scalability is related to the ability of the routing table on a router (meter) to scale with the number of nodes in the AMI network. Another form of scalability is related to the costs associated to the deployment of the network when the number of nodes becomes large. It is expected for the communication architecture to work equally well for a small network as well as for a large network.

5) *Ease of deployment*: This refers to the level of feasibility and easiness with which the network can be deployed.

6) *Adaptability*: This refers to the ability of a routing protocol to adapt to different network topologies.

#### *D. Discussion*

In [8] a performance analysis of RPL and Geographic Routing in a Smart Grid context was executed, utilizing OMNeT++ as the simulation tool to implement the routing algorithms. Simulation were run for 500 node AMI scenarios, which were configured for gathering statistics of hop count and end-to-end delay.

The test case used for the performance analysis was constructed based on the scenario that each of the 500 nodes sends multi-point to point traffic directed towards the collector. The application packet rate was set at 1 packet/second. All other nodes in the network simply participated in the routing and were not allowed to transmit when one of the nodes was transmitting. Each node transmitted 100 packets with the collector as the destination. An average of 160ms and 173ms of end-to-end delay were obtained for RPL and Geographical routing, respectively.

Regarding reliability, it was measured by computing the PDR, defined as the total number of received packets at the collector over the total number of packets transmitted by each node. On this matter, RPL showed a constant packet delivery ratio between 98% and 100% for each packet and an average of 99.98% while Geographical routing showed similar performance with an average of 99.30% [8].

Other protocols such as DADR and HYDRO are also analyzed, considering their behavior in testbeds and real deployments. In [39] a study was conducted to determine the behavior of DADR in a 1500 node network topology. The study showed an average PDR of 97.8%. HYDRO, as a combination of both centralized and distributed forwarding mechanisms, shows to have a high reliability according to [40], as multiples routes are provided to a given destination. By constantly evaluating the qualities of the links, the protocol becomes robust in terms of adaptability, as any change in the topology is quickly detected and the protocol reacts to it. An average PDR of 98,9% was obtained when examining the performance of the protocol in a 57-node real deployment.

A summary of the results described in this section can be observed in (Fig. 5), where we compare the routing protocols based on the different metrics for evaluation.

	Similar performance for the given network size and traffic scenario. (500 Node Network)		Similar features: Discovery and Maintenance Mechanisms		Sharing distributed forwarding approaches		
	Geo Routing	RPL	AODV	DSR	DADR	HYDRO	HWMP
<b>Scalability</b>	High: > 2Million metering end points	Implementation specific. (Factors such as trickled timer, operating mode, etc.)	Low. Transmission of hello messages in a large network can become flooding. High cost of processing	Low. Maintenance of routing tables in a large network have a high cost	High. 1500 Node network topology. The protocol doesn't need too much overhead when updating routes.	High. As the protocol is defined by both centralized and distributed mechanisms.	Low. When 25 or more nodes are in the network, congestions occur.
<b>Latency</b>	End-to-end delay: Avg 173ms	End-to-End Delay: Avg 160ms	High. Great amount of overhead generated (hello messages)	Better than that reached by AODV. Less Overhead	High. Data packets need to travel forward to several hops in order to reach the destination.	Better than the reached by DADR. The border router helps to forward packets faster.	End to end delay: 300ms for a 300 node network
<b>Reliability</b>	High: PDR>99%	High: PDR>99.9%	High: PDR>91.4%	High: PDR>96%	High: PDR > 97,8%. Protocol shows capability of learning new routes when link failures.	HIGH: PDR> 98,9%. Multiple routes are provided to a destination. Redundancy.	HIGH: PDR> 96% obtained when 9 nodes were deployed, but the protocol outperform when the number of nodes increase to 25 or more.
<b>Adaptability</b>	Highly adaptable to different network topologies	High. routing paths from the nodes to the central points are constructed according to the deployed architecture	High. Expiration time feature helps to clean up table potential broken and out-of-date links information	High. Any change in the network is detected through the Maintenance Mechanism.	High. Routing paths are updated/removed/constructed according to the topology state.	High. As the protocol involves the evaluation of links qualities according to topologies changes.	Highly adaptable to different network topologies
<b>Routing scheme</b>	Mesh-Under	Route-Over	Mesh-Under	Mesh-Under/Route-Over	Mesh-Under	Mesh-Under/Route-Over	Mesh-Under
<b>Availability</b>	High	High	Medium	Medium	High	High	Low
<b>Data Delivery Priority</b>	Application Dependant	Application Dependant	Application Dependant	Application Dependant	Application Dependant	Application Dependant	Application Dependant
<b>Interoperability</b>	High	High	High	High	High	High	High
<b>Easyness of Deployment</b>	High	High	High	High	Low	High	Low

Fig. 5. Comparison of Routing Protocols in the AMI scope [31] [32] [33] [34] [35] [40]

The choice of the routing protocol may also be considered taking into account the technology that is used for deployment purposes. Thus, a protocol might fit better than other, in a certain technology. For instance, in the case of a mesh technology, a protocol that involves end-to-end retransmission when a packet loss occurs wouldnt be too suitable, as the possibility of fragments loss is bigger in a multihop scheme.

## VI. OPEN NETWORKING ISSUES

In this section, we identify the challenges related to networking issues in AMI networks. We classify them to separate the challenges inherent to the communications technology from those inherent to the routing process.

### *A. Related to Communications Technologies*

When wireless technologies are selected for communications in the AMI, in particular in the NAN domain, aspects such as coverage, reliability, and spectrum management are still open issues [46]. If coverage is increased, this may have a negative impact in terms of capacity of the wireless network, due to interference and re-transmissions caused by larger wireless links. Also, if coverage is reduced to avoid the interference problem, the number of next-hop candidates gets reduced; hence, the process of finding a path to/from the collector may fail. Relaying techniques are being proposed in order to address this trade-off between coverage and capacity [46]. In terms of reliability, the extended list of applications to be supported by the AMI network brings higher standards with variable quality requirements in order to serve such applications. Nonetheless, wireless communications are susceptible to adverse weather conditions and variable propagation patterns, which directly affect the network reliability. Forwarding mechanisms that improve reliability in AMI networks with highly unstable links have been proposed to address this issue [38]. Spectrum management is another key challenge when more and more wireless technologies over unlicensed bands are deployed. Such is the case for 802.11-based and 802.15-based technologies that are employed in the NAN domain. An efficient use of the spectrum is therefore a critical issue.

If the selection is for a wired technology, such as PLC, then network adaptability is an issue to consider. In the majority of cases, bus or star topologies that connect smart meters to a collector are employed with wired technologies. Thus, a single link failure may represent the complete disconnection of a customer premises since the nature of the technology does not permit to find alternative paths (unless redundant links are employed, which increases the deployment costs). Another issue among the different wired technologies is the interoperability. Since Automatic Meter Reading (AMR) has been present for some time, traditional technologies employed at the time did not consider the possibility to interconnect to other networks. Most solutions are built on top of proprietary stacks of protocols that reduce the chances to re-use such technologies in order to deploy the new IP-based applications expected in the AMI network.

### *B. Related to the Routing Process*

There are several open issues that need to be addressed together with routing. On the one hand, there is the need for securing the information that is transmitted across the smart grid. Apart from mitigation of cyber-security attacks, a balance between individual energy consumption data for billing purposes and aggregated data for statistical analysis is required from the AMI [47]. On the other hand, the different natures of traffic due to an expanded list of applications to be deployed in the AMI raises the need for QoS-aware routing. Hence, routing metrics should adapt to fulfill the QoS requirements. Although complex combinations of metrics can be achieved through objective functions such as the one proposed in RPL [28], there is still a lack of flexibility for the objective function to adapt “on the fly” according to the type of traffic that is being routed at a certain time.

Moreover, the NAN domain of an AMI network poses a critical challenge: a network with a number of nodes that start from hundreds and may grow to millions. Although scalability is defined as one of the design factors of routing protocols, those employed in the AMI context need to demonstrate that a minimum level of performance can actually be maintained in a very large network.

## VII. CONCLUSION

In this paper, we have presented a comprehensive survey of communication technologies and routing protocols for Advance Metering Infrastructure deployments, with a special focus on the network domain that connects the smart meters at customer premises and data collectors that connect to the utility, namely the Neighborhood Area Networks (NAN) in AMI. We have described the evolution of the AMI network and the advances in real deployments around the world. As for the communication technologies, we have provided a classification of the different wired and wireless options, identifying the network domain in which each technology fits better. Together with the communication technologies, we have also provided descriptions for the routing protocols proposed for the NAN domain and the set of metrics we have employed for the comparison. Open networking issues are also provided and classified depending on whether they are related to the communication technology or the routing process. A proper balance between coverage and capacity are aspects to be investigated when employing wireless technologies for a NAN network with a large number of nodes. Also, while legacy Automated Meter Reading (AMR) systems can be extended to support other AMI applications, interoperability is still an issue, specially when connection to traditional IP networks is expected. Aspects such as secure routing, privacy protection, and QoS capabilities need further study for routing in the NAN domain to support the extended list of applications to be supported in the AMI network.

## REFERENCES

- [1] V. C. Gungor, D. Sahin, T. Kocak, S. Ergut, C. Buccella, C. Cecati, and G. P. Hancke, "Smart Grid Technologies: Communication Technologies and Standards," *IEEE Transactions on Industrial Informatics*, vol. 7, no. 4, pp. 529–539, Nov. 2011.
- [2] G. Deconinck, "An evaluation of two-way communication means for advanced metering in Flanders (Belgium)," in *2008 IEEE Instrumentation and Measurement Technology Conference*. IEEE, May 2008, pp. 900–905.
- [3] G. Rajalingham, Q.-D. Ho, and T. Le-Ngoc, "Attainable throughput, delay and scalability for geographic routing on smart grid neighbor area networks," in *Wireless Communications and Networking Conference (WCNC), 2013 IEEE*, April 2013, pp. 1121–1126.
- [4] C.-J. Tang and M.-R. Dai, "An Evaluation on Sensor Network Technologies for AMI Associated Mudslide Warning System," in *2010 First International Conference on Networking and Computing*. IEEE, Nov. 2010, pp. 237–242.
- [5] J. Wang and V. C. M. Leung, "A survey of technical requirements and consumer application standards for IP-based smart grid AMI network," in *The International Conference on Information Networking 2011 (ICOIN2011)*. IEEE, Jan. 2011, pp. 114–119.
- [6] C. Bennett and D. Highfill, "Networking AMI Smart Meters," in *2008 IEEE Energy 2030 Conference*. IEEE, Nov. 2008, pp. 1–8.
- [7] Y. Yan, Y. Qian, H. Sharif, and D. Tipper, "A survey on smart grid communication infrastructures: Motivations, requirements and challenges," *Communications Surveys Tutorials, IEEE*, vol. 15, no. 1, pp. 5–20, First 2013.
- [8] G. Iyer, "Wireless Mesh Routing in Smart Utility Networks," M.Sc. thesis, Auburn University, 2011.
- [9] F. E. R. Commission, "Assessment of demand response and advanced metering," FERC, Tech. Rep. December, 2012. [Online]. Available: <http://www.ferc.gov/legal/staff-reports/12-20-12-demand-response.pdf>
- [10] V. A. Vinod Namboodiri and W. Jewell, "Communication Needs and Integration Options for AMI in the Smart Grid," Tech. Rep. March, 2012.
- [11] G. Leon, "Smart Planning for Smart Grid AMI Mesh Networks," EDX Wireless, LLC, Tech. Rep. May, 2011.

- [12] "Understanding ZigBee gateway," Zigbee Alliance, pp. 1–13, September 2010. [Online]. Available: <https://docs.zigbee.org/zigbee-docs/dcn/09-5465.pdf>
- [13] A. I. Sabbah, A. El-Mougy, and M. Ibnkahla, "A Survey of Networking Challenges and Routing Protocols in Smart Grids," *IEEE Transactions on Industrial Informatics*, vol. 10, no. 1, pp. 210–221, Feb. 2014.
- [14] J. Song, S. Han, A. Mok, D. Chen, M. Lucas, and M. Nixon, "WirelessHART: Applying wireless technology in real-time industrial process control," in *Real-Time and Embedded Technology and Applications Symposium, 2008. RTAS '08. IEEE*, April 2008, pp. 377–386.
- [15] G. Montenegro, N. Kushalnagar, J. Hui, and D. Culler, "Transmission of IPv6 Packets over IEEE 802.15.4 Networks," *IETF RFC 4944*, 2007.
- [16] R. Lu, X. Li, X. Liang, X. Shen, and X. Lin, "GRS: The green, reliability, and security of emerging machine to machine communications," *IEEE Communications Magazine*, vol. 49, no. 4, pp. 28–35, Apr. 2011.
- [17] F. Cal, M. Conti, and E. Gregori, "IEEE 802.11 wireless LAN: Capacity analysis and protocol enhancement," 1998.
- [18] W.-F. Alliance, "Wi-Fi for the Smart Grid Mature, Interoperable, Secure Technology for Advanced Smart Energy Management Communications," Tech. Rep. September, 2010.
- [19] v. C. Cheolho Shin, Mi-Kyung Oh, "Smart utility network (sun) standardization in IEEE 802.15.4g," in *OSIA Standards Technology Review Journal*, September 2010.
- [20] M. Bahr, "Proposed routing for IEEE 802.11s WLAN mesh networks," in *Proceedings of the 2Nd Annual International Workshop on Wireless Internet*, ser. WICON '06. New York, NY, USA: ACM, 2006.
- [21] I. W. G. on Broadband Wireless Access, "IEEE 802.16," Tech. Rep. [Online]. Available: <http://ieee802.org/16>
- [22] F. M. J. F. Aguirre, "Viability of WiMAX for smart grid distribution network," in *European International Journal of Science and Technology*, April 2013.
- [23] S. F. Consulting, "Empowering the smart grid with WiMAX," Tech. Rep.
- [24] S. K. Tan, M. Sooriyabandara, and Z. Fan, "M2M communications in the smart grid: Applications, standards, enabling technologies, and research challenges," *Int. J. Digital Multimedia Broadcasting*, vol. 2011, 2011. [Online]. Available: <http://dblp.uni-trier.de/db/journals/ijdmdb/ijdmdb2011.html#TanSF11>
- [25] T. Winter, P. Thubert, A. Brandt, J. Hui, R. Kelsey, P. Levis, K. Pister, R. Struik, J. Vasseur, and R. Alexander, "RPL: IPv6 Routing Protocol for Low-Power and Lossy Networks," *IETF RFC 6550*, 2012.
- [26] J. B. A. Brandt and G. Porcu, "Home Automation Routing Requirements in Low-Power and Lossy Networks," *IETF RFC 5826*, 2010.
- [27] S. D. K. Pister, P. Thubert and T. Phinney, "Industrial Routing Requirements in Low-Power and Lossy Networks," *IETF RFC 5673*, 2009.
- [28] T. W. M. Dohler, T. Watteyne and D. Barthel, "Routing Requirements for Urban Low-Power and Lossy Networks," *IETF RFC 5548*, 2009.
- [29] N. R. J. Martocci, P. De Mil and W. Vermeylen, "Building Automation Routing Requirements in Low-Power and Lossy Networks," *IETF RFC 5867*, 2010.
- [30] B. Pavković, F. Theoleyre, and A. Duda, "Multipath opportunistic RPL routing over IEEE 802.15.4," in *Proceedings of the 14th ACM international conference on Modeling, analysis and simulation of wireless and mobile systems - MSWiM '11*. New York, New York, USA: ACM Press, Oct. 2011, p. 179.
- [31] D. Wang, Z. Tao, J. Zhang, and A. Abouzeid, "RPL based routing for advanced metering infrastructure in smart grid," in *Communications Workshops (ICC), 2010 IEEE International Conference on*, May 2010, pp. 1–6.

- [32] S. Ruhrup, "Theory and practice of geographic routing," in *Ad Hoc and Sensor Wireless Networks: Architectures, Algorithms and Protocols*, February 2009, pp. 1–37.
- [33] E. B.-R. C. Perkins and S. Das, "Ad hoc On-Demand Distance Vector (AODV) Routing," *IETF RFC 3561*, 2003.
- [34] J. M. Toimoor, "Study of the Scalability of Modified AODV-UU Routing Protocol for the Smart Grid Application," M.Sc., University of Windsor, 2013.
- [35] Y. H. D. Johnson and D. Maltz, "The Dynamic Source Routing Protocol (DSR) for Mobile Ad Hoc Networks for IPv4," *IETF RFC 4728*, 2007.
- [36] L. S. PratibhaKevre, "Compare three reactive routing protocols in grid based clusterwireless sensor network using qualnet simulator," *Journal of Information Engineering and Applications*, vol. 4, 2014.
- [37] T. Iwao, "Distributed Autonomous Depth-first Routing Protocol in LLN draft-iwao-roll-dadr-00.txt," *IETF Internet Draft*, 2009.
- [38] S. Cespedes, A. Cardenas, and Iwao, "Comparison of Data Forwarding Mechanisms for AMI Networks," *Proc. IEEE PES ISGT*, pp. 1–8, 2012.
- [39] T. Iwao, K. Yamada, M. Yura, Y. Nakaya, A. A. Cardenas, S. Lee, and R. Masuoka, "Dynamic Data Forwarding in Wireless Mesh Networks," in *2010 First IEEE International Conference on Smart Grid Communications*. IEEE, Oct. 2010, pp. 385–390.
- [40] S. Dawson-Haggerty, A. Tavakoli, and D. Culler, "Hydro: A hybrid routing protocol for low-power and lossy networks," in *Smart Grid Communications (SmartGridComm), 2010 First IEEE International Conference on*, Oct 2010, pp. 268–273.
- [41] W. Meng, R. Ma, and H.-H. Chen, "Smart grid neighborhood area networks: a survey," *Network, IEEE*, vol. 28, no. 1, pp. 24–32, January 2014.
- [42] J.-S. Jung, K.-W. Lim, J.-B. Kim, Y.-B. Ko, Y. Kim, and S.-Y. Lee, "Improving ieee 802.11s wireless mesh networks for reliable routing in the smart grid infrastructure," in *Communications Workshops (ICC), 2011 IEEE International Conference on*, June 2011, pp. 1–5.
- [43] Y. XU, "Latency and Bandwidth Analysis of LTE for a Smart Grid," M.Sc. thesis, Royal Institute of Technology, 2011.
- [44] W. Wang, Y. Xu, and M. Khanna, "A survey on the communication architectures in smart grid," *Computer Networks*, vol. 55, no. 15, pp. 3604–3629, Oct. 2011.
- [45] J. Zhou, R. Hu, and Y. Qian, "Scalable distributed communication architectures to support advanced metering infrastructure in smart grid," *Parallel and Distributed Systems, IEEE Transactions on*, vol. 23, no. 9, pp. 1632–1642, Sept 2012.
- [46] H. Sun, A. Nallanathan, B. Tan, J. Thompson, J. Jiang, and H. Poor, "Relaying technologies for smart grid communications," *Wireless Communications, IEEE*, vol. 19, no. 6, pp. 52–59, December 2012.
- [47] N. Saputro, K. Akkaya, and S. Uludag, "A survey of routing protocols for smart grid communications," *Computer Networks*, vol. 56, no. 11, pp. 2742–2771, 2012.